




Water Analysis Report

District Level Water Analysis Laboratory

U.P. Jal Nigam (Rural), Kannauj



TC-16888

ULR No	TC-16888-26000000033F	Report No	2463	Date	16.05.2026	Page No	1
Customer Details							
Office Name & Address		J.P. Education Academy, Village and Post Uncha, Indira Nagar, Gursahayganj, Kannauj U.P.					
Reference Letter No. & Date		JPEA/Jal Nigam/ Quality Test Report of Water/2026/605 Dated 12.05.2026					
Basic Details of the Sample							
District	Kannauj	Block	Talgram				
Gram Panchayat	Uncha	Village	Uncha				
Habitation	Uncha	Location	J.P. Education Academy				
Water Source	R.O. Plant	Sample No.	1				
Quantity of the Sample	2000ml	Date of Sample Collection	12.05.2026				
Receiving Date	12.05.2026	Sample Collector	Mr. Siddharth Gupta				
Sample Depositor	Mr. Siddharth Gupta	Sampling Method	IS 17614 (Part 1):2021				
Analysis Start Date	14.05.2026	Analysis Completion Date	14.05.2026				
Environmental Condition							
Temperature		27°C		Humidity		52%	
Technical Data of Analysis							
S.N o	Analysed Parameter	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis		
			Acceptable Limit	Permissible Limit			
1	2	3	4	5	6		
1	Odour	A	Agreeable	Agreeable	IS:3025(Part-5):2018		
2	Taste	A	Agreeable	Agreeable	IS:3025(Part-8):2023		
3	pH	7.68	6.5-8.5	6.5-8.5	IS 3025(Part 11):2022 Electrometric Method		
4	Turbidity(NTU)	0.82	1	5	IS 3025 (Part 10):2023		
5	TDS(mg/L)	132	500	2000	IS 3025 (Part 16):2023		
6	Chloride(mg/L)	23	250	1000	IS 3025(Part 32):2019		
7	Total Alkalinity(mg/L)	188	200	600	IS 3025 (Part 23):2023		
8	Total Hardness(mg/L)	176	200	600	IS 3025 (Part 21):2019		
9	Calcium(mg/L)	23.25	75	200	IS 3025(Part 40): 2023		
10	Magnesium(mg/L)	28.68	30	100	IS 3025 (Part 46):2023		
11	Sulphates(mg/L)	99.56	200	400	APHA 24th Edition 4500 SO ₄ Method F, 2023		
12	Nitrate(mg/L)	17.41	45	45	APHA 24th Edition Method 4500 NO ₃ ⁻ B, 2023		
13	Fluoride(mg/L)	0.439	1	1.5	APHA 24th Edition 4500 F Method C, 2023		
14	Iron(mg/L)	0.36	0.3	1.0	APHA 24th Edition-3500-Fe Method B, 2023		
Note							
1. This certificate refers only to the particular sample(s) submitted for testing.							
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Head of the Laboratory.							
3. The Test results reported in this certificate are valid at the time of and under the stated conditions of Measurements.							
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue .							
5. Source of Sample is Not Verified By Laboratory.							
 AMARENDRA SINGH PRINCIPAL J. P. EDUCATION ACADEMY Deputy Quality Manager				 Authorized Signatory Mohd. Amjad Khan Quality Manager			
				 INDRA KUMAR GUPTA MANAGER J. P. EDUCATION ACADEMY Indra Nagar, Tirwa Road, Gursahayganj, Kannauj (U.P.)			
End of the Report							

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 04/06/2026

It is certified that an inspection team headed by Dr. NEERAJ KUMAR (MO), Dr. RITESH KUMAR (GMC Tirwa)
Shri. MAHENDRA PAL SINGH (PHARMACEUTIST), Shri. YOGENDRA SHUKLA (DRA)

(Name of Officers with designation) from CMC Gursahaiganj, Kannauj PHED

inspected the J.P. Education Academy, Village Uncha, Pargana Talgram
Tirwa Road, Gursahaiganj, Kannauj.

(Name & Address of the school) on (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. ULR No - TC.16888000000033F, 2463 dated 16-05-2026

of U.P. Jal Nigam (Rural) Kannauj (PHED Lab) certified that the

J.P. Education Academy (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year from present date i.e. 03/06/2027

Signature with Seal: 

Name

Designation

Name & Address of the Office / Department: CMC Gursahaiganj

Dr. SHASHANK CHANDRA

MEDICAL OFFICER

To J.P. Education Academy
Village Uncha, Pargana Talgram
Tirwa Road, Gursahaiganj
(Name & Address of the Institution)
Kannauj - 209722

प्रभारी चिकित्सा अधिकारी
सीएससीओ गुरसाहागंज
जनपद-कन्नौज

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


AMARENDRA SINGH
PRINCIPAL

J. P. EDUCATION ACADEMY
Indra Nagar, Tirwa Road, Gursahaiganj, Kannauj (U.P.)


INDRA KUMAR GUPTA
MANAGER

J. P. EDUCATION ACADEMY
Indra Nagar, Tirwa Road, Gursahaiganj, Kannauj (U.P.)