


6701 EVANSTAD DR N
MAPLE GROVE, MN 55369

REFER TO P&ID LEAD SHEETS FOR SYMBOLS AND ABBREVIATIONS
ALL PIPING AND DUCT SHOWN INSIDE VENDOR BUBBLE FURNISHED AND
SUPPLIED BY CONTRACTOR

1 ALL PROCESS SUPPLY AND EXHAUST AIR DUCTWORK TO BE INSULATED WITH 2" THICK FIBERGLASS INSULATION IN MECHANICAL/TECHNICAL SPACE. ALL DUCTWORK IN CLEAN SPACES TO BE INSULATED WITH 2" THICK ELASTOMERIC FOAM INSULATION (E1 or E2).



NT

UPSHER-SMITH

Partners in Health Since 1919

CONSULTING ENGINEER

HORWITZ 

7400 49th AVENUE NORTH
NEW HOPE, MN 55428
(763) 533-1900
www.horwitzinc.com

PROJECT TITLE

PROJECT KEYSTONE - PHASE 1

[illegible]

I HEREBY CERTIFY THAT THIS PLAN,
 SPECIFICATION OR REPORT WAS
 PREPARED BY ME OR UNDER MY
 DIRECT SUPERVISION AND THAT I AM
 A DULY LICENSED ENGINEER UNDER
 THE LAWS OF THE STATE OF
 MINNESOTA.

Date 05/25/22 LIC NO _____

CONFIDENTIAL - THIS DRAWING IS THE PROPERTY OF UPSHER-SMITH. THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE OWNER.

FIG. NO.	2022.1720	DESIGNED BY:	Designer
SCALE:	6" = 1'-0"	CHECKED BY:	Checker
TEXT SIZE:	30x42	APPROVED BY:	Approver

WING TITLE

PC&ID MACHINE TOWER GPCG PRO 300
VENDOR SHEET 3

PID-3000.3