

PROJECT LOCATION

6701 EVANSTAD DR N
MAPLE GROVE, MN 55369

GENERAL NOTES


1. REFER TO P&ID LEAD SHEETS FOR SYMBOLS AND ABBREVIATIONS.
2. ALL AUTOMATED VALVES ARE TO BE FAIL-CLOSE UNLESS OTHERWISE INDICATED.
3. CONNECTION POINTS TO EQUIPMENT ARE SHOWN FOR REFERENCE ONLY.
4. PIPING AND DUCT TAKEOFFS ARE SHOWN SCHEMATICALLY. FOR ACTUAL TAKEOFF ORDER, SEE PLANS.

SHEET NOTES

INTERLOCK NOTES

1. INTERLOCK TO STOP FAN WITH RETURN AIR FIRE ALARM
2. INTERLOCK TO STOP FAN WITH SUPPLY AIR FIRE ALARM
3. INTERLOCK TO STOP FAN WITH PRESSURE ALARM
4. INTERLOCK TO STOP FAN WITH SOFTWARE LOW TEMPERATURE ALARM
5. INTERLOCK TO CLOSE HUMIDIFIER VALVE WITH SOFTWARE HUMIDITY HIGH LIMIT

KEYPLAN



CLIENT

UPSHER-SMITH

Partners in Health Since 1919

CONSULTING ENGINEER

HORWITZ
7400 49th AVENUE NORTH
NEW HOPE, MN 55428
(763) 533-1900
www.horwitzinc.com

PROJECT TITLE

PROJECT KEYSTONE - PHASE 1

REV	BY	DATE	DESCRIPTION
0	RS	31JULY20	ISSUED FOR CONSTRUCTION
1	RS	15JAN21	ASI 006
2	RS	05APRIL21	ASI 011
3	RS	27MAY21	ASI 012
A		01OCT21	FOR COORDINATION
4	RS	17DEC21	ASI 014
5	RS	05/25/22	AS RECORDED

LICENSEE

I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATION OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Todd Matelski
TODD MATELSKI
Date 05/25/22 LIC NO 50819

CONFIDENTIAL - THIS DRAWING IS THE PROPERTY OF UPSHER-SMITH. THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE OWNER.

PROJ. NO.	2022.1720	DESIGNED BY:	BB
SCALE:	12" = 1'-0"	CHECKED BY:	RS
SHEET SIZE:	30x42	APPROVED BY:	TM

DRAWING TITLE

AHU-101 LEVEL 1 VAV P&ID

DRAWING NUMBER

PID-8101

ENTIRE SHEET REISSUED FOR COORDINATION

