

6701 EVANSTAD DR N
MAPLE GROVE, MN 55369



UPSHER-SMITH

CONSULTING ENGINEER

HORWITZ
7400 49th AVENUE NORTH
NEW HOPE, MN 55428
(763) 533-1900
www.horwitzinc.com

PROJECT KEYSTONE - PHASE 1

I HEREBY CERTIFY THAT THIS PLAN,
SPECIFICATION OR REPORT WAS
PREPARED BY ME OR UNDER MY
DIRECT SUPERVISION AND THAT I AM
A DULY LICENSED ENGINEER UNDER
THE LAWS OF THE STATE OF
MINNESOTA.

Date 05/24/24 LIC NO

CONFIDENTIAL - THIS DRAWING IS THE PROPERTY OF UPSHER-SMITH. THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE OWNER.

DRAWING TITLE

WASH IN PLACE ROOM 1730

PID-7330

1. NOT USED.
2. EXISTING OWNER PROVIDED EQUIPMENT.
3. NOT USED
4. PROVIDE SAMPLE SPOOL FOR REMOVAL FOR SAMPLE BOTTLE. TERMINATE AT 4' A.F.F.
5. PROVIDE 4" WIDE SS04 FUNNEL CONNECTING TO LINE. PROVIDE ASSE BPE AIR GAP BETWEEN SAMPLE POINT AND FUNNEL.
6. FOR CALIBRATION OF FLOW METER, REMOVE CONDUCTIVITY SENSOR AND INSTALL STANDARD FROM THE MAIN PIPING TO THE FLOOR DRAIN.

