NOTE: SHORT DASH PIPING SHOWN AFTER CAPPED VALVES REPRESENTS PHASE 2 SPACES. **PROJECT LOCATION** 6701 EVANSTAD DR N MAPLE GROVE, MN 55369 HEATING WATER SUPPLY 1-1/2"-HWS-CU01-F4 FROM HEATING WATER DISTRIBUTION RE: PID-9510 TO HEATING WATER 1-1/2"-HWR-CU01-F4 DISTRIBUTION RE: PID-9510 HEATING WATER SUPPLY TO VAV-RH-2520 0.5 GPM > HEATING WATER RETURN FROM VAV-RH-2520 RE: PID-8413 HEATING WATER SUPPLY TO VAV-RH-2530 1.0 GPM RE: PID-8413 HEATING WATER RETURN FROM VAV-RH-2530 HEATING WATER SUPPLY 0.9 GPM 3/4"-HWS-CU01-F4 TO VAV-RH-3150 HEATING WATER RETURN FROM VAV-RH-3150 HEATING WATER SUPPLY 2.1 GPM

3/4"-HWS-CU01-F4

TO VAV-RH-2540 HEATING WATER RETURN FROM VAV-RH-2540 RE: PID-8413 HEATING WATER SUPPLY 1.0 GPM 3/4"-HWS-CU01-F4 TO VAV-RH-2550 RE: PID-8413 FROM VAV-RH-2550 RE: PID-8413 HEATING WATER SUPPLY 2.5 GPM 3/4"-HWS-CU01-F4 TO VAV-RH-3140B . RE: PID-8419 HEATING WATER RETURN FROM VAV-RH-3140B HEATING WATER SUPPLY 1.0 GPM 3/4"-HWS-CU01-F4 TO VAV-RH-3140A HEATING WATER RETURN FROM VAV-RH-3140A Partners in Health Since 1919 CONSULTING ENGINEER HEATING WATER SUPPLY TO VAV-RH-3170B → 0.5 GPM HORWITZ HEATING WATER RETURN FROM VAV-RH-3170B 7400 49th AVENUE NORTH NEW HOPE, MN 55428 (763) 533-1900 HEATING WATER SUPPLY www.horwitzinc.com TO FCU-3004-STR-D 0.8 GPM PROJECT TITLE HEATING WATER RETURN FROM FCU-3004-STR-D PROJECT KEYSTONE - PHASE 1 HEATING WATER SUPPLY
 REV
 BY
 DATE
 DESCRIPT

 0
 RS
 31JULY20
 ISSUED FOR CONSTRUCTION
 1"-HWS-CU01-F4 TO UH-3004.1 1"-HWS-¢U01-F4 4.0 GPM
 1
 RS
 15JAN21
 ASI 006

 A
 01OCT21
 FOR COORDINATION
 HEATING WATER RETURN 2 RS 17DEC21 ASI 014 1"-HWR-CU01-F4 1"-HWR-CU01-F4 FROM UH-3004.1 3 RS 05/25/22 AS RECORDED HEATING WATER SUPPLY 2.6 GPM 3/4"-HWS-CU01-F4 TO VAV-RH-2560 RE: PID-8413 HEATING WATER RETURN FROM VAV-RH-2560 LICENSEE RE: PID-8413 I HEREBY CERTIFY THAT THIS PLAN,
SPECIFICATION OR REPORT WAS
PREPARED BY ME OR UNDER MY
DIRECT SUPERVISION AND THAT I AM
A DULY LICENSED ENGINEER UNDER
THE LAWS OF THE STATE OF HEATING WATER SUPPLY 1.0 GPM 3/4"-HWS-CU01-F4 TO VAV-RH-3175 . RE: PID-8415 HEATING WATER RETURN MINNESOTA. FROM VAV-RH-3175 HEATING WATER SUPPLY 0.5 GPM

3/4"-HWS-CU01-F4

TO VAV-RH-3170A Date 05/25/22 LIC NO 50819 RE: PID-8415 HEATING WATER RETURN FROM VAV-RH-3170A 3/4"-HWR-CU01-F4 CONFIDENTIAL - THIS DRAWING IS THE PROPERTY OF UPSHER-SMITH. THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE OWNER. HEATING WATER SUPPLY 0.8 GPM 3/4"-HWS-CU01-F4 TO FCU-3165 PROJ. NO. 2022.1720 CHECKED BY: JD SCALE: 12" = 1'-0" SHEET SIZE: 30x42 APPROVED BY: TM HEATING WATER RETURN FROM FCU-3165 DRAWING TITLE HEATING WATER DISTRIBUTION P&ID DRAWING NUMBER PID-9512 ENTIRE SHEET REISSUED FOR COORDINATION