


PROJECT LOCATION

1. REFER TO P&ID LEAD SHEETS FOR SYMBOLS AND ABBREVIATIONS 2. ALL PIPING AND DUCT SHOWN INSIDE VENDOR BUBBLE FURNISHED AND

1 ALL PROCESS SUPPLY AND EXHAUST AIR DUCTWORK TO BE INSULATED WITH 2" THICK FIBERGLASS INSULATION IN MECHANICAL/TECHNICAL SPACE, ALL DUCTWORK IN CLEAN SPACES TO BE INSULATED WITH 2" THICK ELASTOMERIC FOAM INSULATION (E



HORWITZ 7400 49th AVENUE NORTH NEW HOPE, MN 55428

PROJECT KEYSTONE - PHASE

REV	BY	DATE	DESCRIPTION
Α		17DEC21	FOR RECORD
0	RS	05/25/22	AS RECORDED

I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATION OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF

CONFIDENTIAL - THIS DRAWING IS THE PROPERTY OF UPSHER-SMITH. THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE OWNER.

PROJ. NO.	2022.1720	DESIGNED BY:	Designer
SCALE:	6" = 1'-0"	CHECKED BY:	Checker
SHEET SIZE:	30x42	APPROVED BY:	Approver

P&ID MACHINE TOWER EXHAUST AIR

DRAWING NUMBER

PID-3000.5