

Ø0.5"OD (16A@ 460VAC/3ph/60Hz/3C+G, for HPU)  
0.38"ID,0.63"OD (AIR 105psi @ 6 SCFM)  
20'cable from this point-By SL-LLC

CLEAN COMPRESSED AIR  
RE:PID-5100

NO NETWORK DROP

GLATT IBC  
1000L


IBC LIFT  
ENC01-PH-001  
ROOM#2260

SUPPORT ARM FOR CHARGE PORT

VENDOR DRAWING NO.	REV	SHEET	MANUFACTURER
20Y/48023/ENC01-PH-001/LINE ROUTING	D	1 OF 1	SERVOLIFT LLC

PROJECT LOCATION

6701 EVANSTAD DR N  
MAPLE GROVE, MN 55369



UPSHER-SMITH

Partners in Health Since 1919

**HORWITZ**  
7400 49th AVENUE NORTH  
NEW HOPE, MN 55428  
(763) 533-1900  
www.horwitzinc.com

PROJECT TITLE

PROJECT KEYSTONE - PHASE 1

REV	BY	DATE	DESCRIPTION
A	17DEC21	FOR RECORD	
D	RS	05/25/22	AS RECORDED

I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATION OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Date 05/25/22 LIC NO

CONFIDENTIAL - THIS DRAWING IS THE PROPERTY OF UPSHER-SMITH. THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE OWNER.

PROJ. NO.	2022.1720	DESIGNED BY:	Designer
SCALE:	12" = 1'-0"	CHECKED BY:	Checker
SHEET SIZE:	30x42	APPROVED BY:	Approver

DRAWING TITLE

ENC01-PH-001 VENDOR P&ID SHEET 1

DRAWING NUMBER

PID-5100.1