


6701 EVANSTAD DR N
MAPLE GROVE, MN 55369

1. REFER TO P&ID LEAD SHEETS FOR SYMBOLS AND ABBREVIATIONS.
2. ALL AUTOMATED VALVES ARE TO BE FAIL-CLOSE UNLESS OTHERWISE INDICATED.
3. CONNECTION POINTS TO EQUIPMENT ARE SHOWN FOR REFERENCE ONLY.
4. PIPING AND DUCT TAKEOFFS ARE SHOWN SCHEMATICALLY. FOR ACTUAL TAKEOFF ORDER, SEE PLANS.

1. INTERLOCK TO STOP FAN WITH RETURN AIR FIRE ALARM
2. INTERLOCK TO STOP FAN WITH SUPPLY AIR FIRE ALARM
3. INTERLOCK TO STOP FAN WITH PRESSURE ALARM



CONSULTING ENGINEER



PROJECT TITLE

PROJECT KEYSTONE - PHASE 1

[illegible]

LICENSEE

I HEREBY CERTIFY THAT THIS PLAN,
SPECIFICATION OR REPORT WAS
PREPARED BY ME OR UNDER MY
DIRECT SUPERVISION AND THAT I AM
A DULY LICENSED ENGINEER UNDER
THE LAWS OF THE STATE OF
MINNESOTA.

TODD MATELSKI
Date 05/25/22 LIC NO 50819

CONFIDENTIAL - THIS DRAWING IS THE PROPERTY OF UPSHER-SMITH. THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE OWNER.

PROJ. NO.	2022.1720	DESIGNED BY:	BB
SCALE:	12" = 1'-0"	CHECKED BY:	RS
SHEET SIZE:	30x42	APPROVED BY:	TM

DRAWING TITLE

AHU-303 RECIRCULATION P&ID

DRAWING NUMBER

PID-8303

ENTIRE SHEET REISSUED FOR COORDINATION

