









PROJECT LOCATION

6701 EVANSTAD DR N MAPLE GROVE, MN 55369

**GENERAL NOTES** 

REFER TO P&ID LEAD SHEETS FOR SYMBOLS AND ABBREVIATIONS.
 ALL AUTOMATED VALVES ARE TO BE FAIL-CLOSE UNLESS OTHERWISE INDICATED.
 CONNECTION POINTS TO EQUIPMENT ARE SHOWN FOR REFERENCE ONLY.
 PIPING AND DUCT TAKEOFFS ARE SHOWN SCHEMATICALLY. FOR ACTUAL TAKEOFF ORDER, SEE PLANS.

SHEET NOTES

1. SUPPLY AIR: VAV-XXXX (XXXX IS EQUAL TO ROOM NUMBER SERVED)
2. RETURN AIR: RAV-XXXX (XXXX IS EQUAL TO ROOM NUMBER SERVED)
3. EXHAUST AIR: EAV-XXXX (XXXX IS EQUAL TO ROOM NUMBER SERVED)
4. ALL RETURN AIR AND EXHAUST AIR ROOM GRILLES HAVE A 2" MERV 8 FILTER
5. ALL RETURN AIR AND EXHAUST AIR VALVES HAVE A MERV 13 FILTER BOX BEFORE THE VALVE
6. SPACE TEMPERATURE TRANSMITTERS ARE TO BE LOCATED IN THE RETURN AIR DUCT JUST BEYOND THE MERV 8 FILTER
7. HALF TONE PIDS REPRESENT PHASE TWO SPACE.



UPSHER-SMITH
Partners in Health Since 1919

CONSULTING ENGINEER

7400 49th AVENUE NORTH NEW HOPE, MN 55428 (763) 533-1900 www.horwitzinc.com

PROJECT TITLE

PROJECT KEYSTONE - PHASE 1

REV BY DATE DESCRIPTION
4 RS 05/25/22 AS RECORDED

NSEE

I HEREBY CERTIFY THAT THIS PLAN,
SPECIFICATION OR REPORT WAS
PREPARED BY ME OR UNDER MY
DIRECT SUPERVISION AND THAT I AM
A DULY LICENSED ENGINEER UNDER
THE LAWS OF THE STATE OF

TODD MATELSKI

Date 05/25/22 LIC NO 50819

CONFIDENTIAL - THIS DRAWING IS THE PROPERTY OF UPSHER-SMITH. THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE OWNER.

 PROJ. NO.
 2022.1720
 DESIGNED BY:
 BB

 SCALE:
 12" = 1'-0"
 CHECKED BY:
 RS

 SHEET SIZE:
 30x42
 APPROVED BY:
 TM

DRAWING TITLE

SPACE AIR DISTRIBUTION P&ID

DRAWING NUMBER

PID-8401