

6701 EVANSTAD DR N  
MAPLE GROVE, MN 55369

REFER TO P&ID LEAD SHEETS FOR SYMBOLS AND ABBREVIATIONS.  
ALL AUTOMATED VALVES ARE TO BE FAIL-CLOSE UNLESS OTHERWISE  
DICATED.  
CONNECTION POINTS TO EQUIPMENT ARE SHOWN FOR REFERENCE  
ONLY.  
PIPING AND DUCT TAKEOFFS ARE SHOWN SCHEMATICALLY. FOR ACTUAL  
TAKEOFF ORDER, SEE PLANS.

- 1 CONTROL VALVE FURNISHED BY AHU VENDOR
- 2 STRAINER FURNISHED BY AHU VENDOR
- 3 INSIDE OF VENDOR BOUNDARY IS THE VENDOR P&ID, ALL PIPING TO BE PROVIDED BY CONTRACTOR, INCLUDING ALL APPURTENANCES



CLIENT

Partners in Health Since 1919

CONSULTING ENGINEER

7400 49th AVENUE NORTH  
NEW HOPE, MN 55428  
(763) 533-1900  
[www.horwitzinc.com](http://www.horwitzinc.com)

PROJECT TITLE

## PROJECT KEYSTONE - PHASE 1

[illegible]

**LICENSEE**

I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATION OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

TODD MATELSKI  
Date 05/25/22 LIC NO 50819

CONFIDENTIAL - THIS DRAWING IS THE PROPERTY OF UPSHER-SMITH. THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE OWNER.

PROJ. NO. 2022.1720	DESIGNED BY: Designer
SCALE: 12" = 1'-0"	CHECKED BY: Checker
SHEET SIZE: 30x42	APPROVED BY: Approver

DRAWING TITLE

TABLET COATING #1 AIR HANDLING  
UNIT VENDOR P&ID - ROOM 3150

DRAWING NUMBER

PID-5201