

PROJECT LOCATION

6701 EVANSTAD DR N
MAPLE GROVE, MN 55369


GENERAL NOTES

1. REFER TO P&ID LEAD SHEETS FOR SYMBOLS AND ABBREVIATIONS.
2. ALL AUTOMATED VALVES ARE TO BE FAIL-CLOSE UNLESS OTHERWISE INDICATED.
3. CONNECTION POINTS TO EQUIPMENT ARE SHOWN FOR REFERENCE ONLY.
4. PIPING AND DUCT TAKEOFFS ARE SHOWN SCHEMATICALLY. FOR ACTUAL TAKEOFF ORDER, SEE PLANS.

SHEET NOTES

- (1) CONTROL VALVE FURNISHED BY AHU VENDOR
- (2) STRAINER FURNISHED BY AHU VENDOR
- (3) INSIDE OF VENDOR BOUNDARY IS THE VENDOR PAID. ALL PIPING TO BE PROVIDED BY CONTRACTOR, INCLUDING ALL APPURTENANCES. ALL CONTROL DEVICES & CONTROL APPURTENANCES TO BE PROVIDED BY AHU VENDOR.

KEYPLAN



CLIENT

UPSHER-SMITH

Partners in Health Since 1919

CONSULTING ENGINEER

HORWITZ

7400 49th AVENUE NORTH
NEW HOPE, MN 55428
(763) 533-1900
www.horwitzinc.com

PROJECT TITLE

PROJECT KEYSTONE - PHASE 1

REV	BY	DATE	DESCRIPTION
A		01/03/21	FOR COORDINATION
0	RS	17DEC21	AS 014
1	RS	05/25/22	AS RECORDED

LICENSEE

I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATION OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

TODD MATELSKI

TODD MATELSKI
Date 05/25/22 LIC NO 50819

CONFIDENTIAL - THIS DRAWING IS THE PROPERTY OF UPSHER-SMITH. THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE OWNER.

PROJ. NO.	2022.1720	DESIGNED BY:	BB
SCALE:	12" = 1'-0"	CHECKED BY:	RS
SHEET SIZE:	30x42	APPROVED BY:	TM

DRAWING TITLE

FLUID BED PROCESSOR #1 AIR
HANDLING UNIT VENDOR P&ID - ROOM
2810

DRAWING NUMBER

PID-3001