

WATER QUALITY COMPLIANCE REPORT

Apache Junction Water System

Serving Apache Junction — Pinal County, Arizona

Report Period	Q1 2026 (Jan–Mar)	Compliance Status	WARNING
---------------	-------------------	-------------------	---------

1. Executive Summary

During the Q1 2026 (Jan–Mar) monitoring period, the Apache Junction water system recorded a turbidity measurement of 0.52 NTU, which exceeds the EPA treatment-technique threshold of 0.5 NTU and triggers a WARNING status. While no acute health-based MCL violation occurred, the Water Quality Division has initiated enhanced monitoring and corrective filtration review. This report documents the exceedance, root-cause assessment, and remediation plan.

2. Contaminant Monitoring Results

Parameter	Result	EPA Limit	Status
Turbidity (NTU)	0.52	< 0.5	EXCEEDANCE
Lead (ppb)	0.04	≤ 15	PASS
Copper (ppm)	0.22	≤ 1.3	PASS
Chlorine Residual (ppm)	1.3	0.2 – 4.0	PASS
pH	7.4	6.5 – 8.5	PASS
Total Dissolved Solids (ppm)	410	≤ 500	PASS
Total Coliform Bacteria	Absent	Absent	PASS

3. Sampling Methodology

Samples were collected from representative points across the Apache Junction distribution network in accordance with 40 CFR Part 141. Turbidity was measured continuously via inline nephelometric sensors with grab-sample confirmation. Lead and copper were sampled at high-risk service connections following the Lead and Copper Rule protocol. All laboratory analyses were performed by an Arizona Department of Health Services certified laboratory.

4. Corrective Actions

The Water Quality Division has implemented the following corrective measures for the Apache Junction system: (a) increased filtration backwash frequency; (b) daily turbidity grab sampling until three consecutive readings fall below 0.45 NTU; (c) inspection of filter media integrity; and (d) review of source-water conditions following recent seasonal runoff. A follow-up compliance report will be filed within 30 days. No public notification is required at the WARNING level, but customers may request water quality information by contacting AWC

Customer Service.

Prepared by the Arizona Water Company Water Quality Division. This document constitutes a regulatory filing under the Safe Drinking Water Act and contains operational compliance data classified as Company Confidential. Reviewed by: Dr. Susan Park, Water Quality Manager.