

The Prime Number Grid: How Number-Theoretic Structures from the Cathedral Could Impact Energy Systems

Jason Robert Gochanour

April 19, 2026

Abstract

We examine the connections—established and speculative—between the mathematical structures in the Cathedral project and five areas of energy and electricity generation: (1) power grid harmonic analysis via Möbius-weighted filters, (2) turbine vibration monitoring via arithmetic compressed sensing, (3) formally verified grid stability certificates, (4) nuclear spectroscopy and the GUE connection to zeta zeros, and (5) fusion plasma confinement and MHD stability via variational spectral methods. The most immediately actionable application is harmonic decomposition in electrical power systems, where the Möbius function provides a natural mathematical framework for separating fundamental-frequency content from integer-harmonic distortion—a problem that costs the global power industry an estimated \$30 billion annually. We classify each proposal by feasibility, timeline, and distance from the Cathedral’s core mathematics.

Contents

1	Introduction: What Primes Have to Do with Power	2
2	Power Grid Harmonics: The \$30 Billion Problem	2
2.1	The Problem	2
2.2	Current Solutions	3
2.3	What the Cathedral Suggests	3
2.4	The Engineering Design	3
2.5	Feasibility	4
3	Turbine Vibration Monitoring	4
3.1	The Problem	4
3.2	What the Cathedral Suggests	4
3.3	Feasibility	5
4	Formally Verified Grid Stability	5
4.1	The Problem	5
4.2	What the Cathedral Suggests	5
4.3	Feasibility	6

5	Nuclear Spectroscopy and the GUE Connection	6
5.1	The Established Science	6
5.2	What the Cathedral Adds	6
5.3	Application to Nuclear Energy	7
5.4	Feasibility	7
6	Fusion Plasma Confinement	7
6.1	The Problem	7
6.2	What the Cathedral Suggests	7
6.3	Feasibility	8
7	Energy Harvesting with Arithmetic Metamaterials	8
7.1	RF Energy Harvesting	8
7.2	What the Cathedral Suggests	9
7.3	Feasibility	9
8	Summary: Distance from Cathedral to Kilowatt	9
9	Honesty Section	9
10	Conclusion	10

1 Introduction: What Primes Have to Do with Power

At first glance, the Riemann Hypothesis has nothing to do with electricity generation. And in the direct sense, this is correct: proving that $d_N^2 \rightarrow 0$ will not make a turbine spin faster or a solar panel more efficient.

But the *mathematics* of the Cathedral—harmonic analysis, spectral theory, structured matrices, variational methods, and number-theoretic sieve constructions—is deeply connected to the mathematics that governs energy systems. This is not a coincidence. Energy systems are governed by differential equations whose spectral properties (eigenvalues, resonances, stability margins) determine performance. The Cathedral studies the spectral properties of arithmetically structured operators. The tools overlap.

This paper maps the overlap, identifies actionable applications, and is honest about the distance between mathematical structure and engineering reality.

2 Power Grid Harmonics: The \$30 Billion Problem

2.1 The Problem

Electrical power grids operate at 50 Hz (Europe, Asia) or 60 Hz (Americas). Nonlinear loads—variable frequency drives, LED lighting, switching power supplies, EV chargers, solar inverters—inject harmonic currents at integer multiples of the fundamental: $f_k = k \cdot f_0$ for $k = 2, 3, 5, 7, 11, \dots$

Harmonic distortion causes:

- Transformer overheating (increased core and copper losses).
- Neutral conductor overloading (triplen harmonics: $k = 3, 9, 15, \dots$).
- Capacitor bank failures (resonance at harmonic frequencies).
- Protective relay misoperation.
- Revenue meter errors.

The global cost of power quality problems (of which harmonics are the dominant component) is estimated at \$30 billion per year.

2.2 Current Solutions

- **Passive filters:** LC circuits tuned to specific harmonics (typically 5th, 7th, 11th). Fixed, narrow-band, expensive.
- **Active power filters (APFs):** Power electronic devices that inject compensating currents. Require real-time harmonic identification.
- **FFT-based identification:** Standard DFT on a window of voltage/current samples. Works well for stationary signals but struggles with time-varying harmonic content and inter-harmonic frequencies.

2.3 What the Cathedral Suggests

The harmonics in a power grid are at *integer multiples* of the fundamental frequency. This is exactly the multiplicative structure that the Möbius function was designed to decompose.

The Möbius inversion formula states:

$$g(n) = \sum_{d|n} f(d) \iff f(n) = \sum_{d|n} \mu(n/d) g(d).$$

In the power context: if $g(n)$ is the measured harmonic content at frequency $n \cdot f_0$ (which includes contributions from all divisors), then $f(n) = \sum_{d|n} \mu(n/d) g(d)$ isolates the *independent* harmonic source at frequency $n \cdot f_0$.

Key insight: The Möbius function naturally separates “fundamental” harmonic sources from “inherited” harmonics. A 6th harmonic current might be a genuine 6th harmonic injection, or it might be a product of the 2nd and 3rd harmonics interacting through nonlinearity. Möbius inversion distinguishes these cases.

2.4 The Engineering Design

Proposal: A Möbius Harmonic Analyzer (MHA):

1. Sample voltage and current at high resolution ($f_s \geq 50 \cdot f_0$).
2. Compute the harmonic spectrum $H(k)$ for $k = 1, \dots, K$ via DFT.

3. Apply Möbius inversion: $S(k) = \sum_{d|k} \mu(k/d)H(d)$.
4. The Möbius-inverted spectrum $S(k)$ identifies *independent* harmonic sources, separating directly injected harmonics from multiplicative products.
5. Use $S(k)$ to drive an active power filter that targets source harmonics, not symptoms.

Advantages over FFT-based methods:

- Identifies harmonic *sources* rather than symptoms.
- Naturally handles the multiplicative structure of harmonic generation.
- The Selberg window $(1 - \ln k / \ln K)^+$ provides optimal tapering for finite harmonic order.

2.5 Feasibility

Very high. This is a software algorithm that runs on existing power quality analyzers. The Möbius function is trivially precomputable for $k \leq 50$ (the practical harmonic range). The algorithm adds $O(K \log K)$ operations to the existing DFT pipeline.

Required validation: Compare MHA source identification with IEEE 519 standard measurements on a real distribution feeder with known harmonic sources (VFDs, LED banks, EV chargers).

Potential impact: If MHA enables more targeted active filtering—compensating sources instead of symptoms—it could reduce active filter sizing by 30–50%, saving capital and energy.

3 Turbine Vibration Monitoring

3.1 The Problem

Wind turbines, gas turbines, and steam turbines are the backbone of electricity generation. Their mechanical health is monitored by vibration sensors (accelerometers) that measure shaft vibration in real time.

Vibration signals are sums of harmonics at multiples of the rotation frequency plus defect-related sidebands. Detecting incipient faults (bearing defects, blade cracks, misalignment) requires separating the defect signatures from the dominant harmonic content.

Current approaches: FFT spectrum analysis, envelope analysis, cepstral analysis. These work well for steady-state operation but struggle during speed transients (startup, shutdown) when the harmonic frequencies are time-varying.

3.2 What the Cathedral Suggests

The arithmetic compressed sensing approach from the companion paper applies directly:

- The vibration signal is naturally sparse in the *arithmetic dictionary*: most energy is at integer multiples of the rotation frequency.
- The fractional-part basis $\{1/(kx)\}$ encodes exactly this multiplicative harmonic structure.

- The Gram matrix eigenvalue bound $\lambda_{\min}(G_N) > 0$ guarantees that the harmonic components are always separable, even at low signal-to-noise ratios.

Proposal: An Arithmetic Vibration Monitor (AVM) that:

1. Tracks the instantaneous rotation frequency $f_0(t)$ from a tachometer or phase-locked loop.
2. Projects the vibration signal onto the time-varying arithmetic dictionary $\{1/(k \cdot f_0(t) \cdot x)\}$.
3. Identifies anomalous components (not at integer multiples) as potential defect signatures.
4. Uses Möbius inversion to separate independent sources from harmonic products.

3.3 Feasibility

High. Vibration monitoring hardware is already deployed on most utility-scale turbines. The AVM is a software upgrade to existing monitoring systems. The key advantage: tracking instantaneous frequency allows analysis during transients, where conventional FFT fails.

Potential impact: Earlier detection of bearing defects could extend turbine lifetime by 10–20% and reduce unplanned outages. For a 5 GW wind fleet, this represents \$50–100M per year in avoided downtime and replacement costs.

4 Formally Verified Grid Stability

4.1 The Problem

Modern power grids are increasingly complex: intermittent renewables (wind, solar), distributed storage (batteries, EVs), demand response, and HVDC interconnections create a system with millions of interacting components. Grid operators must guarantee stability under all credible operating conditions.

Current stability analysis:

- **Simulation:** Run time-domain simulations for thousands of contingency scenarios. Computationally expensive and never exhaustive.
- **Small-signal analysis:** Linearize around the operating point and compute eigenvalues. Valid only near the linearization point.
- **Transient stability studies:** Offline analysis for planning; cannot guarantee real-time stability.

No existing approach provides a *certificate* that the grid will remain stable under a specified set of conditions.

4.2 What the Cathedral Suggests

The Cathedral proves positive definiteness of a family of matrices $\{G_N\}_{N \geq 1}$ —a parameterized stability certificate verified by machine. The same framework can prove grid stability:

1. **Model:** Formalize the swing equation $M_i \ddot{\delta}_i + D_i \dot{\delta}_i = P_i - \sum_j |V_i||V_j||Y_{ij}| \sin(\delta_i - \delta_j - \theta_{ij})$ in Lean 4.
2. **Lyapunov function:** Define the energy-like function $V = \frac{1}{2} \sum_i M_i \dot{\delta}_i^2 - \sum_i P_i (\delta_i - \delta_i^*) - \sum_{(i,j)} |V_i||V_j||Y_{ij}| (\cos(\delta_i - \delta_j) - \cos(\delta_i^* - \delta_j^*))$.
3. **Prove:** $V > 0$ and $\dot{V} \leq 0$ within the region of attraction.
4. **Axiomatize:** Numerical grid parameters (line impedances, generator inertias, load models) as named axioms with auditable sources.
5. **Certify:** The output is a machine-checked statement: “This grid configuration is stable under conditions A, B, C, conditional on axioms X, Y, Z.”

4.3 Feasibility

Medium. The mathematical framework (Lyapunov stability for power systems) is textbook material. The challenge is formalizing it in Lean 4 and connecting to numerical grid data. A proof-of-concept for a 3-bus system would be achievable in 1–2 years.

Potential impact: Transformative for grid operators managing high-renewable penetration. A stability certificate could replace thousands of simulation runs and provide provable guarantees that no credible contingency causes instability. This is especially valuable for islanded microgrids and ship/aircraft power systems.

5 Nuclear Spectroscopy and the GUE Connection

5.1 The Established Science

The Montgomery–Odlyzko law (1973/1987) established that the pair correlation of nontrivial zeta zeros matches the GUE (Gaussian Unitary Ensemble) statistics of random matrix theory:

$$R_2(\alpha) = 1 - \left(\frac{\sin(\pi\alpha)}{\pi\alpha} \right)^2 + \delta(\alpha).$$

The same GUE statistics describe:

- Energy level spacings of heavy nuclei (confirmed experimentally for ^{166}Er , ^{238}U , and others).
- Eigenvalue spacings of quantum chaotic systems.
- Bus arrival times in Cuernavaca (a celebrated empirical surprise).

5.2 What the Cathedral Adds

The Cathedral does not work with random matrix theory directly, but its Gram matrix G_N provides a *deterministic* number-theoretic matrix whose eigenvalue distribution can be compared with GUE predictions. The numerical experiments show:

- $\lambda_{\min}(G_N) \sim C/\ln N$ (soft-edge behavior reminiscent of Tracy–Widom).
- $\lambda_{\max}(G_N) \sim N$ (linear bulk growth).
- The eigenvalue ratio $Q_N/\ln N \rightarrow C \approx 21.65$ converges to a number-theoretic constant.

5.3 Application to Nuclear Energy

Reactor physics: Neutron transport in a reactor core is governed by the Boltzmann transport equation, whose eigenvalues determine criticality. The dominant eigenvalue $k_{\text{eff}} = 1$ at criticality; the spectral gap to the second eigenvalue determines how quickly transients decay.

Proposal: Use the Cathedral’s spectral analysis techniques (Rayleigh quotient bounds, positive definiteness proofs, condition number tracking) to provide:

1. Verified bounds on the spectral gap of the neutron transport operator for a given core configuration.
2. Machine-checked certificates that $k_{\text{eff}} < 1$ (subcritical) under specified conditions.
3. Formal proofs that shutdown margin recommendations are mathematically sound.

5.4 Feasibility

Low-medium for full implementation, but the individual mathematical components are mature. The Nuclear Regulatory Commission (NRC) already requires validated criticality calculations; machine-verified bounds would be a step beyond validation.

6 Fusion Plasma Confinement

6.1 The Problem

Magnetic confinement fusion (tokamaks, stellarators) requires maintaining a hot plasma (10^8 K) in a stable magnetic configuration. The plasma is described by magnetohydrodynamics (MHD), and stability is determined by the eigenvalues of the MHD operator.

The key challenge: proving that a given magnetic configuration is stable against all possible plasma perturbations. This is a variational problem—the energy principle states that the plasma is stable if and only if:

$$\delta W[\xi] = \frac{1}{2} \int [|\nabla \times (\xi \times B)|^2/\mu_0 - (\xi \cdot \nabla p)(\nabla \cdot \xi) + \dots] dV > 0$$

for all displacements ξ .

6.2 What the Cathedral Suggests

This is structurally identical to the Cathedral’s core problem: proving that a quadratic form (the MHD energy) is positive definite for all test vectors (perturbations).

The Cathedral’s techniques directly apply:

- **Rayleigh–Ritz discretization:** Approximate ξ by a finite set of basis functions, reducing the continuous problem to a matrix eigenvalue problem $Av = \lambda Bv$.
- **Positive definiteness proof:** Show that $\lambda_{\min}(B^{-1}A) > 0$ for all relevant configurations.
- **Axiom tiering:** The plasma equilibrium is an axiom (computed numerically); the stability proof is machine-verified from that axiom.

Key parallel: The Cathedral proves $\lambda_{\min}(G_N) > 0$ for *all* $N \geq 1$. An MHD stability proof would show $\delta W > 0$ for *all* perturbations within a specified class. The mathematical structure is the same; the physics is different.

6.3 Feasibility

Low for full implementation (the MHD operator is far more complex than the Gram matrix), but the *methodology* transfers:

1. Discretize the MHD stability functional on a finite element basis.
2. Compute the resulting matrix and bound its minimum eigenvalue.
3. Formalize the bound in Lean 4, with the equilibrium as an axiom.
4. Produce a certificate: “Configuration X is MHD-stable conditional on equilibrium axiom Y.”

Impact: Machine-verified stability certificates could accelerate the design-evaluate-redesign cycle in fusion reactor engineering, particularly for stellarator optimization where thousands of configurations must be evaluated.

7 Energy Harvesting with Arithmetic Metamaterials

7.1 RF Energy Harvesting

Radio frequency energy harvesting (rectenna arrays) captures ambient electromagnetic energy from WiFi, cellular, broadcast, and other RF sources. The challenge: ambient RF energy is broadband and weak, requiring an antenna that:

- Covers a wide bandwidth (100 MHz to 6 GHz).
- Has high efficiency at each frequency.
- Is physically compact.

Periodic antenna arrays have narrow bandwidth (resonant design). Random arrays have low efficiency (poor impedance matching).

7.2 What the Cathedral Suggests

The prime-gap metamaterial concept from the companion paper applies directly:

Proposal: A broadband rectenna with resonant elements at prime-indexed sizes:

- Element k resonates at $f_k = c/(2L_k)$ where $L_k \propto p_k$ (the k -th prime).
- The collective array has a dense, quasi-random frequency coverage: primes are distributed with density $\sim 1/\ln f$, providing denser coverage at low frequencies (where ambient RF power is higher).
- The natural log-density of primes *matches* the typical ambient RF power spectrum (which decreases with frequency), providing more harvesting elements where there is more energy.

7.3 Feasibility

Medium. Wideband rectennas are an active research area. The prime-indexed design rule is novel but physically simple to implement. The key validation: simulate the broadband capture efficiency versus a standard log-periodic antenna.

Potential impact: Prime-indexed rectennas could harvest 10–30% more ambient RF energy than periodic designs, enabling battery-free IoT sensors in urban environments.

8 Summary: Distance from Cathedral to Kilowatt

Application	Cathedral Math	Feasibility	Impact	Timeline
Grid harmonics (MHA)	Möbius inversion	Very High	High	<1 yr
Turbine monitoring (AVM)	Arithmetic CS	High	High	1–2 yr
Grid stability certs	Verified PD proofs	Medium	Very High	2–5 yr
Nuclear spectroscopy	Rayleigh quotient	Low-Med	Medium	5+ yr
Fusion MHD stability	Variational PD	Low	Very High	10+ yr
RF energy harvesting	Prime-gap arrays	Medium	Medium	2–4 yr

The gradient is clear: the closer the application is to harmonic analysis (grid, turbines), the more immediately actionable. The further into nuclear/fusion physics, the longer the timeline but the higher the potential impact.

9 Honesty Section

1. The Möbius Harmonic Analyzer could be developed tomorrow without any knowledge of the Cathedral. The Möbius function has been known since 1832. The Cathedral’s contribution is organizing these ideas in a verified framework that demonstrates their mathematical coherence.
2. The fusion application is a 10+ year research program that may ultimately prove impractical. We include it because the mathematical parallel (proving PD of a quadratic form = proving stability) is exact and illuminating.

3. None of these proposals require RH to be true. The mathematical structures exist independently.
4. The economic impact estimates are order-of-magnitude only.

10 Conclusion

The primes do not generate electricity. But the mathematics that describes the primes—harmonic analysis, spectral theory, variational stability, structured matrices—is the same mathematics that governs power grids, turbines, nuclear reactors, and fusion plasmas. The Cathedral assembles these tools in a new configuration and verifies them by machine. This paper traces the path from verified mathematics to possible engineering.

The most surprising connection is the simplest: power grid harmonics occur at *integer multiples* of 50/60 Hz, and the Möbius function is the mathematical tool built specifically for decomposing integer-multiplicative structure. This connection has been hiding in plain sight since August Ferdinand Möbius defined his function in 1832 and Thomas Edison built the first power grid in 1882. It took a formalization of the Riemann Hypothesis to make the connection explicit.

*The grid hums at 60 hertz.
 Its harmonics are at 120, 180, 300, 420.
 Those numbers are 2, 3, 5, 7 times sixty.
 The primes were in the wire all along.*

References

- [1] IEEE, *IEEE Std 519-2022: Recommended Practice for Harmonic Control in Electric Power Systems*, 2022.
- [2] H.L. Montgomery, *The pair correlation of zeros of the zeta function*, Proc. Symp. Pure Math. **24** (1973), 181–193.
- [3] M.L. Mehta, *Random Matrices*, 3rd ed., Academic Press, 2004.
- [4] J.P. Freidberg, *Ideal MHD*, Cambridge, 2014.
- [5] P. Kundur, *Power System Stability and Control*, McGraw-Hill, 1994.
- [6] J.R. Gochanour, *From Zeta Zeros to Engineering*, 2026.
- [7] J.R. Gochanour, *What Could Be Built: Seven Engineering Frontiers*, 2026.