

Date: 08/7/2013**REQUEST FOR QUOTE****Nº PRO-12-0568-1****Manufacturer:** EMEK ELEKTRIK ENDUSTRISI A.S.**Contact:** Ufuk Akkaya**Client:** ABB S.A.**Project:** SE EL HIERRO - SHOUGANG**Our Reference:** 0431-ETT-1

| Item | Quantity | Product description | |
|------|----------|---|---------------------------|
| 1 | 2 | Inductive voltage transformer-24kV | |
| | | Rated Voltage | 24 kV |
| | | Ratio | 22.9/V3//0.1/V3-0.1/V3 KV |
| | | Burden | 25VA-25 VA |
| | | Accuracy | 0,5-3P |
| | | BIL | 125 kVp |
| | | Power Frequency | 50 kV |
| | | Withstand | |
| | | Creepage Distance | 31 mm/kV |
| | | Frequency | 60 Hz |
| | | Installation Type | Outdoors |

| |
|--|
| |
|--|