

Date: 28/1/2013

REQUEST FOR QUOTE

Nº PRO-12-0218-1

Manufacturer:

Contact:

Client: CAME CONTRATISTAS Y SERV.GENERALES S.A.

Project: PROYECTO SS EE 8 DE AGOSTO Y EL CARMEN

Our Reference: 0122-ETT-1

Item	Quantity	Product description
1	6	CURRENT TRANSFORMER 17.5KV
		Rated Voltage 13.8 kV
		Ratio 600/5/5 A
		Burden 30 VA
		Accuracy 0.2/ 5P
		Ith 25 kA
		BIL 95 kVp
		Power Frequency 38 kV
		Withstand
		Creepage Distance 25 mm/kV
		Frequency 60 Hz
		Installation Type EXTERIOR
2	9	CURRENT TRANSFORMER 24KV
		Rated Voltage 22.9 kV
		Ratio 200-400/5/5 A
		Burden 30 VA
		Accuracy 0.2 /5P
		Ith 25 kA
		BIL 125 kVp
		Power Frequency 50 kV
		Withstand
		Creepage Distance 25 mm/kV
		Frequency 60 Hz
		Installation Type EXTERIOR
3	3	INDUCTIVE VOLTAGE TRANSFORMER 17.5 kV
		Rated Voltage 17.5 kV
		Ratio 13.8/V3: 0.10/V3: 0.10/V3 KV
		Burden 30 VA
		Accuracy 0.5/ 3P
		BIL 95 kVp
		Power Frequency 38 kV
		Withstand
		Creepage Distance 25 mm/kV
		Frequency 60 Hz
		Installation Type EXTERIOR
4	6	INDUCTIVE VOLTAGE TRANSFORMER 24 kV
		Rated Voltage 22.9 kV
		Ratio 22.9/V3: 0.10/V3: 0.10/V3
		Burden 30 VA
		Accuracy 0.2/ 3P

		BIL	125 kVp
		Power Frequency Withstand	50 kV
		Creepage Distance	25 mm/kV
		Frequency	60 Hz
		Installation Type	exterior

--