

**Date:** 03/12/2012**REQUEST FOR QUOTE****Nº PRO-12-0132-1**

**Manufacturer:** EMA Electromecánica S.A  
**Contact:** Gerardo Masuyama  
**Client:** ARPL TECNOLOGIA INDUSTRIAL S.A.  
**Project:** DISTRIBUCION  
**Our Reference:** 0081-ETT-1

Item	Quantity	Product description	
1	1	<b>Interruptor Tanque Vivo 24kV</b>	
		Rated Voltage	24 kV
		Rated Current	630 A
		Ith	25 kA
		BIL	150 kVp
		Power Frequency Withstand	60 kV
		Frequency	60 Hz
		Creepage Distance	25 mm/kV

--