

Telef.: 0051-1-436-2500

Fax: 355-2184

PURCHASE ORDER № 0015-POR-1

EMEK ELEKTRIK ENDUSTRISI A.S. MANUFACTURER:

Esemboga yolu 23km. Akyurt Ankara Turkey Tel.: +90 3123980181

Gregori Gómez (gregori.gomez@emek.com.tr) RESPONSIBLE:

PROJECT: nueva se

SUPPLIER' REF::

SHIPPING MARKS:

Tel.:

DELIVERY TO:

INVOICE TO:

Tel.:

CONTACT:

DATE:

Item		Description	Quantity	Unit Price	Total
1	145kV Disconnector		2	9,132.48	18,264.96
	Rated Voltage	145 kV			
	Rated Current	2000 A			
	Ith	31 kA			
	Phases	3			
	Operation Type	central			
	Earthing Blade	no			
	BIL	650 kVp			
	Creepage Distance	25 mm/Kv			
	Frequency	60 Hz			
	Installation Type	exterior			
2	Current Transformer		3	7,945.56	23,836.6
	Rated voltage	138 kV			
	Ratio	1000/1-1-1 A			
	Burden	30 VA			
	Accuracy	0.2			
	Ith	31 kA			
	BIL	650 kVp			
	Creepage Distance	25 mm/kV			
	Frequency	60 Hz			
		a veta mi a m			
	Installation Type	exterior			





Telef.: 0051-1-436-2500

Fax: 355-2184

commercial terms	Shipping Document Required: - Comercial Invoice - Packing list - Bill of Loading (3 / 3)	APPROVED BY:
------------------	--	--------------