

Date : 21/9/2012

REQUEST FOR QUOTE

NRO. PRO-12-0020-1 v.1

Manufacturer **EMEK Elektrik Endustrisi A.S.**  
 Contact **GREGORI GÓMEZ**  
 Client **CAM-COMPAÑIA AMERICANA DE MULTISERVICIOS DEL PERU S.A.**  
 Project **prueba**  
 Our Reference **0012-ETT-1**

Item	Quantity	Product description	
1	1	Disconnecter 145kV	
		Installation Type	OUTDOOR
		Earthing Blade	WITH EARTHING BLADE
			CENTRE BREAKER
		Rated Voltage	138 kV
		Power Frequency Withstand	230 kV
		Rated Current	2000 A
		Ith	25 kA
		Creepage Distance	25 mm/kV
		BIL	550 kVp
		Frequency	60 Hz
		Phases	3