

**Date:** 03/12/2012**REQUEST FOR QUOTE****Nº PRO-12-0133-1**

**Manufacturer:** Esitas Group Companies  
**Contact:** Kortay Ileri  
**Client:** Edison Energy Peru S.A.C.  
**Project:** SUMINISTRO DE RECLOSER'S  
**Our Reference:** 0080-ETT-1

| Item | Quantity | Product description              |              |
|------|----------|----------------------------------|--------------|
| 1    | 4        | <b>24 kV VOLTAGE TRANSFORMER</b> |              |
|      |          | Rated Voltage                    | 24 kV        |
|      |          | Ratio                            | 22.9/0.22 kV |
|      |          | Burden                           | 500 VA       |
|      |          | BIL                              | 170 kVp      |
|      |          | Creepage Distance                | 33.88 mm/kV  |
|      |          | Frequency                        | 60 Hz        |
|      |          | Installation Type                | OUTDOOR      |

|  |
|--|
|  |
|--|