

Date: 10/12/2012

REQUEST FOR QUOTE Nº PRO-12-0149-1

Manufacturer: CROMPTON GREAVES LTD (SWITCHGEAR DIVISION)

Contact:

Client: SN POWER PERU S.A. Project: **CAÑON DEL PATO**

FL-12-0092-1 Our Reference:

Item	Quantity	Product description	
1	2	72.5 kV Disconnector	
		Rated Voltage	72.5 kV
		Rated Current	2000 A
		Ith	31 kA
		Phases	3
		Operation Type	central break
		Earthing Blade	Si
		BIL	325 kVp
		Power Frequency Withstand	125 kV
		Creepage Distance	25 mm/Kv
		Frequency	60 Hz
		Main Switch Auxiliary Contact	10NO+10NC
		Earth Switch Auxiliary Contact	10NO+10NC
		Auxiliary Voltage	110 VDC
		Type of Main Operation	Motorized
		Type of Earth Switch Operation	Manual
		Installation Type	Outdoor
2	1	72.5kV Circuit Breaker	
		Rated Voltage	72.5 kV
		Rated Current	3250 A
		Ith	40 kA
		BIL	325 kVp
		Power Frequency Withstand	250 kV
		Frequency	60 Hz
		Creepage Distance	31 mm/KV
		Phases	3

ELECTROWERKE S.A. RUC 20386239828 Telef.: 271-2700 Fax: 355-2184