

Date: 09/7/2013**REQUEST FOR QUOTE****Nº PRO-12-0570-1**

Manufacturer: EMEK ELEKTRIK ENDUSTRISI A.S.
Contact: Ufuk Akkaya
Client: TECSUR S.A.
Project: Suministro de Seccionadores Tripolares de Barra y Línea
Our Reference: 0434-ETT-1

Item	Quantity	Product description	
1	21	Seccionador Barra 72.5 kV, 2000A	
		Rated Voltage	72.5 kV
		Rated Current	2000 A
		Ith	31.5 kA
		Rated Duration of Short Circuit	3 s
		Phases	3
		Operation Type	CENTRAL
		BIL	325 / 375 kVp
		Power Frequency Withstand	140 / 160 kV
		Creepage Distance	2248 mm/Kv
		Frequency	60 Hz
		Main Switch Auxiliary Contact	10 NA + 10 NC
		Auxiliary Voltage	125 VDC
		Type of Main Operation	MOTORIZADO
		Installation Type	EXTERIOR
2	5	Seccionador Línea 72.5 kV, 2000A	
		Rated Voltage	72.5 kV
		Rated Current	2000 A
		Ith	31.5 kA
		Rated Duration of Short Circuit	3 s
		Phases	3
		Operation Type	CENTRAL
		Earthing Blade	SI
		BIL	325 / 375 kVp
		Power Frequency Withstand	140 / 160 kV
		Creepage Distance	2248 mm/Kv
		Frequency	60 Hz
		Main Switch Auxiliary Contact	10 NA + 10 NC
		Earth Switch Auxiliary Contact	06 NA + 06 NC
		Auxiliary Voltage	125 VDC
		Type of Main Operation	MOTORIZADO
		Type of Earth Switch Operation	MOTORIZADO

		Installation Type	EXTERIOR
--	--	-------------------	----------

--