

Date: 18/2/2013**REQUEST FOR QUOTE****Nº PRO-12-0243-1**

Manufacturer: EMEK ELEKTRIK ENDUSTRISI A.S.
Contact: UFUK AKKAYA
Client: CIA. MINERA BUENAVENTURA S.A.A.
Project: prueba 2
Our Reference: 0146-ETT-1

Item	Quantity	Product description
1	3	CURRENT TRANSFORMER 17.5KV
		Rated Voltage 13.8 kV
		Ratio 600/5/5 A
		Burden 30 VA
		Accuracy 0.2/ 5P
		Ith 25 kA
		BIL 95 kVp
		Power Frequency 38 kV
		Withstand
		Creepage Distance 25 mm/kV
		Frequency 60 Hz
		Installation Type EXTERIOR
2	3	CURRENT TRANSFORMER 24KV
		Rated Voltage 22.9 kV
		Ratio 200-400/5/5 A
		Burden 30 VA
		Accuracy 0.2 /5P
		Ith 25 kA
		BIL 125 kVp
		Power Frequency 50 kV
		Withstand
		Creepage Distance 25 mm/kV
		Frequency 60 Hz
		Installation Type EXTERIOR