Date: 06/12/2012

REQUEST FOR QUOTE

Nº PRO-12-0141-1

**Manufacturer**:   EMEK Elektrik Endustrisi A.S.

Contact: UFUK AKKAYA

Client: CAM-COMPAÑIA AMERICANA DE MULTISERVICIOS DEL PERU S.A.

Project: IMPLEMENTACIÓN DE BAHÍAS DE 60 KV EN SET LA UNIÓN Y SET SECHURA

Our Reference: 0089-ETT-1

Item	Quantity	Product description	
1	6	**Capacitive voltage transformer**	
		Rated Voltage	72.5 kV
		Ratio	(60/V3)/(0,1/V3)/(0,1/V3)
		Burden	30-30 VA
		Class	0.2-3P
		BIL	325 kVp
		Power Frequency Withstand	140 kV
		Creepage Distance	31 mm/kV
		Frequency	60 Hz
		Installation Type	Vertical
2	6	**Current transformer**	
		Rated voltage	72.5 kV
		Ratio	200-400/1/1/1A A
		Burden	30VA-30VA-30 VA
		Accuracy	5P20-5P20-0.2S
		Ith	40 A
		BIL	325 kVp
		Power Frequency Withstand	140 kV
		Creepage Distance	31 mm/kV
		Frequency	60 Hz
		Installation Type	Vertical
3	2	**Central break disconnector with earthing blade**	
		Rated Voltage	72.5 kV
		Rated Current	800 A
		Ith	16 kA
		Phases	3
			Horizontal
		Earthing Blade	Si
		BIL	325 kVp
		Power Frequency Withstand	140 kV
		Creepage Distance	31 mm/Kv
		Frequency	60 Hz
		Installation Type	Horizontal
4	2	**Central break disconnector without earthing blade**	
		Rated Voltage	72 kV
		Rated Current	800 A
		Ith	16 kA

			Phases	3
				Horizontal
			Earthing Blade	No
			BIL	325 kVp
			Power Frequency Withstand	140 kV
			Creepage Distance	31 mm/Kv
			Frequency	60 Hz
			Installation Type	Horizontal