

Date: 25/4/2013

REQUEST FOR QUOTE

Nº PRO-12-0334-1

Manufacturer: EMEK ELEKTRIK ENDUSTRISI A.S.
Contact: UFUK AKKAYA
Client: ELECTRO ORIENTE-EMPRESA REGIONAL DE SERVICIO PÚBLICO DE
 ELECTRICIDAD DEL OR
Project: PRUEBA DE MODULO
Our Reference: 0190-ETT-1

Item	Quantity	Product description	
1	2	245kV Disconnecter	
		Rated Voltage	245 kV
		Rated Current	2000 A
		Ith	31 kA
		Rated Duration of Short Circuit	1 s
		Phases	3
		Operation Type	central
		BIL	1050 kVp
		Creepage Distance	31 mm/Kv
		Frequency	60 Hz
		Main Switch Auxiliary Contact	8 NO + 8 NC
		Earth Switch Auxiliary Contact	8 NO + 8 NC
		Auxiliary Voltage	125 VDC
		Type of Main Operation	MOTORIZED
		Type of Earth Switch Operation	MOTORIZED
		Installation Type	HORIZONTAL - OUTDOOR
2	3	245kV Capacitive Voltage Transformer	
		Rated Voltage	245 kV
		Ratio	220/0.22/0.22
		Burden	30 VA
		Class	0.5/3P
		BIL	1050 kVp
		Creepage Distance	31 mm/kV
		Frequency	60 Hz
		Installation Type	OUTDOOR
3	6	245kV Current Transformer	
		Rated voltage	245 kV
		Ratio	1000/1-1-1 A
		Burden	30 VA
		Accuracy	0.2/5P20/5P20
		Ith	31 kA
		BIL	1050 kVp
		Creepage Distance	31 mm/kV
		Frequency	60 Hz
		Installation Type	OUTDOOR

--