

Date: 07/6/2013**REQUEST FOR QUOTE****Nº PRO-12-0442-1****Manufacturer:****Contact:****Client:** CAME CONTRATISTAS Y SERV.GENERALES S.A.**Project:** LINEA DE TRANSMISION 66 kV ARCATA - CRESPO Y SUBESTACIONES**Our Reference:** 0254-ETT-1

Item	Quantity	Product description	
1	6	Surge arrester-4.16kV	
		Rated Voltage	6 kV
		Nominal Discharge Current	10 kAp
		Class	2
		BIL	95 kVp
		Power Frequency Withstand	38 kV
		Creepage Distance	25 mm/kV
		Frequency	60 Hz
2	9	Surge arrester-60kV	
		TOV (1S): 69.6 KVp	
		COV : 48 kVp	
		Rated Voltage	66 kV
		Nominal Discharge Current	10 kAp
		Class	3
		BIL	550 kVp
		Power Frequency Withstand	230 kV
		Creepage Distance	25 mm/Kv
		Frequency	60 Hz