

Date: 06/11/2012

REQUEST FOR QUOTE

NRO. PRO-12-0067-1 v.1

Manufacturer

Kortay Ileri Contact

Client **GOODYEAR DEL PERU S.A.**

Proyect repotenciacion

Our Reference 0045-ETT-1

Item	Quantiy	Product description	
1	3	VOLTAGE TRANSFORMER	
		Rated Voltage	10 kV
		Ratio	10V3//0.11V3/0.11V3
		Burden	15 VA
		Accuracy	3P, 0.2
		BIL	125 kVp
		Creepage Distance	25 mm/kV
		Frequency	60 Hz
		Installation Type	OUTDOOR
2	3	CURRENT TRANSFORMER Rated Voltage 0.72 kV	
		Ratio	100/5
		Burden	7.5 VA
		Accuracy	10P20
		BIL	3 kVp
		Creepage Distance	25 mm/kV
		Frequency	60 Hz
		Installation Type	OUTDOOR