

\_\_\_\_\_\_

Date: 19/11/2012

Fax: 355-2184

## REQUEST FOR QUOTE

NRO. PRO-12-0076-1 v.1

Manufacturer EMEK Elektrik Endustrisi A.S.

Contact UFUK AKKAYA

Client EMPRESA DE GENERACION ELECTRICA DE AREQUIPA S.A. - EGASA

Proyect SE Guadalupe

Our Reference **0056-ETT-1** 

Item	Quantiy	Product description		
1	1			
2	1	123kV DISCONNECTOR		
_		Rated Current	800 A	
		Ith	25 kA	
		Phases	3	
			center	
		Earthing Blade	si	
		BIL	450 kVp	
		Creepage Distance	25 mm/Kv	
		Frequency	60 Hz	
		Installation Type	outdoor	
3	1	Current Transformer		
		Rated voltage	138 kV	
		Ratio	1000/1-1-1 A	
		Burden	30 VA	
		Accuracy	0.2	
		lth	31 A	
		BIL	650 kVp	
		Creepage Distance	25 mm/kV	
		Frequency	60 Hz	
		Installation Type	exterior	