

**Date:** 06/12/2012**REQUEST FOR QUOTE****Nº PRO-12-0140-1****Manufacturer:** EMA Electromecánica S.A**Contact:** GUSTAVO GIGENA**Client:** ELECTROPERU S.A.**Project:** SET San Juan**Our Reference:** 0088-ETT-1

Item	Quantity	Product description	
1	2	<b>Interruptor Tanque Vivo 24kV</b>	
		Rated Voltage	24 kV
		Rated Current	630 A
		Ith	25 kA
		BIL	150 kVp
		Power Frequency Withstand	60 kV
		Frequency	60 Hz
		Creepage Distance	25 mm/kV