

Contents

| | | |
|----------|---|----------|
| 1 | Vertex Detector R&D | 5 |
| 1.1 | DEPFET Pixel Sensors | 5 |
| 1.1.1 | Collaborating Institutions | 5 |
| 1.1.2 | Introduction | 5 |
| 1.1.3 | Recent Milestones | 5 |
| 1.1.4 | Engineering Challenges | 5 |
| 1.1.5 | Future Plans | 6 |
| 1.1.6 | Applications Outside of Linear Colliders | 6 |
| 1.2 | DEPFET Electronics | 6 |
| 1.2.1 | Collaborating Institutions | 6 |
| 1.2.2 | Introduction | 7 |
| 1.2.3 | Recent Milestones | 7 |
| 1.2.4 | Engineering Challenges | 7 |
| 1.2.5 | Future Plans | 7 |
| 1.2.6 | Applications Outside of Linear Colliders | 8 |
| 1.3 | ChronoPix | 8 |
| 1.3.1 | Collaborating Institutions | 8 |
| 1.3.2 | Introduction | 8 |
| 1.3.3 | Recent Milestones | 8 |
| 1.3.4 | Engineering Challenges | 9 |
| 1.3.5 | Main directions of the R&D for the next 5 years | 9 |
| 1.3.6 | Applications Outside of Linear Colliders | 10 |
| 1.4 | FPCCD | 10 |
| 1.4.1 | Collaborating Institutions | 10 |
| 1.4.2 | Introduction | 10 |
| 1.4.3 | Recent Milestones | 10 |
| 1.4.4 | Engineering Challenges | 11 |
| 1.4.5 | Future Plans | 11 |
| 1.4.6 | Applications Outside of Linear Colliders | 12 |
| 1.5 | CMOS | 13 |
| 1.5.1 | Collaborating Institutions | 13 |
| 1.5.2 | Introduction | 13 |
| 1.5.3 | Recent Milestones | 13 |
| 1.5.4 | Engineering Challenges | 13 |

| | | |
|----------|--|-----------|
| 1.5.5 | Future Plans | 13 |
| 1.5.6 | Applications Outside of Linear Colliders | 13 |
| 1.6 | CLICPix | 13 |
| 1.6.1 | Collaborating Institutions | 13 |
| 1.6.2 | Introduction | 13 |
| 1.6.3 | Recent Milestones | 13 |
| 1.6.4 | Engineering Challenges | 14 |
| 1.7 | 3D Pixel Development | 14 |
| 1.7.1 | Collaborating Institutions | 14 |
| 1.7.2 | Introduction | 14 |
| 1.7.3 | Recent Milestones | 14 |
| 1.7.4 | Engineering Challenges | 15 |
| 1.7.5 | Future Plans | 16 |
| 1.7.6 | Applications outside of Linear Colliders | 16 |
| 1.8 | SOI | 17 |
| 1.8.1 | Collaborating Institutions | 17 |
| 1.8.2 | Introduction | 17 |
| 1.8.3 | Recent Milestones | 17 |
| 1.8.4 | Engineering Challenges | 18 |
| 1.8.5 | Future Plans | 18 |
| 2 | Tracking Detectors | 20 |
| 2.1 | SCIPP Tracking R&D | 20 |
| 2.2 | KPIX | 21 |
| 2.2.1 | Collaborating Institutions | 21 |
| 2.2.2 | Introduction | 21 |
| 2.2.3 | Recent Milestones | 23 |
| 2.2.4 | Engineering Challenges | 23 |
| 2.2.5 | Future Plans | 24 |
| 2.2.6 | Applications Outside of Linear Colliders | 24 |
| 2.3 | Time Projection Chamber – Bonn | 25 |
| 2.3.1 | Collaborating Institutions | 25 |
| 2.3.2 | Introduction | 25 |
| 2.3.3 | Recent Milestones | 25 |
| 2.3.4 | Engineering Challenges | 27 |
| 2.3.5 | Future Plans | 27 |
| 2.3.6 | Applications Outside of Linear Colliders | 27 |
| 3 | Electromagnetic Calorimeter R&D | 28 |
| 3.1 | Scintillator Strips | 28 |
| 3.1.1 | Collaborating Institutions | 28 |
| 3.1.2 | Introduction | 28 |
| 3.1.3 | Recent Milestones | 28 |
| 3.1.4 | Engineering Challenges | 28 |
| 3.1.5 | Future Plans | 29 |
| 3.1.6 | Applications Outside of Linear Colliders | 29 |

| | | |
|----------|---|-----------|
| 3.2 | Silicon Pads | 29 |
| 3.2.1 | Collaborating Institutions | 29 |
| 3.2.2 | Introduction | 29 |
| 3.2.3 | Recent Milestones | 29 |
| 3.2.4 | Engineering Challenges | 30 |
| 3.2.5 | Future Plans | 30 |
| 3.2.6 | Applications Outside of Linear Colliders | 30 |
| 3.3 | SiliconPads LAL | 31 |
| 3.3.1 | Introduction and Physics Prototype | 31 |
| 3.3.2 | Technological Prototype | 31 |
| 3.3.3 | Plans of the near future - Ecal assembly bench and R&D on digital electronics | 32 |
| 3.3.4 | Further Activities | 33 |
| 3.3.5 | Funding, Manpower and Partners | 33 |
| 4 | Hadronic Calorimeter R&D | 35 |
| 4.1 | Scintillator Tiles | 35 |
| 4.1.1 | Collaborating Institutions | 35 |
| 4.1.2 | Introduction | 35 |
| 4.1.3 | Recent Milestones | 35 |
| 4.1.4 | Engineering Challenges | 35 |
| 4.1.5 | Future Plans | 35 |
| 4.1.6 | Applications Outside of Linear Colliders | 35 |
| 4.2 | Resistive Plate Chambers | 35 |
| 4.2.1 | List of participating institutes | 35 |
| 4.2.2 | Description of the DHCAL | 36 |
| 4.2.3 | Current R&D activities | 36 |
| 4.2.4 | Engineering challenges | 37 |
| 4.2.5 | Plans for the coming years | 37 |
| 4.2.6 | Applications beyond the ILC | 38 |
| 4.3 | GEM | 39 |
| 4.3.1 | Collaborating Institutions | 39 |
| 4.3.2 | Introduction | 39 |
| 4.3.3 | Recent Milestones | 39 |
| 4.3.4 | Engineering Challenges | 39 |
| 4.3.5 | Future Plans | 39 |
| 4.3.6 | Applications Outside of Linear Colliders | 39 |
| 4.4 | FCAL | 39 |
| 4.4.1 | Collaborating Institutions | 39 |
| 4.4.2 | Introduction | 40 |
| 4.4.3 | Recent Milestones | 40 |
| 4.4.4 | Engineering Challenges | 40 |
| 4.4.5 | Future Plans | 40 |
| 4.4.6 | Applications Outside of Linear Colliders | 40 |
| 4.5 | Analog HCAL | 40 |
| 4.5.1 | Collaborating Institutions | 40 |

| | | |
|-------|----------------------------------|----|
| 4.5.2 | Introduction | 41 |
| 4.5.3 | Recent Milestones | 41 |
| 4.5.4 | Summary | 45 |
| 4.5.5 | Engineering Challenges | 46 |
| 4.5.6 | Future Plans | 46 |

Chapter 1

Vertex Detector R&D

1.1 DEPFET Pixel Sensors

1.1.1 Collaborating Institutions

Three Spanish institutes are members of the collaboration

IFCA environmental monitoring using Bragg fibres

IFIC contact to (I)LC community, thermo-mechanical properties, assembly of ladders for Belle II

UB design of read-out electronics

1.1.2 Introduction

DEPFET active pixel sensors are one of most mature candidates for the ILC vertex detector and the innermost disks of the forward tracker.

1.1.3 Recent Milestones

The concept of a DEPFET active pixel detector for vertex detection at collider experiments was initiated in the linear collider community (for TESLA). The operation principle was extensively proven on small-scale prototypes. A recent reassessment of the DEPFET potential for a linear collider at the energy frontier is found in [4]. The collaboration is making rapid progress - fueled by the election of DEPFET for the Belle II detector - towards a full-blown detector system including solutions for services and supports. A full-scale, 75 micron thin Belle II ladder was successfully submitted to a test in a beam of charged at DESY in January 2014.

1.1.4 Engineering Challenges

Vertex detector ladders with a thickness of several tens of microns and a spatial resolution of well below 10 microns require very robust mechanical properties. The power

generated by the sensor and ASICs must be removed with the smallest impact on the detector material. Measurements on thin ladders under a realistic load, including pulsed powering according to the ILC beam structure, prove the excellent mechanical properties of the all-silicon ladder. A complete mock-up for the innermost disks is under construction.

1.1.5 Future Plans

Currently, the construction of the Belle II vertex detector (to be installed by 2016) implies a large effort of R&D, including:

- Develop the die-attach technology in a controlled atmosphere required for the mounting of passive components on the DEPFET active pixel detector ladders. The first milestone is a fully integrated electrical prototype based on the EMCM.
- First tests that will determine if all the ASICs on the ladder are fully functional
- The integration of read-out and steering ASICs on the pixel sensor to be performed using a flip-chip technique and so-called bump-bonding, using microscopic solder balls.
- The production of the Belle II vertex detector modules, a joint effort of the DEPFET collaboration
- The test of the last version of the DHP chips

In the near future we hope to characterize the performance of ILC-design prototypes with pixels of 20 x 20 micron²:

- Perform an engineering design for a DEPFET all-silicon module with the required petal geometry
- A detailed characterization of the response of the device
- Design of the ancillary ASICs, taking full responsibility for future design cycles of the Front End read-out chip, the Drain Current Digitizer (DCD) that is relevant to the ILC and a Belle II upgrade. This chip converts the analog signal from the detector to digital and has a crucial impact on the detector performance.

1.1.6 Applications Outside of Linear Colliders

The election of DEPFET technology for the Belle II detector therefore represents an important spin-off of linear collider detector R&D. DEPFET detectors are furthermore used for X-ray imaging at the XFEL. Future space missions envisage the use of DEPFET sensors. Their use in microscopy is being studied.

1.2 DEPFET Electronics

1.2.1 Collaborating Institutions

UB and U. Bonn

1.2.2 Introduction

1.2.3 Recent Milestones

The Front-end Electronics (FE), i.e., readout electronics, is currently organized by a set of several ASICs: The SWITCHER, DCD and DHP chips [27]. The SWITCHER control chips select segments of the sensor array for read-out. A separate driver supplies the clear pulse of up to 20 V to remove the collected signal from the internal gate after read-out. Several designs of the SWITCHER versions optimized for Belle II requirements have been produced and tested successfully in two different CMOS technologies (0.35 μ m and 0.18 μ m). The drain current signals from 256 columns of pixels are processed and digitized by the DCD chip (Drain Current Digitizer [25] [34]. The analog input stage keeps the column line potential constant (necessary to achieve fast readout), compensates for variations in the DEPFET pedestal currents, and amplifies and shapes the signal. The last DCD version is implemented in UMC 0.18 μ m CMOS technology using special radiation hard design techniques (e.g. enclosed NMOS gates) in the analog part. This DCD chip is optimized specifically for Belle II requirements. The derandomized raw data from the DCD are transmitted to the Data Handling Processors (DHP) [29] using fast parallel 8-bit digital outputs. This third ASIC, located on the end of ladder area immediately behind the DCD, performs data processing (pedestal subtraction, common code correction), compression (zero suppression), buffering and fast serialization. It furthermore controls the other read-out ASICs. The first full-scale DHP prototype was implemented in IBM 90 nm CMOS technology. With the discontinuity of this technology new designs started in the TSMC 65nm CMOS process being the DHPT v.1.0 the last full-scale chip.

1.2.4 Engineering Challenges

The UB responsibility is the slow control and biasing part of DHP. Versions DHP0.1 and DHP0.2 were designed in 90nm IBM CMOS process. Several designs (DHPT0.1, DHPT0.2 and DHPT v.1.0) were submitted to fabrication with TSMC 65nm and were tested during the period 2011-2013. The first versions of these ASICs included sub-modules that were included in the final design. The design submitted by the UB comprises temperature independent current references, 11 bias 8-bit DACs with current output, an integrated temperature measuring system and JTAG control. This design has been successfully tested during early 2014.

1.2.5 Future Plans

In the longer term the DCD and DHP are envisaged to evolve into a single chip. Being large arrays of DEPFET pixels a promising technology for the vertex detector of the planned ILC, adaptation of the DCD and DHP chips must also be done.

1.2.6 Applications Outside of Linear Colliders

1.3 ChronoPix

1.3.1 Collaborating Institutions

The chronopixel sensor is been developed in the collaboration of the University of Oregon and Yale University. The silicon sensor engineering is performed by Sarnoff Corporation under contract with the two Universities.

1.3.2 Introduction

The chronopixel is the monolithic CMOS pixelated sensor with the ability to record time stamp of pixel crossing by charge particles in the pixel memory. Each pixel contains 2 memory cells (12 bits each), and can record 2 time stamps happening during the same bunch train. This information is read out in the time interval between bunch trains. Chronopixel option for ILC vertex detector was described in the ILC DBD. By the time of the DBD, 2 prototypes were built and tested, and summary of test results were also presented in the DBD. They are listed below:

- We have proven that we can record time stamps in every pixel with time resolution better than 300 ns (we have tested it down to 150 ns).
- We have tested sparse readout, allowing to read only pixels with hits, thus reducing readout time to the level allowing readout of all pixels in the sensor in the intervals between bunch crossings.
- We have tested pulsed power for analog part of the pixels and have proven that turning power ON in about 100 μ s before bunch train and turning it off between bunch trains does not create any problems for threshold setting accuracy in the comparators.
- We have tested the idea of building all in-pixel electronics only from NMOS transistors, thus eliminating the need for special process (deep p-well) to protect signal charge from parasitical collection by in-pixel transistors. We have proven that all NMOS electronics can be built in this way, and that this does not significantly increase the power consumption compared to CMOS electronics.
- We have tested compensation of comparator offsets using analog calibration, when the value of the offset is stored as a voltage on the capacitor in each pixel. This have advantage over digital calibration (value of offset is stored as code in the special register) in that there are no discrete levels, and accuracy of such a calibration scheme is not affected by the size of such a register and the spread of the initial offsets.

1.3.3 Recent Milestones

- Test of prototype 2 revealed some problems. Possible solutions for these problems were discussed with Sarnoff engineers.

- New contract with Sarnoff for the design of prototype3 was signed in August 2013.
- The submission of prototype 3 to foundry for manufacturing is expected by the end of April 2014.

The most recent report on chronopixel status was presented by N. Sinev at LCWS13 on November 2013 at Tokyo

1.3.4 Engineering Challenges

- Achieving low capacitance of sensor diode in 65 nm and smaller feature size process. Following standard design rules for such process led to much higher than hoped for diode capacitance. There seems to be solution for this problem (using non-standard “native diode” from design library). But that need to be checked, and this is the main goal of the 3rd prototype.
- If low value of sensor diode capacitance will be achieved, the signal/noise ratio will improve. However, lower value of this capacitance will make it more sensitive to cross-talks through capacitive coupling. Reducing such coupling can be a challenge.
- Transition from small prototypes (few mm²) to real ILC detector size (10 cm²) may meet additional problems. One of them will be effect of Lorentz forces on the power supply buses, especially in the case of pulsing power. Pulsing power is the only way to achieve acceptable power dissipation in the vertex detector. However, it will generate varying Lorentz forces, acting on power supply lines. This may produce vibrations, which are unacceptable for required spatial resolution of the detector.

1.3.5 Main directions of the R&D for the next 5 years

- Achieve signal/noise ratio required for close to 100% signal registration efficiency. So far we got a signal/noise of around 10 in prototype 2, and we would like at least 20. We know a few ways to improve it - increasing epitaxial layer thickness, increasing epitaxial layer resistivity, or reducing sensor capacitance. The most attractive would be reducing sensor capacitance, as it does not require special process, however there are some problems to be solved with this approach.
- Achieve required pixel size (prototype 3 will have 25 μm pixels, we would eventually like 15 μm). It may require going to technology with feature size less than 65 nm. There seems to be no problems in that, but both - good signal/noise and pixel size requirements may be challenging.
- Achieve acceptable level of inter-pixel and digital to analog circuit cross talks and parasitic feed backs.

- Depending on available funding, try to build complete sensor with large enough area and full feature readout.

1.3.6 Applications Outside of Linear Colliders

With some modifications (for example, adding time-time convertor) Chronopixel architecture can be applied for any experiment requiring time stamping of individual hits - it may be HL-LHC, CLIC and so on.

1.4 FPCCD

1.4.1 Collaborating Institutions

The following institutes are participating in this project:

- KEK, High Energy Accelerator Research Organization
- Tohoku University
- Shinshu University
- JAXA, Japan Aerospace Exploration Agency

1.4.2 Introduction

Fine pixel CCD (FPCCD) is one of the candidate sensor options for the vertex detector of ILD detector at ILC. In the present design, FPCCD sensors for the innermost layer of the vertex detector have the pixel size of $5\text{ }\mu\text{m}$ and the fully depleted epitaxial layer with a thickness of $15\text{ }\mu\text{m}$. Because of the small size of the pixels, the pixel occupancy is acceptably low even if the hits are accumulated for one bunch train (1 ms). The efforts of the FPCCD collaboration are currently focused on pixel characterization and development, while we also pursue developments to the cooling system (led by KEK), electronics downstream of ASICs (led by Shinshu University) and the reconstruction software (led by Tohoku University).

1.4.3 Recent Milestones

R&D activity for the FPCCD vertex detector at present is mainly focused on FPCCD sensors and a detector cooling system using 2-phase CO_2 . One of the achievements of FPCCD sensors after DBD is the fabrication of real size ($12.3 \times 62.4\text{ m}^2$) sensors with $50\text{ }\mu\text{m}$ total thickness. Figure 1.1 shows the real size prototype sensor. It has 8 readout nodes, and each channel has different pixel sizes of $12\text{ }\mu\text{m}$, $8\text{ }\mu\text{m}$, and $6\text{ }\mu\text{m}$. We have started neutron damage test using small ($6\text{ mm} \times 6\text{ mm}$) FPCCD prototypes [22]. A prototype sensor was irradiated by a neutron beam of few tens of MeV at CYRIC in Tohoku University. Detailed analysis on the irradiated sensor is still on-going. In order to increase the radiation immunity of FPCCD sensors, particularly to reduce the transfer inefficiency due to radiation damage, the sensors should be cooled down




Figure 1.1: Real size FPCCD sensor thinned down to 50 μm

to -40°C . We have started R&D on two-phase CO_2 cooling system for this purpose. There are several examples of utilizing two-phase CO_2 cooling system for high energy physics experiments. For these cases, the CO_2 coolant is circulated using liquid pumps. This method is, however, not so efficient for very low temperature cooling of -40°C . Therefore, we adopted CO_2 gas compressor for the circulation of CO_2 coolant. Figure 1.2 shows a simplified schematic diagram of the system. A prototype system has been constructed, and cooling between -40°C and $+15^\circ\text{C}$ has been successfully demonstrated using this system.

1.4.4 Engineering Challenges

In the present design of ILD vertex detector, two sensor layers are mounted on both sides of a light-weight ladder of 2 mm thick. Our goal of the material budget of this ladder is $0.3\% X_0/\text{ladder} = 0.15\% X_0/\text{layer}$. This goal would not be so easy, and we need a lot of R&D effort. The ladders have to be cooled down to -40°C . We plan to achieve this cooling by heat conduction to the end-plate on which thin cooling tubes for 2-phase CO_2 are attached. The design of this structure is not trivial, and we need R&D including thermal simulation. There are challenges both in mechanical structure and in electronics circuit for the ladder R&D. We have not started this effort yet.

1.4.5 Future Plans

We have been doing our R&D on the FPCCD vertex detector based on a Grant-in-aid for science research which expires at the end of FY2015. By that time, we plan to carry out the following R&D items:

- Characterization of FPCCD sensors including beam tests and radiation damage tests




Figure 1.2: A simplified schematic diagram of the two-phase CO₂ cooling system

- Development of FPCCD sensors with the pixel size of 5 μm , which is our ultimate goal
- Construction of prototype ladders for inner layers
- Development of readout electronics downstream of ASICs

If new funding is secured in future, the following R&D items have to be done:

- Development of larger FPCCD sensors and prototype ladders for outer layers
- Development of readout electronics which can fit in the small space of real experiment
- Construction of real size engineering prototype and its cooling test

1.4.6 Applications Outside of Linear Colliders

Because of the relatively slow readout speed, application of FPCCD sensors to other high energy physics would be limited. However, high spatial resolution of small pixel size must be applicable to measurements of X-ray imaging in material science. Two-phase CO₂ cooling system can be applied to any other detectors which require efficient cooling between -40 °C and near room temperature. Our system, which uses a CO₂ gas compressor, has great advantage for low temperature operation near -40 °C compared with systems using liquid pumps for circulation.

1.5 CMOS

1.5.1 Collaborating Institutions

1.5.2 Introduction

1.5.3 Recent Milestones

1.5.4 Engineering Challenges

1.5.5 Future Plans

1.5.6 Applications Outside of Linear Colliders

1.6 CLICPix

1.6.1 Collaborating Institutions

- CERN
- Spanish network for Future Linear Colliders
- University of Liverpool
- Institute of Space Science, Bucharest
- University of Bristol

The University of Glasgow and the University of Oxford also intend to be involved, but they have not yet contributed.

1.6.2 Introduction

To achieve the physics goals of flavour tagging at CLIC, a vertex pixel detector with high spatial precision (3 μm single-point resolution), 10 ns time stamping and ultra-low mass (0.2% X_0 per detection layer) will be required.

1.6.3 Recent Milestones

- Development of the CLICpix hybrid pixel readout ASIC with 25 μm pitch, analog readout, time stamping, and power-pulsing functionality, implemented in 65 nm CMOS technology
- Development of ultra-thin (50 μm) planar pixel sensors, as well as active sensors with capacitive coupling
- Low-mass fine-pitch interconnects between sensor and ASIC
- Through-silicon via technology for powering, configuration and readout of the ASIC

- Low-mass powering infrastructure, including power-pulsing with local energy storage
- Low-mass carbon-fibre supports
- Detector cooling based on forced air-flow
- Concepts for mechanical integration and detector assembly
- Detector layout optimisation studies

1.6.4 Engineering Challenges

1.7 3D Pixel Development

1.7.1 Collaborating Institutions

- Brown University
- Cornell University
- Fermilab
- Northern Illinois University
- SLAC
- University of Illinois Chicago

1.7.2 Introduction

This R&D area covers sensors and electronics integrated utilizing 3-dimensional electronics technology. This technology is distinct from 3D sensors and builds on efforts in the electronics industry to stack multiple layers of electronics to form dense assemblies of complex devices. It is important for Particle Physics in that it allows very fine pitch ($4\text{ }\mu\text{m}$) integration of sensors with multiple layers of electronics, allows interconnection to both the top and bottom of devices, and provides techniques for low mass, thinned devices. The interconnection of top and bottom means that sensors can be bonded to complex electronics with no wasted area for interconnect and optimal delivery of power and ground.

1.7.3 Recent Milestones

Major R&D efforts and recent developments since ILC DBD (with publications/references to major results) We have completed our multi-year effort to demonstrate commercial 3D technology. This consists of two tiers of $0.13\text{ }\mu\text{m}$ CMOS interconnected with Direct Oxide Bonding (DBI) technology and access using Through-Silicon-Vias (TSV). The DBI bonds are at $4\text{ }\mu\text{m}$ pitch. Fermilab sponsored the first 3D multiproject run for Particle Physics. The wafers were delivered last summer. Fermilab had three chips on




Figure 1.3: 3D chips placed on BNL sensor wafers. VIP is middle left and right

the run VICTR – a CMS track trigger chip, VIPIC – an X-ray imaging chip, and VIP – an ILC vertex chip. Tests of the VIPIC and VICTR have shown working devices. Tests for the VIP chip were delayed due to lack of funding and personnel. We have recently restarted this work and initial tests are promising with the readout token successfully passed through the VIP.

In addition to the development of the 3D chips we have also explored the use of DBI to connect the 3D electronics with sensors. Brookhaven Laboratory fabricated a sensor wafer with regions that mate to the VIP, VIPIC and VICTR chips. The chips are ground to expose the top TSVs and contacts are deposited. The assembly is then attached to a handle wafer and the TSVs which project from the other side are exposed. Wafers are then process for DBI bonding and individual die from the 3D wafer are bonded to the sensor wafer. Finally the top “handle” silicon is ground and etched to reveal the previously formed contacts. The total thickness of the readout at the end of this process is about $25\text{ }\mu\text{m}$ (Figure 1.3). These wafers were received at the end of March 2014 and are being tested.

Due to the fact that contacts to a 3D assembly can be made to the body of the die, rather than its edge space usually reserved for wirebond contacts at the edge can be eliminated. This raises the possibility of fabricating large, complex pixel detectors of arrays of 4-side butted devices using sensors with active edges. We are in the process of demonstrating this technology utilizing active edge sensors fabricated at VTT and using wafer-to-wafer bonding to a 3D readout wafer. The active edge wafers are based on a silicon-on-insulator stack and thus can be fabricated with essentially arbitrarily thin sensors, in this case $200\text{ }\mu\text{m}$. Sensor and dummy readout wafers have been fabricated and a test wafer is being etched at SLAC. We expect to have DBI bonded assemblies this summer.

1.7.4 Engineering Challenges

Major engineering challenges include:

- Development of widely commercially available 3D technologies. Based partly on our development the silicon brokers CMP, CMC, and MOSIS now include 3D multiproject runs as part of their standard offerings.

- Development of high yield 3D bonded chip-to-wafer devices. This is the subject of our active edge project.
- This development shares with other vertexing technologies the problems of low mass mechanical support, power delivery, and cooling. An SOI-based device can be made thin without special effort. Such thinned devices will need low mass backing hybrid circuitry, presumably flex on carbon fiber or a similar technology

1.7.5 Future Plans

- Complete the 3D active edge project
- Apply our concepts to x-ray imaging devices
- ILC developments would await renewed funding in the US.

1.7.6 Applications outside of Linear Colliders

As stated above the technology is already being developed for CMS and x-ray imaging applications. The large area sensor concept is applicable for a variety of focal plane array concepts.

1. Grzegorz W. Deptuch, Gabriella Carini, Terence Collier, Pawel Gryboś, Piotr Kmon, et al. Results of Tests of Three-Dimensionally Integrated Chips Bonded to Sensors. *IEEE Trans.Nucl.Sci.*, 2013
2. R. Yarema, G. Deptuch, and R. Lipton. Recent Results for 3D Pixel Integrated Circuits using Copper-Copper and Oxide-Oxide Bonding. *Proceedings of Science*, 2014
3. P. Maj, G. Carini, G. Deptuch, P. Grybos, P. Kmon, et al. Tests of the First Three-Dimensionally Integrated Chip for Photon Science. *PoS, Vertex2012:027*, 2013
4. G. Deptuch, U. Heintz, M. Johnson, C. Kenney, R. Lipton, M. Narian, S. Parker, A. Shenai, L. Spiegel, J. Thom, and Z. Ye. 3D Technologies for Large Area Trackers. *ArXiv e-prints*, July 2013
5. R Lipton, G Deptuch, U Heintz, M Johnson, C Kenney, M Narian, S Parker, I Planell-Mendez, E Sawyer, A Shenai, L Spiegel, J Thom, and Z Ye. Combining the two 3ds. *Journal of Instrumentation*, 7(12):C12010, 2012
6. R Yarema, G Deptuch, J Hoff, F Khalid, R Lipton, A Shenai, M Trimpl, and T Zimmerman. Vertically integrated circuit development at fermilab for detectors. *Journal of Instrumentation*, 8(01):C01052, 2013




Figure 1.4: Major issues in the SOI pixel detector and introduction of a middle-SOI layer




Figure 1.5: Cross section of the double SOI chip after processing

1.8 SOI

1.8.1 Collaborating Institutions

KEK

1.8.2 Introduction

1.8.3 Recent Milestones

At present, major issues in the SOI pixel development are “back-gate effect”, “hole trap under the transistors by radiation,” and “sensor-circuit cross talks” as shown in Figure 1.4. For these, we have been developing a double SOI technology. The developed double SOI wafer has an additional middle-SOI(Si) layer under the transistors. The conduction layer of the middle-SOI can solve all the three issues. We could successfully process the double-SOI wafer (Figure 1.5). Threshold shift by radiations is successfully recovered by applying compensating voltage to the middle SOI layer (Figure 1.6).




Figure 1.6: Threshold shift recovery by applying compensating voltage (V_{soi2}) to the middle Si layer

1.8.4 Engineering Challenges

The resolution for the ILC vertex detector is required as better as a few μm . This means pixel size must be less than $20 \mu\text{m}$ square or so. On the other hand, each pixel must register arrival time of the hits during bunch train etc., so this requires many transistors and capacitors must be located in each pixel area. Natural solution to this is 3D vertical integration of circuit layer. SOI technology is very fit to the 3D integration since the thinning is stopped at the buried oxide (BOX). We already tried 3D SOI pixel chip in collaboration with T-Micro Co. Ltd. Process flow of micro-bump 3D connection is shown in Figure 1.7. We have confirmed low resistance ($6 \Omega/\text{bump}$) between upper and lower tiers for 1,000 daisy chain (2,000 bumps) as show in Figure 1.8. However, we think much higher density digital circuit such as 32 nm technology may be necessary for the upper tier in the ILC. This requires bonding of two different technology wafers. The 3D integration of different technology wafers (or chips) is still engineering challenge.

1.8.5 Future Plans

Detector R&D plans for the coming years; We are planning following items for the coming year.

- Sep. 2014 : Complete architecture study for the ILC pixel detector.
- Mar. 2015 : Design and fabrication of first test chip for the ILC.
- Dec. 2015 : Beam test of the test chip.




Figure 1.7: Micro-bump 3D integration process flow of the SOI pixel




Figure 1.8: Resistance of micro-bump daisy chain between upper and lower tiers

Chapter 2

Tracking Detectors

2.1 SCIPP Tracking R&D

SCIPP has been involved in Linear Collider tracking R&D for a number of years, and its work has led to the development of a refined understanding of several generic tracking issues with potential applications for Linear Collider detectors. These include the use of resistive strips and dual-end readout for the determination of the longitudinal coordinate of the charge deposition on narrow electrodes [13] and limitations on silicon microstrip ladder length for precision narrow-strip sensors [14]. These studies are in fact dependent only on the properties of the electrode that collects the signal and propagates it to the readout electronics, and thus are independent of the sensor technology that generates the signals. Thus, this work may have relevance to detection issues across a wide array of fields. Ongoing tracking R&D is focused on the further development of the Long Shaping-Time Front End (LSTFE) microstrip readout ASIC. This properties of this ASIC have been explicitly optimized for the readout of long ladders of silicon strip sensors that are motivated by the need for precise low-mass central tracking for a Linear Collider Detector. With a small and straightforward change to the shaping properties of the ASIC, it could be reoptimized for use for the short strips and high occupancy that would be expected for ILC forward-tracking applications. Similar to most ILC-oriented readout designs, the LSTFE features a long shaping time optimized to reduce voltage-referenced readout noise, as appropriate for narrow-strip, long-ladder applications. Unique to the LSTFE design, however, is the use of time-over-threshold readout to estimate the analog pulse-height generated by through-going subatomic particles. A pulse-development and readout simulation developed at SCIPP suggested that the intrinsic statistical fluctuations of the charge-deposition process in 300 Åm of silicon obviate the need for a precise measurement of deposited charge. A simulation of the centroid-finding (position-resolution) uncertainty provided by time-over-threshold readout showed little degradation relative to that provided by an exact measurement of deposited charge. On the other hand, there are several advantages offered by the use of time-over-threshold readout. It is very simple to implement within a digital back-end to the LSTFE's analog front end (the

implementation would be on the same chip as the front-end readout), requiring only a measurement of the number of clock counts that the given channel is over threshold, and then the assembly and transmission of a single data word containing the time of the upward transition, the time over threshold after the transition, and the channel number. This happens in real time and is driven immediately off the chip into the DAQ, eliminating the need for buffering and ADC conversion. In particular, there is no limit to the rate at which particles can be detected other than the return-to-baseline of the analog signal, and so the data-accumulation rate capability of the device is very high. In addition, for forward tracking, for which short strips are envisioned, the shaping time can be shortened significantly. This will further improve the rate capability of the LSTFE readout, making it an excellent choice for the high-occupancy forward region. Figure 1 shows the measured fractional charge uncertainty for the LSTFE prototype ASIC; for depositions expected from minimum-ionizing particles (1-4 fC) the fractional charge measurement uncertainty is approximately 15%, which is small compared to the intrinsic fluctuations that arise from the deposition process.

References

- [13] Jerome K. Carman, Vitaliy Fadeyev, Khilesh Mistry, Richard Partridge, Bruce A. Schumm, Edwin Spencer, and Max Wilder. Longitudinal resistive charge division in multi-channel silicon strip sensors. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 646(1):118 – 125, 2011
- [14] Kelsey Collier, Taylor Cunningham, Sean Crosby, Vitaliy Fadeyev, Forest Martinez-McKinney, Khilesh Mistry, Bruce A. Schumm, Edwin Spencer, Aaron Taylor, and Max Wilder. Microstrip electrode readout noise for load-dominated long shaping-time systems. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 729(0):127 – 132, 2013

2.2 KPIX

2.2.1 Collaborating Institutions

- SLAC National Accelerator laboratory
- University of California, Davis
- University of California, Santa Cruz
- University of Oregon
- University of New Mexico

2.2.2 Introduction

KPiX is a 1024 channel “System on a Chip” intended for bump bonding to large area Si sensors, enabling low multiple scattering Si strip tracking and high density Particle Flow calorimetry for SiD at the International Linear Collider (ILC).




Figure 2.1: Fractional pulse-height uncertainty (percent) versus injected charge (fC) for the LSTFE front-end ASIC. The development of this ASIC has been done solely at the Santa Cruz Institute for Particle Physics (SCIPP) within the University of California at Santa Cruz, and while slowed significantly due to the loss of support for Linear Collider Detector R&D, continues within SCIPP. Tasks that remain in developing a chip suitable for use in a Linear Collider Detector include the development of the digital back end; significant progress has already been made in defining the architecture of this section of the chip and in implementing this architecture in prototype form on an FPGA. Power cycling (switching the chip into a low-power quiescent mode for most of the 199 ms between beam crossings) also needs to be implemented.

Each channel consists of a dynamically switchable gain charge amplifier; shaping; threshold discrimination; and 4 sample and hold capacitors and 4 timing registers. The chip permits 4 separate measurements of amplitude and time of threshold crossing during each train, and amplitude digitization and readout during the intertrain period. The dynamic range is from sub minimum ionizing particle (mip) (320 micron silicon) to more than 2000 mip. KPjX also has a calibration system for each channel, servos for leakage compensation, “DC” reset for asynchronous operation for testing with cosmic rays, and polarity inversion for use with GEMs and similar detectors. The noise floor is about 0.15 fC (1,000 electrons), and the maximum signal is 10 pC (utilizing the dynamic range switching). The full dynamic range corresponds to 17 bits.

2.2.3 Recent Milestones

ILC related R&D in the US is largely unfunded and small efforts are being kept alive on the margins. The KPjX R&D is such an example of necessary work for SiD that is marginally alive.

2.2.4 Engineering Challenges

At this time, KPjX is seen as the baseline readout system for the tracker and electromagnetic calorimeter. A stack of 13 EMCal sensors with bump bonded KPjX was assembled for a beam test at SLAC in the summer of 2013. That test discovered that two kinds of crosstalk are significant:

- In-time crosstalk occurs due to parasitic coupling of traces on metal 2 of the sensor to other pixels. The level of crosstalk increases with the size of the signal, and decreases with increased speed of the front end charge amplifier (meaning increased current and power dissipation). A new sensor design is being developed that uses metal 1 to shield the traces of metal 2, and these ideas will be tested in the next sensor prototype.
- Out-of-time cross talk occurs when many pixels are hit and reset simultaneously. The resets collectively cause other pixels to trigger, and a cascade builds up. This uses up all the KPjX buffers. The root cause of the problem appears to be some internal logic within KPjX that is not current limited, and will require design modification.

A more general issue is that both the EMCal and tracker sensors from Hamamatsu were ordered with Al pads, as it was believed that plating (by the zincate process) a stack of metals culminating with Au would be straightforward. This turns out to be wrong. After many attempts at University of California Davis (UCD) and local industry, IZM has Ar ion etched the pad surfaces and sputtered a base layer, permitting the buildup of a stack that ended with Au, and permitting the attachment with solder bumps that had been placed during KPjX manufacture by TSMC. Testing of these sensors revealed 10% pixel to pixel shorts and some opens of signal traces, that are suspected to be damage caused by the Ar ion etch. Future sensors will be ordered with Au pads. An additional issue is that the Tracker sensor was planned to be wire

bonded to its (very thin) cable. The sensor oxide layer is not strong enough to allow wire bonding without damage, and so must be solder bumped. The pad pitch is small, and solder bumping the cable will be challenging. The trouble with the wire bonding to the sensor was unexpected. Another concern is that the current design of KPiX has deadtime after a pixel has accepted a trigger. Only the triggered pixel is affected; all the other pixels are available for signals. This deadtime is different from the usual notion of data acquisition deadtime where the entire detector is unavailable, but the correction to the luminosity integral is easy. Finally, the buffer requirement (4 in the current version of KPiX) is being re-evaluated in SiD simulations. A possible new architecture for KPiX is in early stages of evaluation. A small mechanical engineering effort has started to study the structure of the EMCal. The Sid EMCal has emphasized thin gaps between the tungsten layers to minimize the Moliere radius, and this implies that the structure is connected by columns at the vertices of the sensors. The DBD design shows hexagonal sensors, which indeed are the most efficient way of tiling large areas, but no consideration was given to the edges of these arrays. The engineering work is leading to the realization that it is probably easier and cheaper overall to use two sizes of rectangular sensors, where the two sizes can be selected to tile to the edges of the layers and even tile the endcaps reasonably. Thus it is likely that the next round of EMCal sensor prototypes will be rectangles with square pixels. Tracker sensors are now at IZM for the pad plating and subsequent bonding of KPiX; they will then go to UCD for cable attachment and testing.

2.2.5 Future Plans

Assuming positive developments with Japan are announced soon, we expect the financial support to improve. It should be noted that an important effect of the withdrawal of support is that most of the US collaborators have been forced to move to other work.

- EMCal Sensors: A second round of prototypes will be designed and ordered with rectangular layout; shielded traces, and Au pads.
- Tracker Sensors: The current prototypes will be evaluated, and if appropriate tested in a beam.
- KPiX: A new architecture with little (or no) deadtime will be evaluated. A decision will be made to develop this new architecture or incrementally.
- improve the existing design.
- The EMCal mechanical structure will be pushed towards a conceptual design.

2.2.6 Applications Outside of Linear Colliders

This work represents a significant step in the aggressive integration of silicon sensors with readout electronics, just short of integrating the electronics directly into the sensors. It has prompted consideration of this approach by CMS for calorimetry and by ATLAS for a muon system. It may have applications in sensors for light sources as well as other particle physics detectors.

2.3 Time Projection Chamber – Bonn

2.3.1 Collaborating Institutions

- CEA Saclay
- NIKHEF
- Fraunhofer Institut IZM, Berlin

2.3.2 Introduction

The University of Bonn is studying the pixelized readout of a TPC for the ILD detector. The readout is based on the Timepix ASIC with a triple GEM or Micromegas based gas amplification.

2.3.3 Recent Milestones

The first studies were based on the triple GEM setup with a single Timepix chip. This readout was mounted in a small test detector in the Bonn laboratory. Here, the working principle was tested with a long drift distance. It could be demonstrated that the transverse spatial resolution of the reconstructed primary electrons was close to the expected diffusion limit of single electrons. The results are summarized in the following publications:

- C. Brezina, K. Desch, J. Kaminski, M. Killenberg, and T. Krautscheid. Operation of a gem-tpc with pixel readout. *Nuclear Science, IEEE Transactions on*, 59(6):3221–3228, Dec 2012
- J. Kaminski, Martin Killenberg, Andreas Bamberger, Hubert Blank, Christoph Brezina, K. Desch, T. Krautscheid, Walter Ockenfels, Uwe Renz, Martin Ummenhofer, Peter Wienemann, Simone Zimmermann, and A. Zwerger. Time projection chamber with triple gem and pixel readout. In *Nuclear Science Symposium Conference Record, 2008. NSS '08. IEEE*, pages 2926–2929, Oct 2008
- C Brezina, K Desch, J Kaminski, M Killenberg, F Klöckner, T Krautscheid, U Renz, and M Schumacher. A time projection chamber with triple gem and pixel readout. *Journal of Instrumentation*, 4(11):P11015, 2009
- Jochen Kaminski, Christoph Brezina, Klaus Desch, Martin Killenberg, Frederik Klockner, et al. Time projection chamber with triple GEM and highly granulated pixel readout. *Conf.Proc.*, C0908171:533–535, 2009
- Peter Schade and Jochen Kaminski. A large {TPC} prototype for a linear collider detector. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 628(1):128 – 132, 2011. {VCI} 2010 Proceedings of the 12th International Vienna Conference on Instrumentation

The new focus are GridPix based detectors, where the gas amplification stage is a Micromegas produced in a postprocessing technique, which guarantees a high quality grid well aligned with the readout pixels. This approach was pioneered by NIKHEF and the University of Bonn has modified the production process together with the Fraunhofer Institut IZM so that a wafer-based production of GridPix detectors is standard by now. The new GridPixes were tested on small prototype detectors and also assembled in an 8 GridPix module for the Large Prototype detector at DESY. A successful test beam campaign was performed last year.

- M Lupberger. The pixel-tpc: first results from an 8-ingrid module. *Journal of Instrumentation*, 9(01):C01033, 2014
- W.J.C. Koppert, N. van Bakel, Y. Bilevych, P. Colas, K. Desch, M. Fransen, H. van der Graaf, F. Hartjes, N.P. Hessey, J. Kaminski, J. Schmitz, R. Schön, and F. Zappon. Gridpix detectors: Production and beam test results. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 732(0):245 – 249, 2013. Vienna Conference on Instrumentation 2013

The current work is focused on a new LP module with about 100 GridPixes. This module is a demonstrator that larger areas (400 cm^2) can be produced and operated. It shall be tested in the LP at the beginning of next year. For this a number of challenges have to be coped with. In particular commercial readout systems are not easily scalable. This is why Bonn has developed a cheap and easily expandable system based on the Scalable Readout System (SRS) of the RD51 collaboration. In addition Bonn is developing the software for reconstructing and analyzing the test beam and simulation data. For this the LCTPC software framework of MarlinTPC is used.

- Jason Abernathy, Klaus Dehmelt, Ralf Diener, Jan Engels, Jim Hunt, Martin Killenberg, T. Krautscheid, A. Munnich, Simone Zimmermann, Martin Ummenhofer, Adrian Vogel, and Peter Wienemann. Marlintpc: A common software framework for tpc development. In *Nuclear Science Symposium Conference Record, 2008. NSS '08. IEEE*, pages 1704–1708, Oct 2008

Finally, Bonn also takes part in designing new pixel chips. To test the new digitization and readout techniques two test chips were designed in collaboration with NIKHEF. Then Bonn also contributed to the design of the Timepix successor chip, Timepix3, which is being tested now:

- A Kruth, C Brezina, S Celik, V Gromov, R Kluit, F Zappon, K Desch, and H van der Graaf. Gossipo-3: measurements on the prototype of a read-out pixel chip for micro-pattern gaseous detectors. *Journal of Instrumentation*, 5(12):C12005, 2010
- C. Brezina, Y. Fu, F. Zappon, M. van Beuzekom, M. Campbell, K. Desch, H. van der Graaf, V. Gromov, R. Kluit, X. Llopart, T. Poikela, and V. Zivkovic. Gossipo-4: Evaluation of a novel pll-based tdc-technique for the readout of gridpix-detectors, 2014

- Y Fu, C Brezina, K Desch, T Poikela, X Llopart, M Campbell, D Massimiliano, V Gromov, R Kluit, M van Beuzekom, F Zappon, and V Zivkovic. The charge pump pll clock generator designed for the 1.56 ns bin size time-to-digital converter pixel array of the timepix3 readout asic. *Journal of Instrumentation*, 9(01):C01052, 2014

2.3.4 Engineering Challenges

The production of a module with 100 GridPixes requires 4 main components: The production of a large number of GridPixes with sufficiently good quality. This has been addressed by the new production method and a large batch is being produced. The challenge of the readout is being addressed by the new readout system. Finally the distribution of the LV power to all ASICs and the cooling of the ASICs still are unclear, but since both challenges are similar for most readout electronics, standard solutions are expected to be adequate.

2.3.5 Future Plans

On a short term the production of the 100 ASIC module is the main goal at Bonn. If this module has been successfully operated, we are interested in replacing the Timepix ASIC by the Timepix3 ASIC and produce GridPix detectors with this improved chip. There are also some ideas of how to improve the grid structure and make it more reliable. Finally, the reconstruction and analysis software needs further improvement and has to be extended, so that simulated data for the final TPC (i.e. 10,000 hits per track) can be studied.

2.3.6 Applications Outside of Linear Colliders

A single InGrid detector will be installed this year in the CAST experiment for ax-ion search. For a CLIC-TPC a highly granular (i.e. pixelized) readout structure is mandatory to lower the occupancy.

Chapter 3

Electromagnetic Calorimeter R&D

3.1 Scintillator Strips

3.1.1 Collaborating Institutions

Nihon Dental University, Shinshu University, Tokyo University (ICEPP), Tsukuba University

3.1.2 Introduction

3.1.3 Recent Milestones

- introducing a new scintillation light readout scheme, with different scintillator strip shape by having better homogeneity
- photo-sensor of increased number of pixels in 1mmx1mm, this leads larger dynamic range for the calorimeter
- more experience on the FE read out board and ASICs

They are not published yet, instead some proceedings

3.1.4 Engineering Challenges

- wrapping the scintillator strip and align them on the FE read out layer automatically
- mass test facility for the read out layer

3.1.5 Future Plans

- optimizing scintillator layer: shape of scintillator strip, how to read out scintillation light, the location of photo-sensor, size and shape of photo-sensor and mass production scheme
- developing photo-sensor with Hamamatsu photonics company, to have larger dynamic range and mass test scheme
- establish a detector fabrication plan

3.1.6 Applications Outside of Linear Colliders

- photo-sensor named MPPC from Hamamatsu photonics INC is employed for the T2K experiment, CMS upgrade (HC-CAL), BELLII detector (endocarp muon)
- PET and SPECT development

3.2 Silicon Pads

3.2.1 Collaborating Institutions

- LPNHE-Paris
- LAL
- Univ. of Tokyo
- Kyushu University

3.2.2 Introduction

3.2.3 Recent Milestones

ELECTROMAGNETIC Calorimeter

- First development of PFA for dedicated detector (TESLA Report)
- First prototype of High granularity electromagnetic calorimeter (“physics prototype”, see publications in the CS report).
- First design of ECAL silicon–tungsten for a full scale detector (From TESLA report to DBD 2013)
- R&D on scalable technology for all the involved large detector aspects (integration of embedded readout chips, on thin supporting electronics boards, in self-supporting tungsten–carbon mechanical elements ensuring the cooling and protection; all made of exchangeable elements with a quality control procedure; the associated DAQ).

- Realisation of a large self-supporting W–Carbon fiber structure with integrated stress monitoring (using Fiber Bragg Grating)
- Recently: tests of 1st base sensor units of the technological prototype in beam

PFA:

- Development of Mokka an overlayer of the GEANT4 used for ILD, CLIC detectors, CALICE TB, ...
- Reconstruction tools adapted to the high granularity calorimeters (photon reconstruction [GARLIC], Advanced clustering [ARBOR], event displays [DRUID])

ILD integration & optimisation

- for the DBD: integration of all the ILD elements, placement of services, thorough estimation of total cost of the detector
- since DBD: re-optimisation of the ILD dimensionning, esp. for the Si-W ECAL using full PFA reconstruction.

3.2.4 Engineering Challenges

- Silicon wafer cost reduction when used for calorimetry; direct contact with producers established (Hamamatsu, On-Semi, ...).
- A chip with the good dynamic, noise, power dissipation (using power pulsing), etc.
- Integration in a compact device, ensuring all the requests (precision: electronic and mechanic, heat production, reliability)
- Industrialisability of solutions; scalability of tests for a 100M channel detector.

3.2.5 Future Plans

Impossible. No way to see beyond next year (see IN2P3 recommendation) To recall, all the R&D will stop at the end of 2016, if there is no decision in Japan

3.2.6 Applications Outside of Linear Colliders

- CEPC, TLEP and directly today on CMS upgrade
- The compact Silicon-W design has been used in the PAMELA satellite (very similar to physics prototype)

Table 3.1: ASICs produced for recent prototypes of highly granular calorimeters. Note that variants of these ASICs are used in Earth Sciences (PARISROC) and Space Applications (SPACIROC).

| ASIC | Detector | produced quantities |
|---------------|-----------------------------------|---------------------|
| SKIROC [12] | SiW ECal | 1000 |
| HADROC [18] | GRPC-SDHCAL | 9000 |
| MICROPROC [2] | Micromega-SDHCAL | 350 |
| SPIROC [31] | Analog HCal and Scintillator ECal | 1000 |

3.3 SiliconPads LAL

3.3.1 Introduction and Physics Prototype

Precision measurements at the Linear Collider require highly granular calorimeters. The activities at LAL are focalised on the R&D for a highly granular silicon tungsten calorimeter. The work is conducted in the framework of the international collaboration CALICE. A prototype called “Physics Prototype” has been operated with success in the years 2004–2011 and has been the subject of large scale test beam campaigns at DESY, CERN at FNAL.. The engineers of the microelectronics group OMEGA of LAL (until 2013) have conceived the ASICs for this prototype as well as for a number of other prototypes, e.g. electromagnetic and hadronic calorimeters with scintillating tiles or strips. The LAL has assured the coordination of the beam test campaigns in 2007, 2008 and 2011. A publication based on data recorded in 2007 has been published in 2011 [3]. This publication gives confidence that embedding the front end electronics into the calorimeter layers does not compromise the detector performance. A second publication on the interaction of hadrons in the Ecal based on the 2008 is about to be published in a peer reviewed journal. This publication started out from the CALICE Analysis Note CAN-025 [19].

3.3.2 Technological Prototype

The work is now oriented versus the construction of a technological prototype. The front end ASICS, called SKIROC2, have been realised by OMEGA. Again it is has to be pointed that here a e horizontal approach of the ASIC development has been followed since similar ASICs has been realised for analog and semi-digital highly granular electromagnetic and hadron calorimeters. An overview on the ASICs produced for recent prototypes is given in Table 3.1. The SKIROC ASIC will be embedded into the calorimeter layers and mounted on 9 layer PCBs that will be as thin as 1.5mm. Silicon wafers the PCB and the 16 mounted circuits constitute the Active Signal Units or ASUs. Up to ten of these ASUs will be assembled to- gether to form a calorimeter layer. The technology of the interconnection has been developed at LAL and applied with success to first units of the technological prototype. A series of beam tests with simplified ASUs have been carried out in the years 2012 and 2013 at DESY. The LAL has organised these beam tests as well as have assured the coordination of the data taking. The analysis of these data validated the concept of the front end electronics

but will also allow for correcting a small number of shortcomings of the SKIROCs ASIC. These will be corrected in the version SKIROC2b that is supposed to be produced at the end of 2014. A paper on the analysis of the 2012 data has been submitted to JINST in March 2014 [36],[20]. Particularly in summer 2013 (i.e. Post-DBD phase), the SKIROC ASIC has been operated in power pulsed mode. For this bias currents of the ASIC are shut down and raised with a given frequency (5Hz for ILC, 10Hz in our beam tests). The good agreement between the MIP spectra obtained in power pulsed and conventional mode (see e.g. [35]) give confidence that this technology can indeed be applied for a calorimeter at a linear collider and more precisely at the ILC. More studies are needed as the technological prototype grows in size. After the departure of the OMEGA group from LAL the development of microelectronics at LAL has been stopped. A new institute with the same name, i.e. OMEGA, has been created by the IN2P3 and is hosted at the Ecole Polytechnique. The ILC group at LAL will continue to collaborate with the new institute. The details will however have to be sorted out under the new circumstances. It is maybe still worthwhile to say that for the next it is planned to first produce the debugged version SKIROC2b (see above) and then the version SKIROC3. The latter will comprise all the features needed for an ASIC.

3.3.3 Plans of the near future - Ecal assembly bench and R&D on digital electronics

The different units of the SiW Ecal for the ILD detector need to be assembled into detector layers of up to two meter in length comprising up to 10 detection units dubbed ASUs. For this we propose to develop an assembly line, incorporating the reception and the test of the material, the alignment of the ASUs and the interconnection, with a continuous monitoring for quality control purposes. The deliverable is a still manual assembly bench capable for a small production of layers. Based on the manual assembly bench we will propose an automatised system for mass assembly together with industrial partners. A survey to search for partners is part of the proposal. A goal is to design the system such that it can be easily duplicated at other sides. In the ideal case the assembly bench is versatile enough to reply to needs for other detector systems than ILD (e.g. CMS). Relevant data recorded during the assembly process can for example stored in a database. The tools for efficient storage and retrieving data and information about detector components can be developed in collaboration with other proposals aiming at the mass production of calorimeter elements and/or benefit from similar tools developed e.g. for the XFEL project. This project might become a task within the calorimeter package of the AIDA2 project.

The departure of the OMEGA group requires re-orientation of the LAL contribution to detector electronics. The LAL has recognised competences in digital electronics. It is considered to embark on the R&D for DAQ systems for linear collider detectors. Details will be worked during 2014. It is envisaged to make this work part of the calorimeter package of the AIDA2 project.




Figure 3.1: Structure of the FLC group at LAL as of April 2014.

3.3.4 Further Activities

Although not explicitly asked it is worthwhile to point out that the LAL plays also a role in the integration of the ILD detector. Notably the engineers are in charge of validating the CAD Models of the sub-detectors before they come part of the official ILD database. It can be expected that this activity increases in importance when the ILC will move towards a real project.

Finally, since 2012 there is a collaboration with the AppStat group of LAL. The aim of this collaboration is to develop algorithms based on machine learning techniques to assure an optimal separation of particle showers in highly granular calorimeters.

3.3.5 Funding, Manpower and Partners

We have a sustained funding through the French IN2P3 that sums up to around 30 kEUR/year (Material and travel funds). Between 2011 and 2014 additional funding came through a French ANR contract (around 110kEUR, partner of the LLR). The latter allowed for financing 2/3 of a PhD thesis. Finally there is a two years PostDoc grant (shared with the LLR) through the excellence cluster P2IO. Funding through AIDA allowed for developing the next generation of ASICs but meanwhile the money has been transferred to the new IN2P3 institute OMEGA. Figure 3.1 summarizes the manpower situation as of April 2014 Please note however that in particular the engineers do not work 100% on ILC matters. Their contribution is 30% on average.

As said above considerations are ongoing to increase the engineering effort in the coming months. The activities of LAL are well embedded in the international collaboration CALICE as well as is in the ILD detector concept. On the Ecal R&D the main partners are the LLR/Palaiseau and OMEGA/Palaiseau. To this adds in France the LPNHE/Paris, LPSC/Grenoble. On the international level we collaborate with the University of Tokyo, the University of Kyushu and the SKKU (Suwon, Korea).

Chapter 4

Hadronic Calorimeter R&D

4.1 Scintillator Tiles

4.1.1 Collaborating Institutions

4.1.2 Introduction

4.1.3 Recent Milestones

4.1.4 Engineering Challenges

4.1.5 Future Plans

4.1.6 Applications Outside of Linear Colliders

4.2 Resistive Plate Chambers

4.2.1 List of participating institutes

The following institutes are currently participating in the DHCAL efforts:

- Argonne National Laboratory – member of CALICE
- Boston University – member of CALICE
- COE College (Iowa)
- University of Iowa – member of CALICE
- Shanghai Jiao Tong University – SJTU (in discussion)
- University of Science and Technology of China – USTC (in discussion)

4.2.2 Description of the DHCAL

The Digital Hadron Calorimeter or DHCAL uses Resistive Plate Chambers (RPCs) as active elements. The chambers are read out with 1×1^2 pads and 1-bit (digital) resolution. A small-scale prototype was assembled and tested in the Fermilab test beam in 2007 to validate the concept. Based on the success of the small-scale test [1-6], a large prototype with up to 54 layers and close to 500,000 readout channels was built in 2008 – 2011. Each layer measured approximately $96 \times 96 \text{ cm}^2$ and was equipped with three chambers, stacked vertically on top of each other. For tests with particle beams the DHCAL layers were inserted into a main stack of 38 or 39 layers, followed by a tail catcher with up to 15 layers. For the tests performed at Fermilab the main stack contained steel absorber plates. At CERN the absorber plates contained a Tungsten based alloy. In both cases the tail catcher featured steel absorber plates. In the various test beam campaigns combined, spanning the years 2010 – 2012, the DHCAL recorded of the order of 14 Million muon events and 36 Million secondary beam events, where the latter contained a mixture of electrons, muons, pions, and protons.

4.2.3 Current R&D activities

The analysis and publication of the test beam results are currently the highest priority of the DHCAL group. Major challenges, such as the calibration (or equalization) of the response of the RPCs and the detailed simulation of the response of RPCs, are very close to having been overcome [7-11]. In parallel, to the analysis of test beam data, the group is pursuing the following R&D activities:

Development of 1-glass RPCs

The DHCAL prototype featured a standard chamber design based on RPCs with two resistive plates. The Argonne group, however, proposes to eliminate one of the glass plates in future applications. The advantages are: close to unit pad multiplicity with significant simplification of the calibration and monitoring procedure, reduced thickness of the active element, higher rate capability, and insensitivity of the response to the surface resistivity of the resistive layer (used to apply the High Voltage). To date several 1-glass RPCs have been assembled. The chambers tested very well with cosmic rays. Tests in particle beams are planned for future test beam campaigns.

Development of high-rate RPCs

Due to the high bulk resistivity of glass (and Bakelite), RPCs are notoriously rate limited [12]. The DHCAL group is addressing this shortcoming with the development of semi-conductive glass (in cooperation with COE college) and of low-resistivity Bakelite (in co-operation with USTC). First chambers with samples of low-resistivity glass plates have been assembled and have tested in the Fermilab test beam.

Development of a High-Voltage distribution system

With up to 50 layers in a single calorimeter module, a cost-effective way to distribute the High-voltage to individual layers is required. A system capable to regulate the voltage within a few 100 V, to monitor both the current and the voltage, and to switch off individual channels, is being developed. A first prototype controlling a single channel has been assembled and tested successfully with an RPC. The development is currently on hold due to lack of funding.

Development of a gas recycling system

The operation of RPCs requires a gas mixture, which is both costly and environmentally harmful. To limit the effect of releasing gas into the environment, the DHCAL group is developing a gas recycling system. The system is based on a new approach, appropriately labeled “Zero Pressure Containment”. A prototype of the gas collection subsystem is currently being assembled; however, progress is again slow due to lack of funding.

Development of the next generation front-end readout system

The next generation front-end readout system will contain several upgrades compared to the current system: higher channel count, token ring passing, low power operation, power pulsing, and improved internal charge injection systems. To proceed, the project is awaiting funding from both US and Chinese agencies.

4.2.4 Engineering challenges

Several engineering challenges remain to be addressed before an RPC-based DHCAL can be proposed as an option for a colliding beam detector. Following is an (incomplete) list of the major issues: - Industrialization of the construction of RPCs. - Design of the readout boards, covering the entire area of the layer (with varying width). The design is expected to feature only a minimum number of different boards. - Design of the gas distribution system, which ensures equal pressure in all layers of a given module, independent of its orientation. - Development of a cooling strategy for the front-end boards, which will include power pulsing, as well as active cooling. - Development of a module assembly procedure.

4.2.5 Plans for the coming years

The activities of the coming years depend strongly on the progress with the Japanese intentions to host the ILC. Assuming the ILC project goes ahead, the DHCAL group will a) Complete the analysis and publication of the test beam data, b) Complete the R&D projects listed above, and c) Start the development of the design of calorimeter modules. In case, the ILC is not going forward, the group plans on completing the data analysis and to continue the tests of high-rate RPCs. Other R&D projects, such as the development of distribution systems, will be put on hold.

4.2.6 Applications beyond the ILC

The DHCAL technology was specifically developed for the hadron calorimeter of the ILC, with its low particle rate and radiation dose. To export the technology to other environments, the rate capability of the chambers and the radiation hardness of the readout need to be improved. The former is being addressed with low-resistivity plates (glass and Bakelite), while the latter will require a new front-end readout system based on an ASIC using a smaller feature size. Possible applications are the tail catcher of the forward calorimeters of CMS and the outer wheels of the ATLAS muon system. Both options are being pursued actively.

References

1. Gary Drake, José Repond, David Underwood, and Lei Xia. Resistive plate chambers for hadron calorimetry: Tests with analog readout. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 578(1):88 – 97, 2007
2. B Bilki, J Butler, T Cundiff, G Drake, W Haberichter, E Hazen, J Hoff, S Holm, A Kreps, E May, G Mavromanolakis, E Norbeck, D Northacker, Y Onel, J Repond, D Underwood, S Wu, and L Xia. Calibration of a digital hadron calorimeter with muons. *Journal of Instrumentation*, 3(05):P05001, 2008
3. B Bilki, J Butler, E May, G Mavromanolakis, E Norbeck, J Repond, D Underwood, L Xia, and Q Zhang. Measurement of positron showers with a digital hadron calorimeter. *Journal of Instrumentation*, 4(04):P04006, 2009
4. B Bilki, J Butler, E May, G Mavromanolakis, E Norbeck, J Repond, D Underwood, L Xia, and Q Zhang. Measurement of the rate capability of resistive plate chambers. *Journal of Instrumentation*, 4(06):P06003, 2009
5. B Bilki, J Butler, G Mavromanolakis, E May, E Norbeck, J Repond, D Underwood, L Xia, and Q Zhang. Hadron showers in a digital hadron calorimeter. *Journal of Instrumentation*, 4(10):P10008, 2009
6. Q Zhang, B Bilki, J Butler, E May, G Mavromanolakis, E Norbeck, J Repond, D Underwood, and L Xia. Environmental dependence of the performance of resistive plate chambers. *Journal of Instrumentation*, 5(02):P02007, 2010
7. CAN-30 and CAN-30A: Analysis of DHCAL Muon Data
8. CAN-31: DHCAL Noise Analysis
9. CAN-32: DHCAL Noise Analysis
10. CAN-39: Analysis of Tungsten-DHCAL Data from the CERN Test Beam
11. CAN-42: The DHCAL Results from Fermilab Beam Tests: Calibration
12. L.Xia: Development of High-Rate RPCs. Talk given at the XII Workshop on Resistive Plate Chambers RPC2014.

4.3 GEM

4.3.1 Collaborating Institutions

4.3.2 Introduction

4.3.3 Recent Milestones

4.3.4 Engineering Challenges

4.3.5 Future Plans

4.3.6 Applications Outside of Linear Colliders

4.4 FCAL

4.4.1 Collaborating Institutions

- AGH-University of Science and Technology, Cracow, Poland
- CERN, Geneva, Switzerland
- DESY, Zeuthen, Germany
- IFIN-HH, Bukharest, Romania
- IFJPAN, Cracow, Poland
- ISS Bukharest, Romania
- LAL Orsay, France
- JINR Dubna, Russia
- NCPHEP Minsk, Belarus
- Pontificia Universidad Catolica de Chile, Santiago, Chile
- Tel Aviv University, Tel Aviv, Israel
- Tohoku University Sendai, Japan
- University of Colorado Boulder, USA
- University of California Santa Cruz, USA
- VINCA Institute of Nuclear Science & University of Belgrade, Belgrade, Serbia

4.4.2 Introduction

4.4.3 Recent Milestones

4.4.4 Engineering Challenges

4.4.5 Future Plans

4.4.6 Applications Outside of Linear Colliders

4.5 Analog HCAL

4.5.1 Collaborating Institutions

The AHCAL effort is organized with a reasonable degree of task sharing. The table below lists the participating institutes and their main fields of activity:

DESY steel structures, electronics and integration, test beam support, software, project management

Hamburg SiPMs and tile optimisation, test beam and commissioning with DESY

Heidelberg high gain ASICs, SiPM mass tests and characterisation

MPI Munich SiPM development, tile optimisation, cassettes, fast timing

Wuppertal embedded LED electronics and test stands

Mainz DAQ central components, AHCAL data concentrator, mass production

Omega SPIROC ASICs

CERN tungsten absorber, testbeam and Geant4 support

ITEP tiles and SiPMs, test bench characterisation

MEPHI SiPM development

Dubna power supplies and distribution

Prague fibre based LED system, temperature compensation

NIU alternative SiPM coupling, DAQ interface

Bergen calibration studies, temperature compensation

Shinshu scintillator strip alternative, photo-sensors

4.5.2 Introduction

With the advent of silicon photo-multipliers (SiPMs), the scintillator tile technology became a candidate for highly granular particle flow calorimetry. With analogue read-out, energy and spatial resolution can be optimized independently. The particle flow performance is well understood; all published studies using Pandora are based on this technology.

The CALICE AHCAL was the first large LC hadron calorimeter prototype to be exposed to test beams. Analysis is nearly complete and mostly published; the results validate the technology and the simulations.

The development of engineering solutions for a realistic detector is on its way. The integration of read-out electronics and calibration system into the detector layers has been demonstrated. The next step, an integrated stack, is being prepared. In parallel, as improved photo-sensors become available from industry, the design of the basic read-out cell – the tile with SiPM – is optimized with regard to mass production procedures.

4.5.3 Recent Milestones

Past and present R&D: test beam data analysis

The following results using data taken the first AHCAL “physics” prototype in 2006 – 2011 at CERN and Fermilab have been published in peer-reviewed journals:

1. Detector construction, noise and ageing studies
2. Electromagnetic linearity and resolution
3. Hadronic linearity and resolution, software compensation
4. Test of particle flow algorithms (AHCAL with SiW ECAL)
5. Studies using a scintillator SiPM based tail catcher
6. Geant 4 validation with pion showers
7. Geant 4 validation with tungsten absorber (low energy)
8. Imaging capabilities, track segments

We consider all of them as critical for validating a given HCAL technology. Papers 6, 7 and 8 appeared in the last year since the ILC TDR was handed over.

Preliminary results have been made public in the form of CALICE analysis notes after intense internal reviewing on the following topics:

1. Combined performance SiW ECAL + AHCAL + Tail Catcher
2. Leakage estimation using shower topology
3. Time structure of showers in Fe and W
4. Geant 4 validation with protons

5. Parameterisation of pion and proton shower shapes

6. Geant 4 validation with tungsten absorber (high energy)

Notes 4, 5 and 6 appeared in the last year since the release of the ILC TDR. The studies are actively been followed up towards final publication; only the leakage study is presently uncovered due to lack of manpower.

Studies of the combined performance of the AHCAL in conjunction with the scintillator tungsten ECAL with MPPC readout are on-going. Results are expected in the coming year and will make the analysis of the first generation test beam data complete.

Data taking with a first, partially instrumented stack of the second generation has started at DESY and will continue in fall 2014 with electrons and hadrons at CERN. A framework for analysis software exists, but there is still a lot to do. In particular, calibration and correction procedures for timing measurements need to be developed.

The CALICE test beam results are nowadays the primary source of validation for hadron shower simulation, according to Geant 4 representatives, and extremely valuable for other HEP experiments, e.g. at the LHC, as well.

We finally note that test beam analysis plays an important role in training our students. Roughly speaking, each paper or note corresponds to one or several PhD theses. It is a distributed effort; the results have been obtained at DESY, CERN, MPI Munich, Hamburg, Heidelberg, Mainz and Wuppertal universities, ITEP Moscow and Northern Illinois University. Past and present R&D: technology 1. Optimisation of the scintillator SiPM read-out cell

As a consequence of the wide success of SiPM applications in other fields, e.g. in medical imaging, the development of improved sensors is dynamically pursued in industry, and several groups (ITEP, MEPHI, Shinshu, Hamburg) are in close contact with leading producers. Progress has been made in terms of dark rate, noise above MIP threshold and dynamic range. In addition, the samples are much more homogenous than at the time of the first prototype, which results in a simplification of commissioning and calibration procedures.

In the time since the TDR, tile SiPM cells without wave-length shifting fibre have been developed, following a design by MPI Munich. One is based on machined, individually wrapped scintillator plates (Hamburg), the other one on injection-moulded tiles (ITEP). Both are using sensors from KETEK, those on the moulded tile have a very large dynamic range. 300 devices have been produced and tested at ITEP, and more than thousand devices have been produced and tested with semi-automatic procedures at Hamburg and Heidelberg. Part of them has been integrated into the test beam set-up early this year. This version is a good candidate for a baseline design for a full detector, but more data taking and analysis is needed.

Industrialisation of the SiPM and tile design and production procedures is a long-standing item, but tests with industrial facilities such as automatic pick-and-place machines have begun only recently (Mainz). This needs to be continued in the coming years, fed back into the cell optimisation, and awaits a feasibility demonstration at larger scale.

An alternative design, with photo-sensors integrated in the read-out electronics board, has been proposed some time ago (Northern Illinois), but the detailed devel-

opment of the corresponding sensor and scintillator configuration has only recently been taken up again (NIU, Mainz, ITEP). It has the potential to result in further simplifications (which should be read as cost and time savings), but poses higher performance requirements to the SiPM and raises new issues in the quality assurance and integration chain. The goal is to develop such an alternative solution in the next 2–3 years.

2. Electronics and active layer integration

The design of the active layers (DESY) with integrated read-out ASICs (LAL/OMEGA) and calibration system (Wuppertal) has been basically validated in beam tests of a single HCAL layer consisting of four base units (HBUs) at CERN in 2012 and reported in the TDR. An HBU reads 12×12 tiles with 4 ASICs. The present ASIC belongs to the 2nd generation ROC family used also in ECAL and SDHCAL. An HCAL layer carries interfaces for DAQ, calibration and power supply, which already have a compact design fulfilling space constraints at an ILC detector.

The main difference between the integrated electronics and that of the physics prototype is the self-triggered operation and on-detector zero-suppression, which implies much higher demands on controlling the noise behaviour and ensuring a stable detector response. It is thus mandatory to re-establish the calorimeter performance with a full-scale beam test. However, this is out of reach with present funding levels.

Further R&D in the next years has to be done both on the ASIC and on the PCB. For the ASIC, development of a 3rd generation ROC chip will start after fixing open issues with the 2nd generation (OMEGA). The 3rd will have a more robust slow control architecture and channel-wise buffer management which improves rate capabilities. In parallel, an alternative design of the analogue part (Heidelberg), which can handle a larger range of sensor gain needs to be complemented with a digital part.

The PCB with integrated photo-sensors, as counterpart of the corresponding tile design (see 1.), needs to be developed, taking automatic production and quality assurance into account. The PCB is also one of the main cost drivers of a particle flow HCAL. Dedicated R&D, in close cooperation with industrial manufacturers, is necessary to bring the cost down. First contacts have been made (DESY, Heidelberg, SKKU Korea).

3. System integration

While the integration of layers is well advanced, that of entire stacks or module has only begun. Since the TDR release, efforts concentrated on developing a multi-layer DAQ capable of reading larger systems (DESY, Mainz). An intermediate version has been used in an electron beam test of an 8 layer stack at DESY in early 2014.

Work has been intensified to further develop the DAQ towards a scalable system, with the goal to have it ready for beam tests at CERN starting in fall 2014. It involves integration of a dedicated module data concentrator, which collects signals from all layers for sending them to the off-detector data receiver.

Further work will be required to integrate the HCAL DAQ into a higher level system for the purpose of combined beam tests, for example with a tracking device for uniformity studies, or with an ECAL for inter-calibration and combined performance. The same is true for slow control data.

A power supply system with optimised channel density per module is being developed at Dubna.

It has been demonstrated that temperature-induced variations of the SiPM gain can be compensated by adjusting the bias voltage (Prague, Bergen). The approach has the potential to stabilise the detector response and trigger efficiency and thus simplify operations significantly. Automatic procedures based on this principle need to be developed and implemented for a test at system level.

On the mechanical side, a cooling system needs to be developed. The ASICs integrated in the detector layers are power-pulsed and do not need active cooling, but the interfaces, in particular the power regulators, do. A simple solution for beam tests is on the way (DESY), but a leak-less under-pressure based system for a large detector still needs to be prototyped.

4. Infrastructure for production, quality assurance and characterisation

The AHCAL is probably the sub-detector with the largest number of individual components. While the number of electronics boards, layers and interfaces is similar to other ECAL or HCAL options, the large quantity of tiles and SiPMs deserves special attention. This affects production and quality assurance, but also characterisation, i.e. test bench measurements of parameters to be used later for calibration purposes.

While it would be premature to discuss building up full production infra-structure, conceptual solutions need to be developed and exercised using demonstrators, which could be seen as prototypes of future installations. The demonstration requires reasonably large samples of detector elements, in the order of 10000, as they would be needed for a next generation full prototype.

A semi-automatic test stand for SiPMs and tiles has been developed at Heidelberg and used for the elements of the early 2014 beam test. It needs to be adapted for future designs, e.g. with SiPMs integrated in the PCB.

Automatic assembly of HBUs (Mainz), i.e. of placing and soldering tiles and SiPMs on the PCB, needs to be demonstrated in practice, too. First encouraging tests with individual samples have been reported, but obviously only larger scale tests can validate the concept.

5. Absorber structure

The absorber structure bears more challenges than conventional hadronic calorimeters. Due to the much finer longitudinal segmentation and the imperative to minimise the total radius inside the coil, there are many active gaps with tight tolerances. A design has been developed and prototyped, which achieves the required tolerances with a cost-effective roller-levelling process without machining off excess material (DESY). Two test structures have been built; one covers the full transverse cross section of a barrel module, the other the full lateral extension. The cassettes (DESY, MPI Munich) housing the active elements have the final design and are used in beam tests.

These structures need to be investigated with respect to their robustness against earthquakes (DESY). Simulations of the whole ILD structure have been initiated, and measurements on the test structures exposed to accelerating forces should be done.

As enough active elements become available for instrumenting several active layers at full size, the thermal simulations should be verified with measurements, too.

4.5.4 Summary

The AHCAL effort has produced a number of significant results in the time since the ILC TDR:

- Publication of 3 journal papers and 3 preliminary results in the form of internally reviewed notes, on Geant 4 validation with pions and protons in steel and tungsten, including new observables like track segments
- Development, production and beam test of a new, simplified tile SiPM system without wave-length shifting fibres and improved sensor performance
- Test with electron beams of a small stack with second generation electronics and DAQ in a realistic absorber structure

The AHCAL is ready to make the next step towards a realistic full-scale prototype and a technical design report. In order to achieve this, coordinated R&D is required in the following areas:

Software and analysis:

- Completion of physics prototype test beam analysis
- 2nd generation prototype reconstruction and simulation software
- Development of timing reconstruction
- Analysis of 2nd generation test beam data

Tile SiPM system:

- Development of scintillator SiPM system with SiPM on the PCB
- Development of associated assembly, quality assurance and characterisation procedures
- Development of associated PCB

Electronics:

- 3rd generation ASIC of ROC family
- ASIC for larger range of SiPM gains
- PCB cost optimisation

System integration:

- Scalable DAQ
- Module level data collector
- Integration of DAQ and slow control into higher level system
- Implementation of temperature compensation scheme

- Power supply system
- Cooling system

Mass production concepts:

- Semi-automatic test stands
- Automatic placement and soldering of tiles and SiPMs

Absorber structure:

- Earthquake stability calculations and tests
- Thermal tests with full-scale instrumented and powered structures

There are ample opportunities for new groups to join into any of these fields, depending on the special competences they wish to contribute.

Particular engineering challenges are

- Assess and ensure earthquake stability of the absorber structure whilst maintaining a minimum of dead material
- Developing an active layer element consisting of tiles, SiPMs and readout electronics that can be automatically assembled, including production and quality assurance procedures

4.5.5 Engineering Challenges

4.5.6 Future Plans

Bibliography

- [1] Jason Abernathy, Klaus Dehmelt, Ralf Diener, Jan Engels, Jim Hunt, Martin Killenberg, T. Krautscheid, A. Munnich, Simone Zimmermann, Martin Ummenhofer, Adrian Vogel, and Peter Wienemann. Marlintpc: A common software framework for tpc development. In *Nuclear Science Symposium Conference Record, 2008. NSS '08. IEEE*, pages 1704–1708, Oct 2008.
- [2] C Adloff, J Blaha, M Chefdeville, A Dalmaz, C Drancourt, F Dulucq, A Espargilière, R Gaglione, N Geffroy, J Jacquemier, Y Karyotakis, G Martin-Chassard, J Prast, N Seguin-Moreau, Ch de La Taille, and G Vouters. Microroc: Micro-mesh gaseous structure read-out chip. *Journal of Instrumentation*, 7(01):C01029, 2012.
- [3] C. Adloff, K. Francis, J. Repond, J. Smith, D. Trojand, L. Xia, E. Baldolemar, J. Li, S.T. Park, M. Sosebee, A.P. White, J. Yu, Y. Mikami, N.K. Watson, G. Mavromanolakis, M.A. Thomson, D.R. Ward, W. Yan, D. Bencheckroun, A. Hoummada, Y. Khoulaki, M. Benyamna, C. Cârloganu, F. Fehr, P. Gay, S. Manen, L. Royer, G.C. Blazey, A. Dyshkant, V. Zutshi, J.-Y. Hostachy, L. Morin, U. Cornett, D. David, R. Fabbri, G. Falley, K. Gadow, E. Garutti, P. Göttlicher, C. Günter, S. Karstensen, F. Krivan, A.-I. Lucaci-Timoce, S. Lu, B. Lutz, I. Marchesini, N. Meyer, S. Morozov, V. Morgunov, M. Reinecke, F. Sefkow, P. Smirnov, M. Terwort, A. Vargas-Trevino, N. Wattimena, O. Wendt, N. Feege, J. Haller, S. Richter, J. Samson, P. Eckert, A. Kaplan, H.-Ch. Schultz-Coulon, W. Shen, R. Stamen, A. Tadday, B. Bilki, E. Norbeck, Y. Onel, K. Kawagoe, S. Uozumi, P.D. Dauncey, A.-M. Magnan, V. Bartsch, F. Salvatore, I. Laktineh, E. Calvo Alamillo, M.-C. Fouz, J. Puerta-Pelayo, A. Frey, C. Kiesling, F. Simon, J. Bonis, B. Bouquet, S. Callier, P. Cornebise, Ph. Doublet, F. Dulucq, M. Faucci Giannelli, J. Fleury, H. Li, G. Martin-Chassard, F. Richard, Ch. de la Taille, R. Pöschl, L. Raux, N. Seguin-Moreau, F. Wicek, M. Anduze, V. Boudry, J.-C. Brient, D. Jeans, P. Mora de Freitas, G. Musat, M. Reinhard, M. Ruan, H. Videau, M. Marcisovsky, P. Sicho, V. Vrba, J. Zalesak, B. Belhorma, and H. Ghazlane. Effects of high-energy particle showers on the embedded front-end electronics of an electromagnetic calorimeter for a future lepton collider. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 654(1):97 – 109, 2011.
- [4] O. Alonso, R. Casanova, A. Dieguez, J. Dingfelder, T. Hemperek, T. Kishishita, T. Kleinohl, M. Koch, H. Kruger, M. Lemarenko, F. Lutticke, C. Marinas,

- M. Schnell, N. Wermes, A. Campbell, T. Ferber, C. Kleinwort, C. Niebuhr, Y. Soloviev, M. Steder, R. Volkenborn, S. Yaschenko, P. Fischer, C. Kreidl, I. Peric, J. Knopf, M. Ritzert, E. Curras, A. Lopez-Virto, D. Moya, I. Vila, M. Boronat, D. Esperante, J. Fuster, I.G. Garcia, C. Lacasta, A. Oyanguren, P. Ruiz, G. Timon, M. Vos, T. Gessler, W. Kuhn, S. Lange, D. Munchow, B. Spruck, A. Frey, C. Geisler, B. Schwenker, F. Wilk, T. Barvich, M. Heck, S. Heindl, O. Lutz, T. Muller, C. Pulvermacher, H.J. Simonis, T. Weiler, T. Krausser, O. Lipsky, S. Rummel, J. Schieck, T. Schluter, K. Ackermann, L. Andricek, V. Chekelian, V. Chobanova, J. Dalseno, C. Kiesling, C. Koffmane, L.L. Gioi, A. Moll, H.G. Moser, F. Muller, E. Nedelkovska, J. Ninkovic, S. Petrovics, K. Prothmann, R. Richter, A. Ritter, M. Ritter, F. Simon, P. Vanhoefer, A. Wassatsch, Z. Dolezal, Z. Drasal, P. Kodys, P. Kvasnicka, and J. Scheirich. Depfet active pixel detectors for a future linear e^+e^- collider. *Nuclear Science, IEEE Transactions on*, 60(2):1457–1465, April 2013.
- [5] B Bilki, J Butler, T Cundiff, G Drake, W Haberichter, E Hazen, J Hoff, S Holm, A Kreps, E May, G Mavromanolakis, E Norbeck, D Northacker, Y Onel, J Repond, D Underwood, S Wu, and L Xia. Calibration of a digital hadron calorimeter with muons. *Journal of Instrumentation*, 3(05):P05001, 2008.
- [6] B Bilki, J Butler, G Mavromanolakis, E May, E Norbeck, J Repond, D Underwood, L Xia, and Q Zhang. Hadron showers in a digital hadron calorimeter. *Journal of Instrumentation*, 4(10):P10008, 2009.
- [7] B Bilki, J Butler, E May, G Mavromanolakis, E Norbeck, J Repond, D Underwood, L Xia, and Q Zhang. Measurement of positron showers with a digital hadron calorimeter. *Journal of Instrumentation*, 4(04):P04006, 2009.
- [8] B Bilki, J Butler, E May, G Mavromanolakis, E Norbeck, J Repond, D Underwood, L Xia, and Q Zhang. Measurement of the rate capability of resistive plate chambers. *Journal of Instrumentation*, 4(06):P06003, 2009.
- [9] C Brezina, K Desch, J Kaminski, M Killenberg, F Klöckner, T Krautscheid, U Renz, and M Schumacher. A time projection chamber with triple gem and pixel readout. *Journal of Instrumentation*, 4(11):P11015, 2009.
- [10] C. Brezina, K. Desch, J. Kaminski, M. Killenberg, and T. Krautscheid. Operation of a gem-tpc with pixel readout. *Nuclear Science, IEEE Transactions on*, 59(6):3221–3228, Dec 2012.
- [11] C. Brezina, Y. Fu, F. Zappon, M. van Beuzekom, M. Campbell, K. Desch, H. van der Graaf, V. Gromov, R. Kluit, X. Llopart, T. Poikela, and V. Zivkovic. Gossipo-4: Evaluation of a novel pll-based tdc-technique for the readout of gridpix-detectors, 2014.
- [12] S Callier, F Dulucq, C de La Taille, G Martin-Chassard, and N Seguin-Moreau. Skiroc2, front end chip designed to readout the electromagnetic calorimeter at the ilc. *Journal of Instrumentation*, 6(12):C12040, 2011.

- [13] Jerome K. Carman, Vitaliy Fadeyev, Khilesh Mistry, Richard Partridge, Bruce A. Schumm, Edwin Spencer, and Max Wilder. Longitudinal resistive charge division in multi-channel silicon strip sensors. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 646(1):118 – 125, 2011.
- [14] Kelsey Collier, Taylor Cunnington, Sean Crosby, Vitaliy Fadeyev, Forest Martinez-McKinney, Khilesh Mistry, Bruce A. Schumm, Edwin Spencer, Aaron Taylor, and Max Wilder. Microstrip electrode readout noise for load-dominated long shaping-time systems. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 729(0):127 – 132, 2013.
- [15] G. Deptuch, U. Heintz, M. Johnson, C. Kenney, R. Lipton, M. Narian, S. Parker, A. Shenai, L. Spiegel, J. Thom, and Z. Ye. 3D Technologies for Large Area Trackers. *ArXiv e-prints*, July 2013.
- [16] Grzegorz W. Deptuch, Gabriella Carini, Terence Collier, Pawel Gryboś, Piotr Kmon, et al. Results of Tests of Three-Dimensionally Integrated Chips Bonded to Sensors. *IEEE Trans.Nucl.Sci.*, 2013.
- [17] Gary Drake, José Repond, David Underwood, and Lei Xia. Resistive plate chambers for hadron calorimetry: Tests with analog readout. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 578(1):88 – 97, 2007.
- [18] F. Dulucq, C. De la Taille, G. Martin-Chassard, and N. Seguin-Moreau. Hardroc: Readout chip for calice/eudet digital hadronic calorimeter. In *Nuclear Science Symposium Conference Record (NSS/MIC)*, 2010 IEEE, pages 1678–1683, Oct 2010.
- [19] C. Adloff et al. Interactions of hadrons in the calice siw ecal prototype, 2011.
- [20] T. Frisson. Beam test performance of the skiroc2 asic, 2013.
- [21] Y Fu, C Brezina, K Desch, T Poikela, X Llopart, M Campbell, D Massimiliano, V Gromov, R Kluit, M van Beuzekom, F Zappon, and V Zivkovic. The charge pump pll clock generator designed for the 1.56 ns bin size time-to-digital converter pixel array of the timepix3 readout asic. *Journal of Instrumentation*, 9(01):C01052, 2014.
- [22] Shuhei Ito. R&d status of fpccd vertex detector, 2013.
- [23] J. Kaminski, Martin Killenberg, Andreas Bamberger, Hubert Blank, Christoph Brezina, K. Desch, T. Krautscheid, Walter Ockenfels, Uwe Renz, Martin Ummenhofer, Peter Wienemann, Simone Zimmermann, and A. Zwerger. Time projection chamber with triple gem and pixel readout. In *Nuclear Science Symposium Conference Record*, 2008. NSS '08. IEEE, pages 2926–2929, Oct 2008.

- [24] Jochen Kaminski, Christoph Brezina, Klaus Desch, Martin Killenberg, Frederik Klockner, et al. Time projection chamber with triple GEM and highly granulated pixel readout. *Conf.Proc.*, C0908171:533–535, 2009.
- [25] J Knopf, P Fischer, C Kreidl, and I Peric. A 256 channel 8-bit current digitizer asic for the belle-ii pxd. *Journal of Instrumentation*, 6(01):C01085, 2011.
- [26] W.J.C. Koppert, N. van Bakel, Y. Bilevych, P. Colas, K. Desch, M. Fransen, H. van der Graaf, F. Hartjes, N.P. Hessey, J. Kaminski, J. Schmitz, R. Schön, and F. Zappone. Gridpix detectors: Production and beam test results. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 732(0):245 – 249, 2013. Vienna Conference on Instrumentation 2013.
- [27] Hans Krüger. Front-end electronics for {DEPFET} pixel detectors at superbelle (belle ii). *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 617(1–3):337 – 341, 2010. 11th Pisa Meeting on Advanced Detectors Proceedings of the 11th Pisa Meeting on Advanced Detectors.
- [28] A Kruth, C Brezina, S Celik, V Gromov, R Kluit, F Zappone, K Desch, and H van der Graaf. Gossipo-3: measurements on the prototype of a read-out pixel chip for micro-pattern gaseous detectors. *Journal of Instrumentation*, 5(12):C12005, 2010.
- [29] M Lemarenko, M Havranek, T Hemperek, T Kishishita, H Krüger, and N Werme. The data handling processor for the belle ii pixel vertex detector: efficiency optimization. *Journal of Instrumentation*, 7(01):C01069, 2012.
- [30] R Lipton, G Deptuch, U Heintz, M Johnson, C Kenney, M Narian, S Parker, I Planell-Mendez, E Sawyer, A Shenai, L Spiegel, J Thom, and Z Ye. Combining the two 3ds. *Journal of Instrumentation*, 7(12):C12010, 2012.
- [31] S Conforti Di Lorenzo, S Callier, J Fleury, F Dulucq, C De la Taille, G Martin Chassard, L Raux, and N Seguin-Moreau. Spiroc: design and performances of a dedicated very front-end electronics for an ilc analog hadronic calorimeter (ahcal) prototype with sipm read-out. *Journal of Instrumentation*, 8(01):C01027, 2013.
- [32] M Lupberger. The pixel-tpc: first results from an 8-ingrid module. *Journal of Instrumentation*, 9(01):C01033, 2014.
- [33] P. Maj, G. Carini, G. Deptuch, P. Grybos, P. Kmon, et al. Tests of the First Three-Dimensionally Integrated Chip for Photon Science. *PoS, Vertex2012*:027, 2013.
- [34] I. Peric, T. Armbruster, M. Koch, C. Kreidl, and P. Fischer. Dcd: The multi-channel current-mode adc chip for the readout of depfet pixel detectors. *Nuclear Science, IEEE Transactions on*, 57(2):743–753, April 2010.
- [35] R. PÖSCHL. Construction and test of a large scale prototype of a silicon tungsten electromagnetic calorimeter for a future lepton collider.

