

Totally Integrated Automation Portal

Main [OB1]

Main Properties

General

Name	Main	Number	1	Type	OB	Language	LAD
Numbering	Automatic						

Information

Title	"Main Program Sweep (Cycle)"	Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Default value	Comment
▼ Input			
Initial_Call	Bool		Initial call of this OB
Remanence	Bool		=True, if remanent data are available
Temp			
Constant			

Network 1: Envio para 1200

%I54.0

"emb_f1 (NC)_ET200L"

%Q46.0

"emb_f1 (NC) 1200"

Network 2:

%I54.1

"emb_f2 (NC)_ET200L"

%Q46.1

"emb_f2 (NC) 1200"

Network 3:

%I54.2

"etq_s (NC)_ET200L"

%Q46.2

"etq_s (NC) 1200"

Network 4:

MOVE

EN — ENO

%MW200

"emb_nivel"

IN

OUT1

%QW48

"emb_nivel 1200"

Network 5:

MOVE

EN — ENO

%MW202

"etq_temp"

IN

OUT1

%QW50

"etq_temp 1200"

Network 6: Receção do 1200

%I46.0

"Emb_Falha 1200"

%Q54.0

"Emb_Falha ET200L"

Network 7:

