

| Room Name | 1 Bed Room - CCU, 20m2 | Room Number 1BR-SP-B | | | | |
|---------------------------------------|---|--|--|--|--|--|
| Revision | 3 | | | | | |
| Issue Date | 20.03.17 | | | | | |
| BRIEFING | | | | | | |
| Briefed Area | 20.00 m ² | | | | | |
| Hours of Operation | 24 Hours | | | | | |
| Occupancy | 1 patient; 1-2 visitors, 1-2 staff intermittently | | | | | |
| Acoustics | Acoustic privacy is required | | | | | |
| Remarks | | | | | | |
| Description / Special Requirements | A 1 Bed Room - Special, Coronary Care will accommodate one patient for the delivery of cardiac care treatment. Glazed doors and partition walls are recommended for patient visibility and privacy. Natural light and outlook is essential; the room requires the ability to view out of the window from either the chair or bed. | | | | | |
| SERVICES | | | | | | |
| General Requirements | BODY PROTECTED = No | CARDIAC PROTECTED = Yes | | | | |
| Air | AIRCONDITIONING = Yes | AIRCONDITIONING: hepa filtered = No | | | | |
| | AIRCONDITIONING: positive pressure = No | AIRCONDITIONING: negative pressure = No | | | | |
| | EXHAUST: room exhaust = No | VENTILATION = No | | | | |
| Lighting | LIGHTING: colour corrected = Yes | LIGHTING: dimmable = No | | | | |
| | LIGHTING: downlights = No | LIGHTING: downlights, dimmable = No | | | | |
| | LIGHTING: fluorescent, downlights = No | LIGHTING: fluorescent, flush with ceiling, tamper proof = No | | | | |
| | LIGHTING: fluorescent, general = No | LIGHTING: indirect = No | | | | |
| Nurse Call | NURSE CALL SYSTEM = No | | | | | |

Room Fabrics

| AusHFG code | Description | Comment |
|-------------|--|--|
| CLFS-006 | CEILING: plasterboard, flush set, suspended, paint, washable | |
| CLCN-002 | CORNICE: aluminium, 24mm shadow angle, powdercoat | |
| DWGL-033 | DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint | latch set with hold open device; observation panel optional. |
| DWPR-006 | DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished | Equal to 'Acrovyn' |
| DWPR-010 | DOOR PROTECTION: to door frame, PVC, prefinished | Equal to 'Acrovyn' |
| FLVY-006 | FLOOR FINISH: vinyl, seamless, coved, non slip, textured | under basin |
| FLVY-007 | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant | carpet also acceptable |
| DWOB-003 | OBSERVATION: internal window, alum/glass, double glazed, integral venetian blind, powdercoat | |
| FLSK-010 | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished | feather edge vinyl skirting if carpeted |
| WLWA-004 | WALL FINISH: paint, acrylic, washable | |
| WLWA-010 | WALL FINISH: splashback, vinyl | to basin |
| WLPR-002 | WALL PROTECTION: bed protection wall panel, composite, laminate finish | |
| WLPR-012 | WALL PROTECTION: corner guards, to 900 AFFL, prefinished PVC | Equal to 'Acrovyn' |
| DWWH-005 | WINDOW | Natural light & outlook essential. |

Fittings, Furniture and Equipment (FF&E) Items



Page: 1 Print Date: 20/03/2017





Room Name

1 Bed Room - CCU, 20m2

Room Number 1BR-SP-B

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---|-------|-----|--------------------------------|
| MMGE-002 | ADAPTER: suction | 3 | 2 | |
| HYBA-010 | BASIN: handwash, Type B | 1 | 1 | Refer to BHWS-B (similar) |
| MMBE-010 | BED: patient, electric with mattress | 3 | 1 | |
| FQCW-016 | BIN: waste, general, 20L | 3 | 1 | to basin |
| DWWD-007 | BLIND: venetian, integral | 1 | 1 | to internal observation window |
| FIHR-004 | BRACKET: for display screen, ceiling mounted | 1 | 1 | |
| FIHR-013 | BRACKET: for monitor, ECG | 3 | 1 | |
| FIHR-019 | BRACKET: for suction bottle | 2 | 2 | |
| MMGE-019 | CHAIR: patient | 3 | 1 | |
| FQBS-030 | CHAIR: visitor, patient | 3 | 1 | |
| FIJO-130 | CUPBOARD: tall, single door, adj shelves and clothes rail | 1 | 1 | |
| FQGE-009 | CURTAIN: bed screen | 3 | 1 | |
| DWWD-011 | CURTAIN: window, drapes | 3 | 1 | set |
| FIDI-014 | DISPENSER: disposable glove | 2 | 1 | near basin |
| FIDI-025 | DISPENSER: paper/hand towel | 2 | 1 | to basin |
| FIDI-030 | DISPENSER: soap | 2 | 1 | to basin |
| FIDI-031 | DISPENSER: soap antiseptic | 2 | 1 | to basin |
| ITBU-012 | DISPLAY SCREEN: patient entertainment system | 1 | 1 | |
| MGFP-002 | FLOWMETER: medical air | 3 | 1 | |
| MGFP-004 | FLOWMETER: oxygen | 3 | 2 | |
| FQSN-051 | LOCKER: 2 drawers, open under, lockable, mobile | 3 | 1 | |
| MMHA-005 | MONITOR: patient, cardiac | 3 | 1 | may be telemetry |
| FIJO-193 | SHELF: flowers | 1 | 1 | |
| MMGE-100 | SUCTION BOTTLE | 3 | 2 | |
| FQTA-013 | TABLE: overbed | 3 | 1 | |
| HYTP-037 | TAPWARE: mixer, elbow levers | 1 | 1 | |
| ITNE-049 | TELEPHONE: handset, desktop | 3 | 1 | |
| FIRT-021 | TRACK: curtain, bedscreen | 1 | 1 | |
| FIRT-027 | TRACK: curtain, box pelmet | 1 | 1 | |

Engineering Services

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---|-------|-----|---|
| ITCL-004 | BUTTON: nurse call, emergency | 1 | 1 | on services panel, + indicator button & light |
| ITCL-006 | BUTTON: nurse call, patient to staff | 1 | 1 | on services panel, + indicator button & light+ indicator button & light |
| ITCL-008 | BUTTON: nurse call, staff assist | 1 | 1 | on services panel, + indicator button & light+ indicator button & light |
| ELGP-206 | GPO: double, on services panel, RCD protected | 1 | 1 | |

AHHA
assratission health infrastructure alliance
opposition or a statut part valve to the control of the contro

Page: 2 Print Date: 20/03/2017





Room Name

1 Bed Room - CCU, 20m2

Room Number 1BR-SP-B

| AusHFG code | Description | Group | Qty | Comment |
|-------------|--|-------|-----|--|
| ELGP-122 | GPO: emergency power, single, on services panel | 1 | 8 | on services panel |
| ELGP-101 | GPO: single, ceiling mounted | 1 | 1 | for ceiling mounted display screen |
| ELGP-109 | GPO: single, wall mounted | 1 | 1 | bedhead low level, for electric bed |
| ELGP-109 | GPO: single, wall mounted | 1 | 1 | adjacent to patient chair |
| ELGP-110 | GPO: single, wall mounted, cleaner | 1 | 1 | |
| ITCL-028 | HANDSET: nurse call, with patient to staff call button | 1 | 1 | on services panel, with light switch |
| LIFX-017 | LIGHT: night light | 1 | 1 | |
| LIFX-011 | LIGHT: reading light | 1 | 1 | up/down light |
| ITIN-025 | OUTLET: data, double RJ45, on services panel | 1 | 1 | on services panel |
| ITIN-016 | OUTLET: data, single RJ45, wall mounted | 1 | 1 | optional, for monitor communications with associated cabling and connections; verify outlet type/s with monitor selected |
| ITIN-070 | OUTLET: MATV | 1 | 1 | |
| MGAS-022 | OUTLET: medical air (MA), on services panel | 1 | 1 | on services panel |
| MGAS-042 | OUTLET: oxygen (O2), on services panel | 1 | 2 | on services panel |
| MGAS-062 | OUTLET: suction, on services panel | 1 | 2 | on services panel |
| MMSP-026 | SERVICES PANEL: wall mounted | 2 | 1 | |
| ELBO-015 | SWITCH: light, single | 1 | 4 | on service panel (1 no,) |

AHHA