

National foreword

This British Standard is the UK implementation of EN 60085:2008. It is identical to IEC 60085:2007. It supersedes BS EN 60085:2004 and BS EN 62114:2001, which are withdrawn.

The UK participation in its preparation was entrusted to Technical Committee GEL/112, Evaluation and qualification of electrical insulating materials and systems.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© BSI 2009

ISBN 978 0 580 56610 3

ICS 17.220.99; 29.035.01

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 March 2009.

Amendments issued since publication

Amd. No.	Date	Text affected
----------	------	---------------

English version

**Electrical insulation -
Thermal evaluation and designation
(IEC 60085:2007)**

Isolation électrique -
Evaluation et désignation thermiques
(CEI 60085:2007)

Elektrische Isolierung -
Thermische Bewertung und Bezeichnung
(IEC 60085:2007)

This European Standard was approved by CENELEC on 2007-12-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

Foreword

The text of document 112/74/FDIS, future edition 4 of IEC 60085, prepared by IEC TC 112, Evaluation and qualification of electrical insulating materials and systems, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60085 on 2007-12-01.

This European Standard supersedes EN 60085:2004 and EN 62114:2001.

The major technical changes with regard to EN 60085:2004 concern the fact that EN 60085:2008 is an amalgamation of EN 60085:2004 together with EN 62114:2001.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2008-09-01 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn | (dow) | 2010-12-01 |

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60085:2007 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 60216-6	NOTE Harmonized as EN 60216-6:2006 (not modified).
-------------	--

www.docin.com

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60216-1	⁻¹⁾	Electrical insulating materials - Properties of thermal endurance - Part 1: Ageing procedures and evaluation of test results	EN 60216-1	2001 ²⁾
IEC 60216-5	⁻¹⁾	Electrical insulating materials - Thermal endurance properties - Part 5: Determination of relative thermal endurance index (RTE) of an insulating material	EN 60216-5	2003 ²⁾
IEC 60505	⁻¹⁾	Evaluation and qualification of electrical insulation systems	EN 60505	2004 ²⁾
IEC 61857	Series	Electrical insulation systems - Procedures for thermal evaluation	EN 61857	Series
IEC 61858	⁻¹⁾	Electrical insulation systems - Thermal evaluation of modifications to an established wire-wound EIS	EN 61858	2005 ²⁾

www.docin.com

ELECTRICAL INSULATION – THERMAL EVALUATION AND DESIGNATION

1 Scope

This International Standard now distinguishes between thermal classes for electrical insulation systems and electrical insulating materials. It establishes the criteria for evaluating the thermal endurance of either electrical insulating materials (EIM) or electrical insulation systems (EIS). It also establishes the procedure for assigning thermal classes.

This standard is applicable where the thermal factor is the dominant ageing factor.

NOTE A thermal class is not assigned to an EIM as related to its use in an EIS

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60216-1: *Electrical insulating materials – Properties of thermal endurance – Part 1: Ageing procedures and evaluation of test results*

IEC 60216-5, *Electrical insulating materials – Thermal endurance properties – Part 5: Determination of relative thermal endurance index (RTE) of an insulating material*

IEC 60505: *Evaluation and qualification of electrical insulation systems*

IEC 61857 (all parts), *Electrical insulation systems – Procedures for thermal evaluation*

IEC 61858, *Electrical insulation systems – Thermal evaluation of modifications to an established wire-wound EIS*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60505, as well as the following, apply.

3.1

electrical insulating material (EIM)

solid or fluid with negligibly low electric conductivity, or a simple combination of such materials, used to separate conducting parts at different electrical potential in electrotechnical devices

NOTE 1 A "simple combination" may be a combination of EIM delivered in a joint state, for example, a flexible material consisting of a paper laminated on polyethylene terephthalate film.

NOTE 2 For testing purposes, electrodes may be applied on material specimens without this combination formally constituting an EIS to be tested as such.

3.2

electrical insulation system (EIS)

insulating structure containing one or more EIM together with associated conducting parts employed in an electrotechnical device

3.3

candidate EIM

EIM under evaluation to determine its estimated thermal endurance

3.4

reference EIM

material with known thermal endurance, preferably derived from service experience, used for comparative tests with the candidate EIM

3.5

candidate EIS

EIS under evaluation to determine its service capability (thermal)

3.6

reference EIS

established EIS evaluated on the basis of either a known service experience record or a known comparative functional evaluation

3.7

EIM assessed thermal endurance index (EIM ATE)

numerical value of the temperature in degrees Celsius, up to which the reference EIM possesses known, satisfactory service experience in the specified application

3.8

EIM relative thermal endurance index (EIM RTE)

numerical value of the temperature in degrees Celsius at which the estimated time to endpoint of the candidate EIM is the same as the estimated time to endpoint of the reference EIM at a temperature equal to its EIM ATE

3.9

EIS assessed thermal endurance index (EIS ATE)

numerical value of the temperature in degrees Celsius for the reference EIS as derived from known service experience or a known comparative functional evaluation

3.10

EIS relative thermal endurance index (EIS RTE)

numerical value of the temperature in degrees Celsius for the candidate EIS which is relative to the known EIS ATE of a reference EIS, when both EIS are subjected to the same ageing and diagnostic procedures in a comparative test

3.11

thermal class

designation that is equal to the numerical value of the recommended maximum continuous use temperature in degrees Celsius

NOTE 2 EIM with different thermal endurance indices (ATE/RTE according to IEC 60216-5) may be combined to form an EIS which has a thermal class that may be higher or lower than the recommended maximum continuous use temperature of any of the individual components according to IEC 60505.

4 General considerations – Relation of EIM to EIS

The description of an electrotechnical device as being of a particular thermal class does not mean, and must not be taken to imply, that each EIM used in its construction is of the same thermal endurance.

The thermal class for an EIS may not be directly related to the thermal endurance of the individual EIM included in it. In the EIS, the protective character of other EIM used in the system may improve the performance of an individual EIM allowing its use in an EIS with a thermal class greater than the thermal endurance of the individual EIM. On the other hand, problems of incompatibility between EIM may decrease the appropriate thermal class of the system below the thermal endurance of the EIM. Therefore, the thermal capabilities of an EIM shall not be deduced from the thermal class of an EIS of which it is a component

4.1 Maximum use temperature

The thermal classes in this standard are numerically equal to the maximum temperature recommended for the EIS under normal operating conditions as defined by the product technical committee.

Product TCs shall determine the operating conditions under which the maximum temperature of the device may differ from the thermal class of the EIS. Such situations may occur because either a shorter or longer life than normal is envisaged, or exceptional conditions of service exist.

4.2 Other factors of influence

Apart from thermal factors, the ability of the EIS to fulfil its function is affected by many factors, such as electrical and mechanical stresses, vibration, deleterious atmospheres and chemicals, moisture, dirt and radiation. All such factors should be taken into account when designing particular electrotechnical devices and further guidance on the evaluation of these aspects may be found in IEC 60505.

4.3 Thermal evaluation of EIM

Insulating materials and simple combinations of insulating materials shall follow the precepts set forth in IEC 60216-1 and be evaluated in accordance with IEC 60216-5 and refer to expected service conditions.

4.4 Thermal evaluation of EIS

Experience has demonstrated that, under normal operating conditions, satisfactory economic life is obtained for many electrotechnical devices such as rotating machines, transformers, etc., that are designed and built in accordance with standards based on thermal evaluations of EIS.

Test procedures for the thermal evaluation of EIS shall follow the precepts set forth in IEC 60505. Specific test procedures for EIS intended for use in low-voltage devices are listed in IEC 61857 and IEC 61858.

5 Thermal class

Since the temperature in electrotechnical devices is very often the dominant ageing factor affecting the EIM in the EIS, certain basic thermal classes are useful and have been recognized as such internationally. Where a thermal class is specified for an EIS, this means

the recommended maximum continuous use temperature in degrees Celsius for which that combination of EIM is appropriate.

Thermal classes shall be assigned to an EIS based on service experience or on the results of functional tests based upon test procedures in accordance with 4.4. Thermal classes are assigned to an EIS based on the EIS ATE or EIS RTE.

While a thermal class may be applied to an EIM based on service experience or on the results of testing in accordance with 4.3, this does not automatically imply that it is suitable for use in an EIS of that thermal class, or that the thermal class of an EIS in which it is a part is the same as for that EIM.

Designations for the thermal classes of are as follows:

Table 1 – Thermal class assignment

ATE or RTE °C		Thermal class °C	Letter designation ^a
≥90	<105	90	Y
≥105	<120	105	A
≥120	<130	120	E
≥130	<155	130	B
≥155	<180	155	F
≥180	<200	180	H
≥200	<220	200	N
≥220	<250	220	R
≥250 ^b	<275	250	-

^a If desired, the letter designation may be added in parentheses, e.g. Class 180 (H). Where space is a factor, such as on a nameplate, the product TC may elect to use only the letter designation.

^b Designations of thermal classes over 250 shall increase by increments of 25 and be designated accordingly.

Bibliography

IEC 60216-6, *Electrical insulating materials – Thermal endurance properties – Part 6: Determination of thermal endurance indices (TI and RTE) of an insulating material using the fixed time frame method*

IEC 62101/TS, *Electrical insulation systems – Short-time evaluation of combined thermal and electrical stresses*
