Optimal Arbitrage of Networked Energy Storage

Challenge Specification for TIG

The CEL Team

January 18, 2026

Abstract

This document specifies a single challenge level for TIG: optimal dispatch of a portfolio of batteries located on a transmission-constrained network. The solver must choose charge/discharge actions over a finite horizon to maximize realized profit at real-time nodal prices while respecting battery physics and DC power flow line limits. To ensure "hard-to-solve, easy-to-verify" structure and to prevent lookahead exploitation, the real-time price process is generated sequentially from a cryptographic commitment that depends on the solver's past actions. The instance generator exposes tunable difficulty parameters (network scale, congestion tightness, portfolio heterogeneity, volatility, and tail risk), and TIG runs five tracks with fixed parameter regimes.

1 Introduction

Storage arbitrage in electricity markets is fundamentally a spatiotemporal control problem. Temporal opportunity arises from intraday price volatility; spatial opportunity arises because nodal prices diverge when the transmission network becomes congested. A portfolio operator can profit by coordinating batteries across locations and time, but the optimization is complicated by coupling constraints (line limits) and by uncertainty in real-time prices.

The present challenge isolates the computational core in a form suitable for TIG. The solver is given an instance consisting of a transmission network, exogenous nodal injections, a day-ahead price forecast surface, and a portfolio of batteries placed at nodes. The solver must output a battery dispatch schedule. Profit is evaluated at real-time nodal prices that are revealed sequentially. To remove trivial strategies based on precomputing the entire future price path, the distribution of future real-time prices is made dependent on the solver's committed past actions via a hash-based mechanism. Verification recomputes prices, states, flows, and profit deterministically in time linear in the horizon and near-linear in network size.

2 Problem overview and timing

Time is discretized into H steps of duration Δt hours, indexed by $t \in \{0, 1, \ldots, H-1\}$. The solver knows the full instance at $t = 0$, including the day-ahead price surface and all exogenous injections for the full horizon. The solver also receives the initial real-time nodal price vector $\lambda^{\mathrm{RT}}_{\cdot,0}$, generated deterministically from the instance seed. At each step t, the solver selects battery actions $u_{\cdot,t}$ after observing the current state of charge and the current real-time nodal prices. After the action is committed, the environment updates battery states, checks feasibility of line flows, updates the commitment seed, and generates $\lambda^{\mathrm{RT}}_{\cdot,t+1}$. Consequently, $\lambda^{\mathrm{RT}}_{\cdot,t+1}$ is not knowable at time t without committing to $u_{\cdot,t}$.

3 Mathematical specification

3.1 Sets, indices, and instance data

Let $\mathcal{N} = \{1, \ldots, n\}$ be the set of nodes, $\mathcal{L} = \{1, \ldots, L\}$ the set of transmission lines, and $\mathcal{B} = \{1, \ldots, m\}$ the set of batteries. Each battery b is located at node $\nu(b) \in \mathcal{N}$. The instance provides (i) a PTDF matrix $\mathrm{PTDF} \in \mathbb{R}^{L \times n}$ associated with a designated slack bus $s \in \mathcal{N}$, (ii) nominal line limits $\overline{F}_\ell^{\mathrm{nom}}$ and a congestion scaling factor γ_{cong} defining effective limits $\overline{F}_\ell := \gamma_{\mathrm{cong}} \overline{F}_\ell^{\mathrm{nom}}$, (iii) exogenous nodal injections $p_{i,t}^{\mathrm{exo}}$ (generation minus load) for all i, t, (iv) a day-ahead nodal price forecast $\lambda_{i,t}^{\mathrm{DA}}$ for all i, t, (v) battery parameters, initial states of charge, and (vi) an initial commitment seed $s_0 \in \{0, 1\}^{256}$.

3.2 Battery actions, derived charge/discharge, and SOC dynamics

To make the action space unambiguous and to avoid explicit charge/discharge complementarity constraints, the solver controls each battery with a signed power decision

$$u_{b,t} \in [-\overline{P}_b^c, \overline{P}_b^d],$$

where $u_{b,t} > 0$ corresponds to discharge (net injection) and $u_{b,t} < 0$ corresponds to charge (net withdrawal). We define the induced nonnegative charge and discharge powers by

$$c_{b,t} := (-u_{b,t})_+, \qquad d_{b,t} := (u_{b,t})_+,$$

where $(x)_+ := \max\{x, 0\}$. Let $E_{b,t}$ denote the state of charge (MWh). SOC evolves as

$$E_{b,t+1} = E_{b,t} + \eta_b^c \, c_{b,t} \, \Delta t - \frac{d_{b,t} \, \Delta t}{\eta_b^d}, \tag{1}$$

and must satisfy bounds $\underline{E}_b \leq E_{b,t} \leq \overline{E}_b$ for all t. (Default fractional bounds and initial SOC are fixed in Appendix A, unless overridden.)

3.3 Nodal injections, slack balancing, and DC line flows

Storage injection at node i is the sum of signed battery powers located at i:

$$p_{i,t}^{\mathrm{stor}} = \sum_{b : \nu(b) = i} u_{b,t}.$$

Total injection is

$$p_{i,t} = p_{i,t}^{\mathrm{exo}} + p_{i,t}^{\mathrm{stor}}.$$

To enforce power balance in a verifier-friendly way, the slack bus injection is defined endogenously each period by

$$p_{s,t} := -\sum_{i \in \mathcal{N} \setminus \{s\}} p_{i,t},$$

and $p_{i,t}$ for $i \neq s$ is as above. This formulation enforces the global balance constraint: at each moment, total power injected into the network must equal total power withdrawn. Rather than checking balance as a constraint, we *define* the slack bus injection to absorb whatever imbalance exists among the other nodes, guaranteeing balance by construction. Given $p_{\cdot,t}$, line flows are computed using the PTDF mapping

$$f_{\ell,t} = \sum_{k \in \mathcal{N}} \mathrm{PTDF}_{\ell k} \, p_{k,t}. \tag{2}$$

Thermal limits must hold at all times:

$$|f_{\ell,t}| \leq \overline{F}_\ell \qquad \forall \ell \in \mathcal{L}, \ \forall t. \tag{3}$$

3.4 Action-committed real-time price generation

Real-time nodal prices are generated sequentially via a commitment scheme that depends on the solver's past actions and states. This is the mechanism that prevents precomputing a future price path without committing to actions.

Quantization for hashing. Submitted actions and SOC values are quantized to fixed-point integers before hashing:

$$\tilde{u}_{b,t} = \mathrm{round}\left(\frac{u_{b,t}}{q_u}\right) \in \mathbb{Z}, \qquad \tilde{E}_{b,t} = \mathrm{round}\left(\frac{E_{b,t}}{q_E}\right) \in \mathbb{Z},$$

with default quantization steps q_u and q_E specified in Appendix A. The verifier uses the quantized integers in the commitment function irrespective of how the solver computes internally.

Seed update. Let $\mathcal{H}$ be SHA-256. The seed evolves by

$$s_{t+1} = \mathcal{H}\Big(s_t \,\|\, t \,\|\, (\tilde{u}_{1,t}, \ldots, \tilde{u}_{m,t}) \,\|\, (\tilde{E}_{1,t}, \ldots, \tilde{E}_{m,t})\Big), \tag{4}$$

where concatenation uses a canonical byte encoding: big-endian signed 64-bit integers in the natural order of indices (Appendix A). This makes the commitment deterministic and language-agnostic.

Deterministic PRNG from seed. All pseudo-random draws at time t are derived from s_t using hash-in-counter-mode. For integer counter $j \geq 0$, define

$$W_j = \mathcal{H}(s_t \,\|\, j), \qquad U_j = \frac{\mathrm{uint64}(W_j)}{2^{64}} \in [0, 1),$$

where $\mathrm{uint64}(\cdot)$ takes the first eight bytes of W_j as an unsigned 64-bit integer. Standard normals are generated deterministically from the U_j stream using Box–Muller (or an equivalent transform fixed in the reference implementation).

Spatially correlated shocks. At each time t, define a common factor $z_t \sim \mathcal{N}(0, 1)$ and i.i.d. idiosyncratic node shocks $\varepsilon_{i,t} \sim \mathcal{N}(0, 1)$. With spatial correlation parameter $\rho_{\mathrm{sp}} \in [0, 1]$, set

$$\xi_{i,t} = \sqrt{\rho_{\mathrm{sp}}}\, z_t + \sqrt{1 - \rho_{\mathrm{sp}}}\, \varepsilon_{i,t}.$$

This construction ensures that $\mathrm{Corr}(\xi_{i,t}, \xi_{j,t}) = \rho_{\mathrm{sp}}$ for any pair of nodes $i \neq j$, while each $\xi_{i,t}$ remains a standard normal. The parameter ρ_{sp} thus directly controls the degree to which price shocks are system-wide versus node-specific.

Endogenous congestion indicator (lagged to avoid circularity). Prices at time t include a congestion premium based on whether congestion occurred at the previous dispatch. Define $\mathbf{1}^{\mathrm{cong}}_{i,0} := 0$. For $t \geq 0$, define $\mathbf{1}^{\mathrm{cong}}_{i,t+1}$ from flows at time t by

$$\mathbf{1}^{\mathrm{cong}}_{i,t+1} = \mathbf{1}\Big\{\exists \ell \text{ incident to node } i : \; |f_{\ell,t}| \geq \tau_{\mathrm{cong}} \overline{F}_\ell\Big\},$$

where $\tau_{\mathrm{cong}} \in (0, 1)$ is a fixed proximity threshold. This construction ensures that the price used to settle action $u_{\cdot,t}$ is known before choosing $u_{\cdot,t}$, while the next-step price depends on the committed action through the induced flows.

Jump (scarcity) component. This component models scarcity events—sudden, large price spikes that occur when supply is tight or unexpected outages occur. Independently for each node-time pair, with probability ρ_{jump} draw $Z \sim \text{Pareto}(\alpha)$ (support $[1, \infty)$) and set $J_{i,t} := \lambda^{\text{DA}}_{i,t} \cdot Z$; otherwise set $J_{i,t} := 0$. The parameter ρ_{jump} controls the frequency of these events, while $\alpha > 2$ controls tail heaviness (smaller α yields more extreme spikes).

Real-time nodal price. Let $\zeta_t := \max\{0, z'_t\}$ where $z'_t \sim \mathcal{N}(0, 1)$ is an additional factor draw from the same PRNG stream. The real-time LMP is defined by

$$\lambda^{\text{RT}}_{i,t} = \text{clip}\Big(\lambda^{\text{DA}}_{i,t} \cdot \big(1 + \mu + \sigma\, \xi_{i,t}\big) + \gamma_{\text{price}} \cdot \mathbf{1}^{\text{cong}}_{i,t} \cdot \zeta_t + J_{i,t},\ \lambda_{\min},\ \lambda_{\max}\Big), \tag{5}$$

where μ is a deterministic bias, $\sigma > 0$ is volatility, $\gamma_{\text{price}} > 0$ is the congestion premium scale, and $\text{clip}(x, a, b) = \min\{\max\{x, a\}, b\}$. Default values and track overrides are given in Appendix A and Appendix B.

Remark 1. *The commitment enters through s_{t+1} in (4). Since s_{t+1} depends on the entire action vector $u_{\cdot,t}$ (quantized), the joint law of future prices depends on the solver's committed actions. This eliminates offline enumeration of future prices without committing to a specific trajectory, while keeping verification a deterministic replay.*

Role of frictions. Without friction terms, the optimal strategy would exploit arbitrarily small price differences by charging and discharging constantly, cycling batteries at unrealistically high rates. The friction function $\phi_b(\cdot)$ penalizes such behavior, ensuring that only sufficiently large price spreads justify action and that battery usage remains physically plausible.

3.5 Profit, frictions, and objective

Settlements use the nodal real-time price at the battery's node. The per-period portfolio profit is

$$R_t = \sum_{b \in \mathcal{B}} u_{b,t}\, \lambda^{\text{RT}}_{\nu(b),t}\, \Delta t - \sum_{b \in \mathcal{B}} \phi_b(u_{b,t}), \tag{6}$$

where frictions are modeled as

$$\phi_b(u) = \kappa_{\text{tx},b}\, |u|\, \Delta t + \kappa_{\text{deg},b} \left(\frac{|u| \Delta t}{\overline{E}_b} \right)^{\beta_b}. \tag{7}$$

The first term is a *transaction cost* proportional to energy throughput, representing market fees, bid–ask spreads, or other per-MWh charges. The second term is a *degradation cost* that penalizes deep cycling: the exponent $\beta_b > 1$ makes the marginal cost of cycling increase with intensity, discouraging aggressive charge/discharge patterns that accelerate battery wear.

The TIG score for an instance is the total realized profit $\sum_{t=0}^{H-1} R_t$ provided all constraints are satisfied. If any constraint in (1) or (3) is violated at any time (beyond numerical tolerances specified in Appendix A), the submission is invalid for that instance.

4 Difficulty parameters and TIG track design

The challenge has two distinct sources of hardness: coupled feasibility under network constraints, and sequential decision-making under action-committed stochastic prices. Network coupling is primarily controlled by (n, L) and the tightness scaling γ_{cong}; portfolio complexity is controlled by m and heterogeneity h (dispersion of battery parameters); uncertainty is controlled by volatility σ and jump tail parameters $(\rho_{\text{jump}}, \alpha)$. TIG runs five tracks, each fixing a parameter regime.

The five tracks need not form a strict ladder of computational difficulty; rather, they are designed to induce qualitatively different algorithmic regimes, encouraging solvers to develop flexible approaches that can adapt to varying conditions. Early tracks are correctness-oriented and only mildly congested, while later tracks feature frequent congestion, heavier tails, longer horizons, and materially heterogeneous fleets. This diversity tests whether algorithms can balance feasibility management, risk control, and spatiotemporal coordination across a range of scenarios.

5 Verification protocol

A verifier is given the full instance data, the initial seed s_0, and the submitted action array $\{u_{b,t}\}$. Verification proceeds deterministically as follows. At $t = 0$, the verifier initializes SOCs at the specified $E_{b,0}$ and computes $\lambda^{\mathrm{RT}}_{\cdot,0}$ from s_0 using (5) with $\mathbf{1}^{\mathrm{cong}}_{\cdot,0} = 0$. For each $t = 0, 1, \ldots, H-1$, it (i) quantizes $u_{b,t}$ and $E_{b,t}$, (ii) updates SOCs via (1) and checks SOC bounds, (iii) computes $p_{\cdot,t}$ including slack balancing and then flows $f_{\cdot,t}$ via (2), checking (3), (iv) computes the period profit R_t via (6)–(7), (v) forms $\mathbf{1}^{\mathrm{cong}}_{\cdot,t+1}$ from $f_{\cdot,t}$, (vi) updates s_{t+1} via (4), and (vii) generates $\lambda^{\mathrm{RT}}_{\cdot,t+1}$ via (5). The reported score is the sum of verified profits. Computational cost is $O(H \cdot (Ln + m))$ operations with small constants; no optimization is performed during verification.

6 Instance generation (reference design)

Instances are generated from a single master seed and track parameters. This section provides the detailed algorithms used in the reference implementation.

6.1 Network topology and PTDF matrix

The generator first produces a connected network graph with n nodes and L lines. Connectivity is ensured by building a spanning tree (selecting $n-1$ edges to connect all nodes), then adding $L-(n-1)$ additional edges uniformly at random among non-existing pairs. Each line ℓ connecting nodes i and j is assigned a susceptance $b_\ell = b_{\mathrm{base}} \cdot (0.8 + 0.4\, r_\ell)$ where $r_\ell \sim \mathrm{Uniform}(0,1)$ and $b_{\mathrm{base}} = 10$. Nominal flow limits are similarly perturbed: $\overline{F}^{\mathrm{nom}}_\ell = \overline{F}_{\mathrm{base}} \cdot (0.8 + 0.4\, r'_\ell)$ with $\overline{F}_{\mathrm{base}} = 100$ MW.

The PTDF matrix is constructed via the standard DC power flow derivation:

1. **Build the bus susceptance matrix $\mathbf{B} \in \mathbb{R}^{n\times n}$:**

$$B_{ii} = \sum_{\ell:\, i\in\ell} b_\ell, \qquad B_{ij} = -b_\ell \text{ if line } \ell \text{ connects } i \text{ and } j, \qquad B_{ij} = 0 \text{ otherwise.}$$

2. **Form the reduced matrix $\mathbf{B}_{\mathrm{red}} \in \mathbb{R}^{(n-1)\times(n-1)}$** by deleting the row and column corresponding to the slack bus s.
3. **Invert** to obtain $\mathbf{X}_{\mathrm{red}} = \mathbf{B}^{-1}_{\mathrm{red}}$.
4. **Expand** back to $\mathbf{X} \in \mathbb{R}^{n\times n}$ by inserting zeros in the slack row and column.
5. **Compute PTDF entries**: for each line $\ell = (i,j)$ and injection node k,

$$\mathrm{PTDF}_{\ell k} = b_\ell\,(X_{ik} - X_{jk}).$$

6.2 Exogenous nodal injections $p^{\mathrm{exo}}_{i,t}$

Exogenous injections are generated as a low-rank spatiotemporal process to produce realistic correlated load patterns:

1. **Define two temporal basis functions** (sinusoidal load curves):

$$\varphi_1(t) = \sin\left(\frac{2\pi t}{96}\right), \qquad \varphi_2(t) = \sin\left(\frac{2\pi t}{48} + \frac{\pi}{4}\right).$$

2. **Draw two spatial loading patterns**: for each node $i \neq s$, draw $\psi_1(i), \psi_2(i) \sim \text{Uniform}(-0.5, 0.5)$.

3. **Combine with noise**: for $i \neq s$,

$$p_{i,t}^{\text{exo}} = p_{\text{base}}\,(r_{i,t} - 0.5) + \gamma_{\text{pat}}\big(\psi_1(i)\,\varphi_1(t) + \psi_2(i)\,\varphi_2(t)\big) + \gamma_{\text{noise}}\,\varepsilon_{i,t},$$

   where $r_{i,t} \sim \text{Uniform}(0,1)$, $\varepsilon_{i,t} \sim \mathcal{N}(0,1)$, and default scales are $p_{\text{base}} = 50$ MW, $\gamma_{\text{pat}} = 20$, $\gamma_{\text{noise}} = 2$.

4. **Balance at slack bus**:

$$p_{s,t}^{\text{exo}} = -\sum_{i \in \mathcal{N}\setminus\{s\}} p_{i,t}^{\text{exo}}.$$

5. **Rescale for feasibility**: compute flows under zero storage actions; if any $|f_{\ell,t}| > \gamma_{\text{margin}}\,\overline{F}_\ell$ (with $\gamma_{\text{margin}} = 0.7$), uniformly scale all $p_{i,t}^{\text{exo}}$ down and rebalance at slack. This ensures headroom for battery dispatch.

6.3 Day-ahead nodal prices $\lambda_{i,t}^{\text{DA}}$

Day-ahead prices combine a smooth system-wide baseline with node-specific offsets and temporal correlation:

1. **Generate a base price curve** $\bar{\lambda}_t$ using a Gaussian process with a periodic-plus-squared-exponential kernel:

$$K(\tau) = \sigma_{\text{per}}^2 \exp\left(-\frac{2\sin^2(\pi|\tau|/T_{\text{per}})}{\ell_{\text{per}}^2}\right) + \sigma_{\text{SE}}^2 \exp\left(-\frac{\tau^2}{2\ell_{\text{SE}}^2}\right),$$

   where $\tau = |t_1 - t_2| \cdot \Delta t$ is the time difference in hours, $T_{\text{per}} = 24$ h, and default hyperparameters are $\sigma_{\text{per}} = 10$, $\ell_{\text{per}} = 2$, $\sigma_{\text{SE}} = 5$, $\ell_{\text{SE}} = 4$. The GP sample is obtained via Cholesky decomposition of the covariance matrix.

2. **Add a diurnal pattern**:

$$\bar{\lambda}_t \leftarrow \bar{\lambda}_t + \lambda_0 + A\sin\left(\frac{2\pi\,(t\,\Delta t)}{24} - \frac{\pi}{2}\right),$$

   with $\lambda_0 = 50$ \$/MWh and $A = 20$ \$/MWh.

3. **Draw node offsets** δ_i: for each node i,

$$\delta_i = 5\,(r_i - 0.5), \qquad r_i \sim \text{Uniform}(0,1).$$

4. **Generate AR(1) residuals** $\omega_{i,t}$: for each node i, initialize $\omega_{i,0} = 0$ and evolve

$$\omega_{i,t} = \rho_{\text{AR}}\,\omega_{i,t-1} + \sqrt{1-\rho_{\text{AR}}^2}\cdot 2\,z_{i,t}, \qquad z_{i,t} \sim \mathcal{N}(0,1),$$

   with $\rho_{\text{AR}} = 0.8$. (We use ω rather than η to avoid confusion with the efficiency parameters η_b^c, η_b^d in (1).)

5. **Assemble nodal prices**:

$$\lambda_{i,t}^{\text{DA}} = \max\big\{\lambda_{\text{DA,min}},\ \bar{\lambda}_t + \delta_i + \omega_{i,t}\big\}.$$

6.4 Battery placement and parameters

Batteries are placed uniformly at random across nodes (allowing multiple batteries per node). Nominal battery parameters $(\overline{E}^{\text{nom}}, \overline{P}^{\text{nom}})$ are perturbed by the heterogeneity mechanism controlled by h (Appendix B); friction parameters are set to track defaults unless explicitly varied.

7 Baseline algorithm

The reference implementation includes a **flow-aware greedy heuristic** as the baseline solver (see `level2_greedy.rs` in the code repository). At each time step t, the algorithm:

1. Computes the average day-ahead price $\bar{\lambda}_t^{\text{DA}} = \frac{1}{n}\sum_i \lambda_{i,t}^{\text{DA}}$.
2. For each battery b at node $\nu(b)$: if $\lambda_{\nu(b),t}^{\text{DA}} < 0.95\,\bar{\lambda}_t^{\text{DA}}$ and SOC headroom permits, sets $u_{b,t} = -\overline{P}_b^c$ (full charge); if $\lambda_{\nu(b),t}^{\text{DA}} > 1.05\,\bar{\lambda}_t^{\text{DA}}$ and SOC permits, sets $u_{b,t} = +\overline{P}_b^d$ (full discharge); otherwise idles.
3. Iteratively adjusts actions to satisfy network flow constraints: identifies the most violated line, scales down actions of batteries whose PTDF contributions worsen the violation, and repeats until feasible or a maximum iteration count is reached.
4. If violations persist, applies binary search over a global scaling factor $\alpha \in [0, 1]$ to find the largest α such that $\alpha \cdot u_{\cdot,t}$ is flow-feasible.

This greedy baseline is intentionally simple; it does not perform lookahead or stochastic optimization, making it a natural lower bound for more sophisticated solvers.

A Default constants (initial values for testing)

The following constants are used unless overridden by the track definition. These are intended as starting values for pilot runs and can be adjusted after testing.

Canonical encoding. All integers in the hash input to (4) are encoded as big-endian signed 64-bit two's-complement. The concatenation order is exactly (s_t), then (t), then $(\tilde{u}_{1,t}, \ldots, \tilde{u}_{m,t})$, then $(\tilde{E}_{1,t}, \ldots, \tilde{E}_{m,t})$.

B TIG tracks: five parameter regimes and rationale

Each track fixes (n, L, m, H) and the key difficulty knobs $(\gamma_{\text{cong}}, \sigma, \rho_{\text{jump}}, \alpha, h)$. Instances within a track vary by the master seed, which drives network realization, day-ahead prices, and exogenous injections.

Heterogeneity mechanism (parameter h). Let $(\overline{E}^{\text{nom}}, \overline{P}^{\text{nom}})$ be nominal battery capacity and power for a track. For each battery b, draw $r_b \sim \text{Uniform}(0, 1)$ and set a multiplicative factor $M_b := 3^{h(2r_b-1)} \in [3^{-h}, 3^h]$. Then set $\overline{E}_b = \overline{E}^{\text{nom}} M_b$ and $\overline{P}_b^c = \overline{P}_b^d = \overline{P}^{\text{nom}} M_b$, with SOC bounds $\underline{E}_b = e_{\min}\overline{E}_b$ and $\overline{E}_b = e_{\max}\overline{E}_b$. This yields identical batteries at $h = 0$ and up to a $3\times$ spread at $h = 1$, matching the intended interpretation.

Rationale for the five tracks. The tracks are designed to induce qualitatively different algorithmic regimes rather than a strict ladder of computational difficulty; this encourages solvers to develop flexible, adaptive approaches.

Symbol	Meaning	Default value
Δt	time step duration	0.25 h (15 minutes)
s	slack bus index	1
q_u	action quantization step	0.01 MW
q_E	SOC quantization step	0.01 MWh
$e_{\min}, e_{\max}$	fractional SOC bounds	$e_{\min} = 0.10,\ e_{\max} = 0.90$
$E_{b,0}$	initial SOC	$0.50\,\overline{E}_b$
η_b^c, η_b^d	charge/discharge efficiency	0.95, 0.95
$\kappa_{\text{tx},b}$	transaction cost	\$0.25/MWh
$\kappa_{\text{deg},b}$	degradation scale	\$1.00
β_b	degradation exponent	2
μ	RT bias term	0
ρ_{sp}	spatial correlation	0.70
γ_{price}	congestion premium scale	\$20/MWh
τ_{cong}	congestion proximity threshold	0.97
ρ_{jump}	jump probability	0.02
α	Pareto tail index	3.5
$\lambda_{\min}$	RT price floor	\$-200/MWh
$\lambda_{\max}$	RT price cap	\$5000/MWh
$\lambda_{\text{DA,min}}$	DA price floor	\$0/MWh
$\varepsilon_{\text{flow}}$	flow feasibility tolerance	10^{-6} (per-unit of $\overline{F}_\ell$)
ε_{soc}	SOC feasibility tolerance	10^{-9} MWh
$\mathcal{H}$	hash function	SHA-256

Table 1: Default constants for Level 2 (initial test settings).

Track 1 is a correctness-and-baseline regime: the network is small, line limits are effectively nominal ($\gamma_{\text{cong}} = 1$), volatility is modest, and tail events are rare and thin-tailed, so many algorithm families can be competitive and feasibility is easy to maintain.

Track 2 introduces meaningful congestion by tightening limits ($\gamma_{\text{cong}} = 0.8$) and increasing both stochasticity and fleet diversity, making spatial coordination materially valuable without turning the problem into a pure feasibility puzzle.

Track 3 increases horizon and scale simultaneously, creating a regime in which solvers must manage multi-day energy carry, coordinate a larger portfolio, and remain robust to more frequent spikes; this tends to separate simple myopic heuristics from methods that internalize constraints and future opportunity cost.

Track 4 increases network density and further tightens limits, increasing the frequency of binding line constraints and raising the importance of congestion-aware control; at the same time, heavier tails make risk management and degradation/friction tradeoffs central.

Track 5 combines large network, large portfolio, tight limits, high volatility, and heavy tails, producing a regime where profitable operation requires consistently feasible coordination and disciplined response to rare but dominant scarcity events, while verification remains a straightforward replay.

C Table of variables and definitions

Track	n	L	m	H	γ_{cong}	σ	ρ_{jump}	α	h
1	20	30	10	96	1.00	0.10	0.01	4.0	0.2
2	40	60	20	96	0.80	0.15	0.02	3.5	0.4
3	80	120	40	192	0.60	0.20	0.03	3.0	0.6
4	100	200	60	192	0.50	0.25	0.04	2.7	0.8
5	150	300	100	192	0.40	0.30	0.05	2.5	1.0

Table 2: Proposed TIG tracks for Level 2. Here n is nodes, L is lines, m is batteries, H is time steps, γ_{cong} scales line limits, σ is volatility, $(\rho_{\text{jump}}, \alpha)$ control tail risk, and h controls fleet heterogeneity.

Symbol	**Meaning**
H	Number of discrete time steps in the horizon.
Δt	Duration (hours) of one time step.
t	Time index, $t \in \{0, \ldots, H-1\}$.
$\mathcal{N}, n$	Set of nodes and its size.
$\mathcal{L}, L$	Set of lines and its size.
$\mathcal{B}, m$	Set of batteries and its size.
$\nu(b)$	Node index where battery b is located.
$u_{b,t}$	Signed battery power (MW): discharge if positive, charge if negative.
$c_{b,t}, d_{b,t}$	Derived charge/discharge powers (MW), $(\cdot)_+$ decomposition.
$\overline{P}_b^c, \overline{P}_b^d$	Charge/discharge power limits (MW).
$E_{b,t}$	Battery state of charge at time t (MWh).
$\underline{E}_b, \overline{E}_b$	SOC lower and upper bounds (MWh).
η_b^c, η_b^d	Charge/discharge efficiency parameters.
$p_{i,t}^{\text{exo}}$	Exogenous nodal injection (MW) at node i and time t.
$p_{i,t}^{\text{stor}}$	Storage-induced nodal injection (MW).
$p_{i,t}$	Total nodal injection (MW), including slack balancing at s.
s	Slack bus index.
PTDF	PTDF matrix mapping nodal injections to line flows under DC approximation.
$f_{\ell,t}$	Flow on line ℓ at time t (MW).
$\overline{F}_\ell^{\text{nom}}$	Nominal thermal limit of line ℓ (MW).
γ_{cong}	Track parameter scaling line limits: $\overline{F}_\ell = \gamma_{\text{cong}} \overline{F}_\ell^{\text{nom}}$.
$\lambda_{i,t}^{\text{DA}}$	Day-ahead nodal price forecast (\$/MWh).
$\lambda_{i,t}^{\text{RT}}$	Real-time nodal price (\$/MWh) generated sequentially.
s_t	Commitment seed at time t (256-bit).
q_u, q_E	Quantization steps for hashing actions and SOCs.
$\tilde{u}_{b,t}, \tilde{E}_{b,t}$	Quantized integer versions of $u_{b,t}$ and $E_{b,t}$.
μ, σ	Bias and volatility of multiplicative price shock.
ρ_{sp}	Spatial correlation of nodal shocks.
$\mathbf{1}_{i,t}^{\text{cong}}$	Congestion indicator used in price at node i, time t.
τ_{cong}	Threshold defining "near-binding" line utilization.
γ_{price}	Congestion premium scale in price model.
$\rho_{\text{jump}}, \alpha$	Jump probability and Pareto tail index for scarcity component.
$J_{i,t}$	Jump/scarcity price component at node i, time t.
$\phi_b(\cdot)$	Friction function (transaction + degradation costs).
R_t	Portfolio profit at time t (objective increment).

h	Track parameter controlling heterogeneity of battery parameters.