GENERAL NOTES

1. THE BUILDER IS TO PROVIDE AN OPERATION MANUAL (CONTAINING INFORMATION FOR MAINTAINING APPLIANCES, ETC.) FOR THE OWNER AT THE TIME OF FINAL INSPECTION. CGC 4.410.1.
2. DURING CONSTRUCTION, ENDS OF DUCT OPENINGS ARE TO BE SEALED, AND MECHANICAL EQUIPMENT IS TO BE COVERED. CGC 4.504.1
3. THE GAS FIREPLACE(S) SHALL BE DIRECT VENT. WOODSTOVE OR PELLET STOVES MUST BE US EPA PHASE II RATED APPLIANCES. CGC 4.503.1
4. VOC'S MUST COMPLY WITH THE LIMITATIONS LISTED IN SECTION 4.504.3 AND TABLES 4.504.1, 4.504.2, 4.504.3 AND 4.504.5 FOR: ADHESIVES, PAINTS AND COATINGS, CARPET AND COMPOSITION WOOD PRODUCTS. CGC 4.504.2.
5. INTERIOR MOISTURE CONTROL AT SLAB ON GRADE FLOORS SHALL BE PROVIDED BY THE SOIL ENGINEER RESPONSIBLE FOR THE PROJECT SOIL REPORT PER CGC SECTION 5.505.2.1, ITEM 3. IF A SOIL ENGINEER HAS NOT PREPARED A SOIL REPORT FOR THIS PROJECT, THE FOLLOWING IS REQUIRED: A 4" THICK BASE 1/2" OR LARGER CLEAN AGGREGATE SHALL BE PROVIDED WITH A VAPOR BARRIER IN DIRECT CONTACT WITH CONCRETE, WITH A CONCRETE MIX DESIGN WHICH WILL ADDRESS BLEEDING, SHRINKAGE AND CURLING SHALL BE USED.
6. THE MOISTURE CONTENT OF WOOD SHALL NOT EXCEED 19% BEFORE IT IS ENCLOSED IN CONSTRUCTION. THE MOISTURE CONTENT NEEDS TO BE CERTIFIED BY ONE OF 3 METHODS SPECIFIED. BUILDING MATERIALS WITH VISIBLE SIGNS OF WATER DAMAGE SHOULD NOT BE USED IN CONSTRUCTION. THE MOISTURE CONTENT MUST BE DETERMINED BY THE CONTRACTOR BY ONE OF THE METHODS LISTED IN CGC SECTION4.505.3.
7. BATHROOM FANS SHALL BE ENERGY STAR RATED, VENTED DIRECTLY TO THE OUTSIDE AND CONTROLLED BY A HUMIDISTAT. CGC 4.506.1.
8. IF PROVIDED, WHOLE HOUSE EXHAUST FANS SHALL HAVE INSULATED COVERS OR LOUVERS WHICH CLOSE WHEN THE FAN IS OFF. THE COVERS OR LOUVERS SHALL HAVE MINIMUM R4.2 INSULATION. CGC 5.507.1.
9. HEATING AND AC SHALL BE SIZED AND SELECTED BY ACCA MANUAL J OR ASHRAE HANDBOOK OR EQUIVALENT. THE DUCT SIZING SHALL BE SIZED IN ACCORDANCE WITH ONE OF THE ACCA METHODS LISTED IN CGC SECTION 4.507.2.
10. PRIOR TO FINAL APPROVAL OF THE BUILDING THE LICENSED CONTRACTOR, ARCHITECT OR ENGINEER IN RESPONSIBLE CHARGE OF THE OVERALL CONSTRUCTION MUST COMPLETE AND SIGN THE GREEN BUILDING STANDARDS CERTIFICATION
11. FORM AND GIVEN TO THE BUILDING DEPARTMENT OFFICIAL TO BE FILED WITH THE APPROVED PLANS.
12. WHEN A SHOWER IS PROVIDED WITH MULTIPLE SHOWER HEADS, THE SUM OF FLOW TO ALL THE HEADS SHALL NOT EXCEED THE 20% REDUCED LIMIT, OR THE SHOWER SHALL BE DESIGNED SO THAT ONLY ONE HEAD IS ON AT A TIME. CGC 4.303.2.
13. LANDSCAPE IRRIGATION WATER USE SHALL HAVE WEATHER BASED CONTROLLERS. CGC 4.304.1.
14. AN AUTOMATIC RESIDENTIAL FIRE SPRINKLER SYSTEM SHALL BE INSTALLED IN ONE- AND TWO-FAMILY DWELLINGS.
15. GARAGE SHALL BE SEPARATED FROM THE RESIDENCE AND ITS ATTIC AREA BY NOT LESS THAN 1/2"GYPSUM BOARD APPLIED TO THE GARAGE SIDE (AT WALLS). GARAGES BENEATH HABITABLE ROOMS SHALL BE SEPARATED BY NOT LESS THAN 5/8" TYPE X GYPSUM BOARD. SECTION 406.1.4. STRUCTURAL MEMBERS SUPPORTING A HORIZONTAL FIRE BARRIER MUST HAVE THE SAME FIRE-RESISTIVE RATING AS THE SEPARATION. SECTION 711.4.
16. COMBUSTION AIR FOR FUEL BURNING WATER HEATERS WILL BE PROVIDED IN ACCORDANCE WITH THE PLUMBING CODE
17. THE WALLS AND SOFFITS OF THE ENCLOSED USABLE SPACE UNDER INTERIOR STAIRS SHALL BE PROTECTED ON THE ENCLOSED SIDE WITH 1/2-INCH GYPSUM BOARD
18. UNDER-FLOOR VENTILATION SHALL BE NOT LESS THAN 1/150 OF UNDER FLOOR AREA.
19. THE WATER HEATER SHALL BE STRAPPED AS PER UPC SECTION 510.5 W/ 11/2" WIDE 16 GA. METAL STRAPS (ONE AT 1/3 FROM THE TOP AND ONE 1/3 FROM THE BOTTOM OF THE WATER HEATER).
20. THE PRESSURE RELIEVE VALVE OF THE WATER HEATER SHALL DRAIN TO THE OUTSIDE OF THE BUILDING WITH THE END PIPE NOT MORE THAN 2' AND NOT LESS THAN 6" ABOVE THE GROUND PER UPC SECTION 608.5.
21. PROVIDE A MIN. 22" X 30" ATTIC ACCESS
22. PROVIDE 70" HIGH NON-ABSORBENT WALL ADJACENT TO SHOWER AND APPROVED SHATTER-RESISTANT MATERIALS FOR SHOWER.
23. PROVIDE ULTRA FLUSH WATER CLOSETS FOR ALL NEW CONSTRUCTION. SHOWER HEADS AND TOILETS MUST BE ADAPTED FOR LOW WATER CONSUMPTION.

CALIFORNIA GREEN CODE STANDARDS

PER 2022 GREEN CODE SEC 4.303.3 PLUMBING FIXTURES (WATER CLOSETS AND URINALS) AND FITTINGS (FAUCET AND SHOWER HEADS) SHALL MEET THE STANDARDS REFERENCED IN TABLE 4.303.3 (REFER TO TABLE ON SHEET A04)

AUTOMATIC IRRIGATION SYSTEM CONTROLLERS FOR LANDSCAPING PROVIDED BY THE BUILDER AND INSTALLED AT THE TIME OF FINAL INSPECTION SHALL COMPLY WITH THE FOLLOWING:

1. CONTROLLERS SHALL BE WEATHER-OR SOIL MOISTURE-BASED CONTROLLERS THAT AUTOMATICALLY ADJUST IRRIGATION IN RESPONSE TO CHANGES IN PLANTS NEEDS AS WEATHER CONDITIONS CHANGE

2. WEATHER-BASED CONTROLLERS WITHOUT INTEGRAL RAIN SENSORS OR COMMUNICATION SYSTEMS THAT ACCOUNT FOR LOCAL RAINFALL SHALL HAVE A SEPARATE WIRED OR WIRELESS RAIN SENSOR WHICH CONNECTS OR COMMUNICATES WITH THE CONTROLLER(S). SOIL MOISTURE-BASED CONTROLLERS ARE NOT REQUIRED TO HAVE RAIN SENSOR INPUT.

PER 2013 GREEN CODE SEC 4.503.1 ANY INSTALLED GAS FIREPLACE SHALL BE A DIRECT-VENT SEALED-COMBUSTION TYPE. ANY INSTALLED WOODSTOVE OR PELLET STOVE SHALL COMPLY WITH U.S. EPA PHASE II EMISSION LIMITS WHERE APPLICABLE. WOODSTOVES, PELLET STOVES AND FIREPLACES SHALL ALSO COMPLY WITH APPLICABLE LOCAL ORDINANCES.

PER 2010 GREEN CODE SEC 4.506.1 MECHANICAL EXHAUST FANS WHICH EXHAUST DIRECTLY FROM BATHROOMS SHALL COMPLY WITH THE FOLLOWING:
1. FANS SHALL BE ENERGY STAR COMPLIANT AND BE DUCTED TO TERMINATE OUTSIDE THE BUILDING.
2. UNLESS FUNCTIONING AS A COMPONENT OF A WHOLE HOUSE VENTILATION SYSTEM, FANS MUST BE CONTROLLED BY A HUMIDISTAT WHICH SHALL BE READILY ACCESSIBLE. HUMIDISTAT CONTROLS SHALL BE CAPABLE OF ADJUSTMENT BETWEEN A RELATIVE HUMIDITY RANGE OF 50 TO 80 PERCENT

A SIGNED AFFIDAVIT FROM INSTALLER STATING METHOD USED FOR THE SELECTION OF HEATING AND AIR CONDITIONING EQUIPMENT AND THAT SUCH EQUIPMENT WAS INSTALLED IN ACCORDANCE TO THAT METHOD IS REQUIRED; THIS AFFIDAVIT SHALL BE PRESENTED TO THE BUILDING INSPECTOR BEFORE FINAL INSPECTION

DOOR SCHEDULE

Mark	Count	Description	Width	Height	Sill Height	Head Height	Thickness	Level	Comments
101	1		3' - 0"	7' - 0"	0' - 0"	7' - 0"	0' - 2"	1st Floor Level	ADU
102	1		8' - 0"	6' - 6"	-0' - 4"	6' - 2"		1st Floor Level	ADU
103	1		8' - 0"	6' - 6"	-0' - 4"	6' - 2"		1st Floor Level	ADU
104	1		2' - 8"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	1st Floor Level	ADU
105	1		2' - 8"	6' - 8"	-0' - 4"	6' - 4"	0' - 2"	1st Floor Level	ADU
106	1		6' - 0"	6' - 10"	0' - 0"	6' - 10"	0' - 2"	1st Floor Level	ADU
107	1		2' - 8"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	1st Floor Level	ADU
108	1		2' - 0"	6' - 1"	0' - 0"	6' - 1"	0' - 1"	1st Floor Level	ADU
109	1		2' - 0"	6' - 1"	0' - 0"	6' - 1"	0' - 1"	1st Floor Level	ADU
110	1		2' - 8"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	1st Floor Level	ADU
111	1		6' - 0"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	1st Floor Level	ADU
112	1		6' - 0"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	1st Floor Level	ADU
113	1		2' - 8"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	1st Floor Level	ADU
114	1		2' - 8"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	1st Floor Level	ADU
201	1		3' - 0"	7' - 0"	0' - 0"	7' - 0"	0' - 2"	2nd FLoor Level	ADU
202	1		2' - 8"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	2nd FLoor Level	ADU
203	1		3' - 0"	6' - 8"	0' - 0"	6' - 8"	0' - 1 1/2"	2nd FLoor Level	ADU
204	1		2' - 0"	6' - 1"	0' - 0"	6' - 1"	0' - 1"	2nd FLoor Level	ADU
205	1		2' - 6"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	2nd FLoor Level	ADU
206	1		2' - 6"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	2nd FLoor Level	ADU
207	1		2' - 6"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	2nd FLoor Level	ADU
208	1		2' - 6"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	2nd FLoor Level	ADU
209	1		5' - 8"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	2nd FLoor Level	ADU
210	1		2' - 6"	6' - 8"	0' - 0"	6' - 8"	0' - 2"	2nd FLoor Level	ADU

WINDOWS SCHEDULE

Mark	Count	Description	Level	Height	Width	Sill Height	Manufacturer	Model	Comments
01	1		1st Floor Level	5' - 0"	3' - 0"	3' - 0"			ADU
02	1	Gliding	1st Floor Level	4' - 0"	4' - 0"	3' - 0"			ADU
03	1		1st Floor Level	2' - 0"	3' - 0"	5' - 6"			ADU
04	1		1st Floor Level	5' - 0"	5' - 0"	2' - 6"			ADU
05	1		1st Floor Level	5' - 0"	3' - 0"	2' - 6"			ADU
06	1		1st Floor Level	5' - 0"	5' - 0"	2' - 6"			ADU
07	1		1st Floor Level	2' - 0"	3' - 0"	5' - 6"			ADU
21	1		2nd FLoor Level	2' - 0"	3' - 0"	5' - 6"			ADU
22	1		2nd FLoor Level	5' - 0"	1' - 4"	0' - 7 11/32"			ADU
23	1		2nd FLoor Level	5' - 0"	1' - 4"	0' - 6 13/16"			ADU
24	1		2nd FLoor Level	5' - 0"	1' - 4"	0' - 5 23/32"			ADU
25	1		2nd FLoor Level	5' - 0"	1' - 4"	0' - 5 23/32"			ADU
26	1		2nd FLoor Level	5' - 0"	5' - 0"	3' - 0"			ADU
27	1	Gliding	2nd FLoor Level	4' - 0"	4' - 0"	3' - 0"			ADU
28	1		2nd FLoor Level	5' - 0"	3' - 0"	3' - 0"			ADU
29	1		2nd FLoor Level	5' - 0"	3' - 0"	3' - 0"			ADU
30	1		2nd FLoor Level	2' - 0"	3' - 0"	5' - 6"			ADU
31	1		2nd FLoor Level	5' - 0"	5' - 0"	3' - 0"			ADU
32	1		2nd FLoor Level	5' - 0"	3' - 0"	3' - 0"			ADU
33	1		2nd FLoor Level	5' - 0"	5' - 0"	3' - 0"			ADU

1

WINDOW NOTES:

1. **ALL EMERGENCY ESCAPE AND RESCUE OPENINGS SHALL HAVE A MINIMUM NET CLEAR OPENING OF 5.7 SQUARE FEET.[SEC. R310.1.1]**
2. **ALL EMERGENCY ESCAPE AND RESCUE OPENINGS SHALL HAVE THE FOLLOWING DIMENSIONS: THE MINIMUM NET CLEAR OPENING HEIGHT DIMENSION SHALL BE 24 INCHES. [SEC. R310.1.2]. THE MINIMUM NET CLEAR OPENING WIDTH DIMENSION SHALL BE 20 INCHES. [SEC.R310.1.3]**
3. **EMERGENCY ESCAPE AND RESCUE OPENINGS SHALL HAVE A SILL HEIGHT OF NOT MORE THAN 44 INCHES ABOVE THE FLOOR. [SEC. R310.1]**

PLANNING
DESIGN
ENGINEERING

DELTA DESIGN Studio

9855 BLACK MT. RD I SAN DIEGO, CA 92126 I P (858)-335-0818 I F (800)-309-1008

Steven Truong Res-New ADU

6633 Electric Ave
La Jolla, CA 92037

REGISTERED PROFESSIONAL ENGINEER
HUY THIEU NGUYEN
No. C62628
Exp. 06/30/2024
CIVIL
STATE OF CALIFORNIA

Revision Dates

1	08.15.24
2	01.01.25

SHEET TITLE

Door-Windows Schedule

Drawing Date: 08.27.26

Check By: Checker

Drawn By: Author

Scale: As indicated

Job Number: 022225

Sheet Number

A102