



1 Site Plan

1" = 10'-0"

KEYNOTES:

- EXISTING LANDSCAPING AREA
- PROPOSED STREET TREES
- EXIST. CONC.
- NOT USED
- PROPOSED TREES PER PERMIT #
- ROOT BARRIER

LANDSCAPE LEGEND

KEY	DESCRIPTION	BOTANICAL NAME	SIZE	QUANTITY
	Gold Medallion trees	Cassia leptophylla	24 GAL	
	Mexican Blue Palm	Brahea edulis	24 GAL	
	EXISTING LANDSCAPING AREA			
	CONCRETE			

NOTE: ALL INDICATED LANDSCAPE AREAS WILL BE DONE WITH ZEROSCAPE FOR MINIMUM WATER USAGE. AN AUTOMATIC DRIP SYSTEM SHALL BE INSTALLED THROUGHOUT ALL LANDSCAPED AREAS AND SHALL BE DESIGNED AND INSTALLED BY QUALIFIED CONTRACTOR. CONTRACTOR TO SUBMIT PLANS FOR APPROVAL BY THE OWNER AND ARCHITECT PRIOR TO THE AWARDED OF CONTRACT FOR INSTALLATION.

LANDSCAPE NOTES

- ALL CONSTRUCTION MATERIALS TO BE STORED IN DRIVE AREA DURING CONSTRUCTION.
- AUTOMATIC DRIP SYSTEM TO BE INSTALLED IN ALL PLANTING AREAS.
- OVER-DIG ALL TREE AND SHRUB HOLES TWO TIMES BALL SIZE AND REPLACE WITH MIX OF TOPSOIL AND ORGANIC MATERIAL.
- MULCH ALL PERENNIAL BEDS WITH AT LEAST THREE INCHES OF ORGANIC MULCH.
- RE-VEGETATE ALL AREAS TO REMAIN NATIVE WITH NATIVE GRASSES.
- THERE IS TO BE NO SOD.
- TRASH TO BE ENCLOSED IN GARAGE.
- APPLY ROCK OVER 6 MIL PLOY WHERE WATER IS CHanneled AROUND HOUSE. DESIGN FOR SHEET DRAINAGE WHERE WATER IS NOT CHanneled.
- ALL CANOPY TREES SHALL BE PROVIDED WITH 40 SQ. FEET ROOT ZONE AND PLANTED IN AN AIR AND WATER PERMEABLE LANDSCAPE AREA. THE MINIMUM DIMENSION (WIDTH) OF THIS AREA SHALL BE 5 FEET.
- TREE ROOT BARRIERS SHALL BE INSTALLED WHERE TREES ARE PLACED WITHIN 5 FEET OF PUBLIC IMPROVEMENTS INCLUDING WALKS, CURBS, OR STREET PAVEMENT OR WHERE NEW PUBLIC IMPROVEMENTS ARE PLACED ADJACENT TO EXISTING TREES. ROOT BARRIERS WILL NOT BE WRAPPED AROUND THE ROOTBALL. IDENTIFY THE TYPE OF ROOT BARRIER.
- ALL LANDSCAPE AND IRRIGATION SHALL BE INSTALLED AND MAINTAINED IN ACCORDANCE WITH THE CITY OF SAN DIEGO'S LANDSCAPE REGULATIONS, THE LAND DEVELOPMENT MANUAL LANDSCAPE STANDARDS, AND ALL OTHER LANDSCAPE RELATED CITY AND REGIONAL STANDARDS.
- ALL REQUIRED LANDSCAPE AREAS SHALL BE MAINTAINED BY [PLEASE SPECIFY]. THE LANDSCAPE AREAS SHALL BE MAINTAINED FREE OF DEBRIS AND LITTER AND ALL PLANT MATERIAL SHALL BE MAINTAINED IN A HEALTHY GROWING CONDITION.
- MINIMUM TREE SEPARATION DISTANCE
 - TRAFFIC SIGNALS / STOP SIGNS - 20 FEET
 - UNDERGROUND UTILITY LINES - 5 FEET (10' FO R SEWER)
 - ABOVE GROUND UTILITY STRUCTURES - 10 FEET
 - DRIVEWAY (ENTRIES) - 10 FEET (5' FOR RESIDENTIAL STREETS < 25MPH)
 - INTERSECTIONS (INTERSECTING CURB LINES OF TWO STREETS) - 25 FEET
- MAINTENANCE: ALL REQUIRED LANDSCAPE AREAS SHALL BE MAINTAINED BY OWNER. LANDSCAPE AND IRRIGATION AREAS IN THE PUBLIC RIGHT-OF-WAY SHALL BE MAINTAINED BY OWNER. THE LANDSCAPE AREAS SHALL BE MAINTAINED FREE OF DEBRIS AND LITTER, AND ALL PLANT MATERIAL SHALL BE MAINTAINED IN A HEALTHY GROWING CONDITION, DISEASED OR DEAD PLANT MATERIAL SHALL BE SATISFACTORILY TREATED OR REPLACED 30 DAYS OF A FINAL LANDSCAPE INSPECTION.
- ALL PRUNING SHALL COMPLY WITH THE STANDARDS OF THE AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI) FOR TREE CARE OPERATIONS AND THE INTERNATIONAL SOCIETY OF ARBORICULTURE (ISA) FOR TREE PRUNING. TOPPING OF TREES IS NOT PERMITTED.
- TREES SHALL BE MAINTAINED SO THAT ALL BRANCHES OVER PEDESTRIAN WALKWAYS ARE 6 FEET ABOVE THE WALKWAY GRADE AND BRANCHES OVER VEHICULAR TRAVEL WAYS ARE 16 FEET ABOVE THE GRADE OF THE TRAVEL WAY PER THE SAN DIEGO MUNICIPAL CODE, SECTION 142.0403(B)(10).
- MULCH: ALL REQUIRED PLANTING AREAS AND ALL EXPOSED SOIL AREAS WITHOUT VEGETATION SHALL BE COVERED WITH MULCH TO A MINIMUM DEPTH OF 3 INCHES, EXCLUDING SLOPES REQUIRING REVEGETATION PER SDMC 142.0411.
- A MINIMUM ROOT ZONE OF 40SF IN AREA SHALL BE PROVIDED FOR ALL TREES. THE MINIMUM DIMENSION FOR THIS AREA SHALL BE 5 FEET, PER SDMC 142.0403(B)(5).
- TREE ROOT BARRIERS SHALL BE INSTALLED WHERE TREES ARE PLACED WITHIN 5 FEET OF PUBLIC IMPROVEMENTS INCLUDING WALKS, CURBS, OR STREET PAVEMENTS OR WHERE NEW PUBLIC IMPROVEMENTS ARE PLACED ADJACENT TO EXISTING TREES. THE ROOT BARRIER WILL NOT WRAP AROUND THE ROOT BALL.
- ANY PLANT MATERIAL REQUIRED BY THIS DIVISION THAT DIES WITHIN 3 YEARS OF INSTALLATION SHALL BE REPLACED WITHIN 30 CALENDAR DAYS OF PLANT DEATH WITH THE SAME SIZE AND SPECIES OF PLANT MATERIAL SHOWN ON THE APPROVED PLAN.
- EXISTING TREES TO REMAIN WITHIN THE AREA OF WORK WILL BE PROTECTED IN PLACE. THE FOLLOWING PROTECTION MEASURES WILL BE PROVIDED:
 - A BRIGHT YELLOW OR ORANGE TEMPORARY FENCE WILL BE PLACED AROUND EXISTING TREES AT THE DRIP LINE.
 - STOCKPILING, TOPSOIL DISTURBANCE, VEHICLE USE, AND MATERIAL STORAGE OF ANY KIND IS PROHIBITED WITHIN THE DRIP LINE.
 - ROOT SYSTEMS OF EXISTING TREES WILL BE PROTECTED FROM FLOODING, EROSION, CHEMICAL SPILLS, AND EXCESSIVE WETTING AND DRYING DURING DEWATERING.
 - THE EXISTING GRADE WILL BE MAINTAINED WITHIN THE DRIP LINE OF EXISTING TREES.
 - ROOTS OF EXISTING TREES WILL BE CUT APPROXIMATELY 6 INCHES BACK FROM NEW CONSTRUCTION.
 - A CERTIFIED CONSULTING ARBORIST SHALL OVERSEE PRUNING OF ANY ROOTS 4-IN OR GREATER IN DIAMETER.
 - MAINTAIN AND DOCUMENT A TREE WATERING SCHEDULE DURING CONSTRUCTION.
 - ALL DAMAGED TREES WILL BE REPLACED WITH ONE OF EQUAL OR GREATER SIZE.

TOTAL THROUGHWAY AREA: 333 SF
TOTAL SHADED AREA ACHIEVED BY CANOPIES : 628 SF
TOTAL AREA OF THE SHADED AREA PROVIDED BY THE TREE'S CANOPY OVER THE THROUGHWAY ZONE: 170 SF
PERCENT ACHIEVED OF SHADED AREA TO THROUGHWAY ZONE AREA: 51%
THE NUMBER OF TREES PROVIDED: 2