

# HOLD POINT EVIDENCE PACKAGE

Lot: HP-PREVIEW-TEST-001

## 1. Hold Point Identification

STATUS: RELEASED

Hold Point Description: Subgrade compaction inspection - requires engineer approval

Scheduled Date: 19 Jan 2026, 11:00 am

Released: 19 Jan 2026, 12:16 am

Released By: Sarah Mitchell

Release Notes: Inspection completed successfully. All work conforms to specification.

## 2. Lot Details

Project: Subcontractor Test Project

Project Number: PRJ-SUB-TEST

Lot Number: HP-PREVIEW-TEST-001

Description: Test lot for HP evidence package preview feature

Activity Type: Earthworks

ITP Template: HP Test ITP Template

## 3. Completed Checklist Items

Completion Status: 1 / 1 items completed

#	Description	Type	Status	Completed By
1	Subgrade compaction inspection - requires ...	HP	Done	Admin User Updated

## 4. Test Results

Total Tests: 1 | Passing: 1

Test Type	Lab	Result	Pass/Fail	Verified
Compaction	ABC Testing Labs	98.5 % MDD	pass	No

## 5. Photos & Evidence

Photos: 0

Checklist Attachments: 0

*(Full photo images available in SiteProof system)*

---

## 6. Survey Data

*(Survey coordinates and as-built data available in SiteProof system)*

---

## 7. Evidence Summary

Checklist Items Completed: 1 / 1

Items Verified: 0

Test Results: 1 (1 passing)

Photos: 0

Attachments: 0

---

Generated: Monday, 19 January 2026 at 4:02:11 am

This evidence package was generated by SiteProof v2 - Civil Execution and Conformance Platform