



GENSAN MEDICAL CENTER

Purok Veterans, Brgy Calumpang, National Highway, General Santos City, 9500

REQUEST FOR REPAIR OF ACCOUNTABILITY

Control No. : 718

Date : 01-Oct-2025

To: Inventory Section

The following items are request list for repair.

AIRCON REPAIR
NURSE SERVICES UNIT 3

Property No. : 20251000784

NOT COOLING. FOR CHECK-UP/REPAIR.

Findings : REPLACED COMPRESSOR & REPROCESS/CHARGE FREON..

I certify that item(s) mentioned above reasonable requires
repair of accountability in view of reason(s) stated above.

Name of Employee

(Sign over printed name)

Text Object

Checked by:

MAE QUIAMCO - BATAN, RSW

10/02/2025

Section/Division/Dept. Head