



## GENSAN MEDICAL CENTER

Purok Veterans, Brgy Calumpang, National Highway, General Santos City, 9500

### REQUEST FOR REPAIR OF ACCOUNTABILITY

Control No. : 751

Date : 23-Oct-2025

To: Inventory Section

The following items are request list for repair.

#### AIRCON

NURSE SERVICES UNIT 3

ENGINEERING & MAINTENANCE DEPARTMENT

Property No. : 20251000999


DAMAGED PCB. FOR REPLACEMENT.

Findings :

FOR REPLACEMENT.

I certify that item(s) mentioned above reasonable requires repair of accountability in view of reason(s) stated above.

Name of Employee  
(Sign over printed name)

Checked by:  11/05/2025  
MAE QUIAMCO - BATAN, RSW  
Section/Division/Dept. Head