



GENSAN MEDICAL CENTER

Purok Veterans, Brgy Calumpang, National Highway, General Santos City, 9500

REQUEST FOR REPAIR OF ACCOUNTABILITY

Control No. : 628
Date : 30-Jun-2025

To: Inventory Section

The following items are request list for repair.

GENERATOR SET
ENGINEERING & MAINTENANCE
DEPARTMENT

Property No. : 20250800450

REPLACE DEFECTIVE PARTS OF GENSET.

Findings : SUPPLY & INSTALLATION OF GENSET CONTROLLER COM AP
WITH ACCESORIES.

I certify that item(s) mentioned above reasonable requires
repair of accountability in view of reason(s) stated above.

Name of Employee
(Sign over printed name)

Checked by:

Section/Division/Dept. Head

Monday, 30 - Jun - 2025

Page 1 of 1