

**EMAC ELECTRO MECHANICAL L.L.C****P O Box - 233237 Dubai U A E****04 - 3411332****SITE / STOCK REQUISITION**


Requisition No.	PL - 006	Division :	PLUMBING
Date Requested	26/08/2026	LPO Required by	07/09/2026
Project No.	P - 270	Original Contract	✓
Project Name.	PARK FIVE BY DEYAAR	Variation Works	

Item No.	Description	Qty. Req.	Model	Make	Remarks
A	COSMOPLAST MAKE - PN20 Cross Linked Polyethylene (PEX) Pipes and Fittings DZR BRASS to DIN 16892 & 16893 with corrugated Polyethylene Conduits Blue & Red. Fittings				
1	COSMOPLAST PEX PIPE 16 x 2.2 MM X PN 20.	27500 Mtr	PX-P-16-2.2	COSMOPLAST	P184.01-GB-TS-MT-MEP-PL-00016 Rev - 00
2	COSMOPLAST CORRUGATED CONDUIT 25 MM BLUE COLOR	29300 Mtr 19300	PX-CC-25B	COSMOPLAST	
3	COSMOPLAST CORRUGATED CONDUIT 25 MM RED COLOR	8300 Mtr 8200	PX-CC-25R	COSMOPLAST	
4	16 x 2.2 MM x 1/2" COSMOPLAST DZR PEX SANITARY ELBOW WITH FEMALE THREAD	8000 Nos	PX-SE-1/2-16	COSMOPLAST	
5	COSMOPLAST PLASTIC ELBOW CASING 25MM DZR ELBOWWITH SS SCREW - BLUE	5600 Nos	PX-BSE-B	COSMOPLAST	
6	COSMOPLAST PLASTIC ELBOW CASING 25MM DZR ELBOWWITH SS SCREW -RED	2400 Nos	PX-BSE-R	COSMOPLAST	
7	16 x 2.2 MM x 1/2' COSMOPLAST DZR PEX MALE ADAPTOR	8000 Nos	PX-MA-1/2-16	COSMOPLAST	
8	PEX Protection Cap (Blue)	5500 Nos	PX-PC-25-16B	COSMOPLAST	
9	PEX Protection Cap (RED)	2500 Nos	PX-PC-25-16R	COSMOPLAST	
COMPLY ALL COMMENTS PRIOR TO DELIVERY. DELIVERY SHOULD BE AS PER PROJECT DELIVERY SCHEDULE					

ORDER SUMMARY	TOWER - 1	TOWER - 2
	FLOORS	FLOORS
ORDERED TILL PREVIOUS MR NO. <u>00</u>	BM - 11 Floor	BM - 11 Floor
ORDERED IN THIS MR NO. <u>05</u>		
TOTAL ORDERED PERCENTAGE (Incl. this MR)	90%	90%

Projects / Departments		Site Stores	
Initiated By	Reviewed By		
	for <i>Sunny</i>	SSR:-	
		DATE:-	
FM/ PE	PM		

Note : Name & Designation of the individuals to be mentioned above

Client: 		Consultant: 		Contractor : 		MEP Sub Contractor: 	
PROJECT NAME: PARK FIVE - ELM BY DEYAAR, Tower-A & Tower-B (G+11F+R) & Shared Podium (1B+G+1P+R) @ Plot Number 6850609 in Me'Aisem First - Dubai Production City, Dubai, UAE		PROJECT CODE: P184.01					
MATERIAL SUBMITTAL				Str. ☐	Arch. ☐	MEP. ☒	☐ Elect. ☒ Plum. ☐ HVA/C ☐ F/ F. ☐ F/A.
REF. No	P184.01-GB-TS-MT-MEP-PL-00016	Rev.	0				
TO : M/s. AE Prime Engineering Consultants							
Prepared By : M/s. Emac Electromechanical LLC							
Date: 22-Jun-2026							
Main Contractor:	M/s. G&B Contracting LLC	Subcontractor/ Supplier :	M/s. Junaid Sant. & Elect. Mat. Tr. LLC	Brand: Cosmoplast			
Contractor's Signature :	Name: Mr. Subeesh Rajan Project Manager Sign	MEP Subcontractor Signature:	Project Manager Sign				
S.N.	Item Description	Rev.	Notes				
1	Material Submittal for PEX Pipes & Fittings M/s. Junaid Sant. & Elect. Mat. Tr. LLC	0					
Attached Documents: PDF							
Comments: The Proposed PEX Pipes PN20 and DZR Brass Fittings from Cosmoplast make & supplier by M/s. Junaid Sant. & Elect. Mat. Trading LLC is accepted in principle, subject to in compliance with below comments: 1. Contractor/ supplier proposed PEX Pipes and DZR Brass Fittings 1 year defect warranty period as per VE are note, provide the Original Warranty, that shall be applicable from date of the issuance of the TOC. 2. PEX Pipes and DZR Brass Fittings installation as per manufacturer recommendation and approved Method Statement, raise mock up installation IR for Engineer's site witness and final approval. 3. All delivered PEX Pipes and DZR Brass materials to be stored and protected against any damage as per manufacturer recommendation. Note: Any deviation from complying to the above comments, will have this acceptance considered as Void and Nil.				Submittal status		A - Approved B - Approved as noted ☒ C - Revise and re - submit D - Rejected R - For Information	
Received Date		Returned Date		Date received by Contractor			
Signature		Signature		Signature			
							

Additional comments from Engr. Ebrahim:
WRAS certificate to be submitted for the fittings

Manda Ravinder Reddy
Resident Engineer