

06.

WATER HEATER



WATER HEATER- ARISTON

APPENDIX A
BILLS OF QUANTITIES

			Ariston S.P.A Middle east (branch)
Sr No	Description	Unit	Rate (AED)
Total Qty for apts + other FOH/BOH areas			Make : Ariston Model : BLU R -Made in China (50L, 80L, 100L) Model : ARI - Made in Belgium (150L)
1	EW/H 50 L	Nos	265
2	EW/H 80L	Nos	305
3	EW/H 100L	Nos	355
4	EW/H 150L	Nos	800



3/21/2025

ANNEXURE B - MODEL SPECIFICATION		
SUPPLY OF ELECTRIC WATER HEATERS TO VARIOUS EMAAR PROJECTS		Ariston Water Heaters
Capacity	Location of use	Proposed Model
ELECTRIC WATER HEATERS		
50 Liters	APARTMENT AND CHANGING ROOMS(AS APPLICABLE)	Brand/Manufacturer : Ariston Model : BLU R 50 H Horizontal mounted 1200W
80 Liters	APARTMENT AND CHANGING ROOMS(AS APPLICABLE)	Brand/Manufacturer : Ariston Model : BLU R 80 H Horizontal mounted 1200W
100 Liters	APARTMENT AND CHANGING ROOMS(AS APPLICABLE)	Brand/Manufacturer : Ariston Model : BLU R 100 H Horizontal mounted 1200W
150 Liters	APARTMENT AND CHANGING ROOMS(AS APPLICABLE)	Brand/Manufacturer : Ariston Model : ARI 150 H THER Horizontal mounted 2000W

Best Regards,
Mohammed Marwan Al Ghaz
Pre-Sales Senior Specialist – Middle East & Caucasus
Ariston Group Spa
Middle East Branch – Dubai,UAE



Ariston SpA Middle East Branch
Dubai Airport Free Zone
Building # 6EA - Office # 704
P.O.Box : 54643, Dubai - U.A.E.





Date: 07-04-2025

To: Emaar Development PJSC

PO box: 9440, Dubai

United Arab Emirates

Technical compliance

SN	Electric water heater	Compliance
1	Provide and install in the positions indicated in the drawings electric water heaters.	By Contractor, Contractor needs to confirm with Ariston before, during and after installation to make sure the installation is according to manufacturer standard.
2	The heaters shall be of welded steel construction with corrosion resistant inner lining having guaranteed minimum life of 5 years.	Comply
3	Contractor & Manufacturer to provide 2 years warranty for the complete system. The lining shall have WRAS, NFS or equal certification.	Comply
4	An outer casing of enameled steel shall be provided, with a minimum of 25mm of cork, glass fibre or foamed plastic insulation between water chamber and outer casing.	Comply
5	The water chambers shall be tested to 8 bar and the water inlet shall be fitted with a safety unit comprising stopcock, non-return drain cock and relief valve. The relief valve discharge shall be taken to drain or to atmosphere	Comply
6	Storage water heater shall be fitted with a dial type thermometer and adjustable thermostat.	Comply
7	The heating elements shall be suitable for 230 volts' single phase 50 Hz supply.	Comply
8	Magnesium anode shall be provided.	Comply
9	The required capacities are shown on the drawings.	Noted & comply

Sign and Stamp

Mohammed Marwan Al Ghaz

Pre-Sales Senior Specialist – Middle East & Caucasus

Ariston Group Spa

Middle East Branch – Dubai, UAE



Ariston SpA Middle East Branch
Dubai Airport Free Zone
Building # 6EA - Office # 704
P.O.Box : 54643, Dubai - U.A.E.