

CERTIFICATE OF CONFORMITY

This certificate confirms the declared products meet stated: performance capabilities, material standards and product standards where applicable and are rigorously subject to 3rd-party assessment by internationally renowned certification bodies.

Description

Product Series: 10751 Gate Valve

Size range: DN15-DN80

Pressure Rating: PN20

Material

Body Material: bronze EN CC491K (BS EN 1982:2024, see below for standard defined limits)

Composition % (mass fraction)												
Grade	Element	Cu	Ni	P	Pb	Sn	Zn	Al	Fe	S	Sb	Sn
CC491K	Min	83.0	-	-	4.0	4.0	4.0	-	-	-	-	-
	Max	87.0	2.0	0.10	6.0	6.0	6.0	0.01	0.3	0.10	0.25	0.01

Hydrostatic Pressure Test

Seat Test Pressure: 22 bar with water

Shell Test Pressure: 30 bar with water

Test Standard(s): BS EN 12266-1 & BS EN 12266-2

Certifications

- **ISO 9001** - products supplied by Aalberts Integrated Piping Systems are done so under a quality management system approved to BS EN ISO 9001: 2015 by an independent 3rd party certification body (Certificate Number FM 00305).
- **WRAS & Regulation 4** - manufactured to the appropriate quality and standards as required in the Water Supply (Water Fittings) Regulations and Scottish Water Byelaws.

For Aalberts Integrated Piping Systems Ltd



Adam Lynaugh, Head of Quality UK