

CERTIFICATE OF CONFORMITY

This certificate confirms the declared products meet stated: performance capabilities, material standards and product standards where applicable and are rigorously subject to 3rd-party assessment by internationally renowned certification bodies.

Description

Product Series: 1260
Size range: ½" – 2"
Pressure Rating: PN20

Material

Body Material: CW511L (BS EN 12165:2024, see below for standard defined limits)

Composition % (mass fraction)											
Grade	Element	Cu	Al	As	Fe	Mn	Ni	Pb	Sn	Zn	Other
CW511L	Min	61.5	-	0.02	-	-	-	-	-	Rem.	-
	Max	63.5	0.05	0.15	0.1	-	0.3	0.2	0.1	-	0.2

Test Details

Hydrostatic Test Pressure: 30 bar

Certifications

- **ISO 9001** – products supplied by Aalberts Integrated Piping Systems are done so under a quality management system approved to BS EN ISO 9001: 2015 by an independent 3rd party certification body (Certificate Number FM 00305).
- **Regulation 4** – the products concerned have been certified as complying with UK Regulation 4

For Aalberts Integrated Piping Systems Ltd



Adam Lynaugh, Head of Quality UK