

## CERTIFICATE OF CONFORMITY

This certificate confirms the declared products meet stated: performance capabilities, material standards and product standards where applicable and are rigorously subject to 3rd-party assessment by internationally renowned certification bodies.

### Description

Product Series: P775 Brass Automatic Air Vent

Size range: ½"

Pressure Rating: PN10

### Material

Body Material: CW617N (BS EN 12165:2024, see below for standard defined limits)

| Composition<br>% (mass fraction) |         |      |      |    |     |    |     |     |     |      |       |
|----------------------------------|---------|------|------|----|-----|----|-----|-----|-----|------|-------|
| Grade                            | Element | Cu   | Al   | As | Fe  | Mn | Ni  | Pb  | Sn  | Zn   | Other |
| CW617N                           | Min     | 57.0 | -    | -  | -   | -  | -   | 1.6 | -   | Rem. | -     |
|                                  | Max     | 59.0 | 0.05 | -  | 0.3 | -  | 0.3 | 2.2 | 0.3 | -    | 0.2   |

### Certifications

- **ISO 9001** - products supplied by Aalberts Integrated Piping Systems are done so under a quality management system approved to BS EN ISO 9001: 2015 by an independent 3<sup>rd</sup> party certification body (Certificate Number FM 00305).

For Aalberts Integrated Piping Systems Ltd



Adam Lynaugh, Head of Quality UK