

CERTIFICATE OF CONFORMITY

This certificate confirms the declared products meet stated: performance capabilities, material standards and product standards where applicable and are rigorously subject to 3rd-party assessment by internationally renowned certification bodies.

Description

Product Series: PRV6 Pressure Reducing Valve

Size range: ½" to 4"

Pressure Rating: PN25

Materials:

Body Materials: CW625N (EN 12164) & CC770S (EN 1982) – controlled between limits in table below

Grade	Element	Cu	Al	As	Fe	Mn	Ni	Pb	Sn	Zn
CW625N	Min	62.0	0.5	0.02	-	-	-	1.2	-	Rem
	Max	64.0	0.7	0.15	0.1	0.1	0.2	1.6	0.3	-

Grade	Element	Cu	Zn	Pb	Sn	Fe	As	Ni	Al	Mn
CC770S	Min	62.0	Rem	0.2	-	-	0.04	-	0.5	-
	Max	64.0	Rem	1.6	0.3	0.3	0.14	0.2	0.7	0.1

Test Details

Shell Test Pressure: 37.5 bar

Certifications & Testing

- **ISO 9001** – products supplied by Aalberts Integrated Piping Systems are done so under a quality management system approved to BS EN ISO 9001: 2015 by an independent 3rd party certification body (Certificate Number FM 00305).
- **UK Regulation 4** - manufactured and tested to the appropriate quality and standards as required in the Water Supply (Water Fittings) Regulations and Scottish Water Byelaws.

For Aalberts Integrated Piping Systems Ltd.



Gavin Peters – Approvals Engineer