

Consultant: Dubai AL Prime Engineering Consultants Tel: +971 4 431 0663 Fax: +971 4 431 0663 PO Box 116781 Abu Dhabi Prime Engineering Consultants Tel: +971 2 679 5699 Fax: +971 2 679 5699 PO Box 108553		Client: PREMIER SCHOOLS[™] INTERNATIONAL (LLC)		Contractor: ابسونز ABSONS General Contracting LLC P.O. B. 6152 Abu Dhabi, UAE Tel: +9712-6340545 Email: info@absonscontracting.com			
PROJECT NAME: GEMS FOUNDER SCHOOL (G+3) Plot F-04, Sector SE45-01, Masdar City, Abu Dhabi, UAE							
MATERIAL SUBMITTAL - MEP				Str.	Arch.	MEP.	☐ Elect. ☐ Plum. ☒ HVA/C ☐ F/ F. ☐ F/A.
REF. NO.	AGC-P0038-MS-MEP-0073-R0			☐	☒	☒	
TO:	PRIME ENGINEERING CONSULTANTS						
Prepared By:	M/S ARCO ELECTROMECHANICAL LLC			 Eng. Osama Arroub Project Manager			
Date:	07-August-2026						
Main Contractor:	ABSONS GENERAL CONTRACTING LLC		Supplier	JUNAID SANITARY MATERIALS TRADING L.L.C			
Consultant's Signature:							
S.I. NO.	Material Description			Brand	Rev.	NOTES	
1	ALTERNATIVE PROPOSAL FOR CHILLED WATER VALVES			PEGLER	0		
Attached Documents: 1.							
Comments: 1-PEGLER shall be subject to Client approval as an alternative manufacturer to the approved vendor list. 2-Proposed V850 gate valve is not acceptable against the specified 65 mm balancing valve requirement. Provide a dedicated PN16 balance valve complete with regulating device, indicator and pressure test points as specified. Revise compliance statement accordingly. 3-Proposed V952 double regulating valve shall comply with PN16 rating and all specified balancing requirements including pressure test points. 4-All valve sizes, types, locations and applications shall be as per approved CHW shop drawings and valve schedule. 5-Valve pressure ratings, end connections, materials and accessories shall comply with project specifications and approved system requirements. 6-Valves on insulated CHW piping shall be provided with the required stem/neck extension to maintain insulation and vapor barrier continuity. 7-Installation shall comply with the approved method statement, manufacturer recommendations and project specifications.				A - Approved	Submittal status	A	
				B - Approved as noted		B	
				C - Revise and Re-submit		C	
				D - Rejected		D	
Received Date		Returned Date		Date received by contractor			
		18/8/2026					
Signature		Signature		Signature			