Material Submittal Form

DMS Transaction ID: 34252

Submittal No.	EXT-0523-MAT-MEP-MEC-01	**Date**	July 12, 2023
Project Name	Al Forsan International Equestrian Club Expansion /Phase 02		
Client/Project Owner	Tawazun Industrial Park (TIP)	**Project ID No.**	
Consultant	Bayaty Architects	**Contract No.**	02-4414646
Contractor	Al Eslah General Cont. Est.	**Contract No.**	+971 54-9952140

Disciplines: ☐ARCHITECTURAL ☐STRUCTURAL ☒MECHANICAL ☐ELECTRICAL ☐Others

Spec. Ref.	BoQ. Ref.	Drawing Ref No.	Material Description	Remarks
Section 22 13 16 Sanitary Waste & Vent Piping	-		**Material submittal for HDPE Drainage Pipes & Fittings** Manufacturer: Cosmoplast Supplier: Cosmoplast Industrial CO. LLC	1 hardcopy

Submittal Attachments Checklist:

☒ Material Source Declaration Form (MSDF)	☒ Department of Economic Development (Registration).
☒ Copies of Relevant Parts of Specs, BoQ & Drawings	☐ Manufacturer / Supplier's Guarantee (as per Contract)
☐ Technical Comparison Table	☒ Previous Approvals
☒ Manufacturer's Technical Data / Original Catalogues	☐ Applicator's Method Statement
☒ Recent Test Reports / Certificates	☒ Others (please specify), sample attached

Comments / Remarks

Refer to Attached Comments Sheet

Status: ☐APPROVED ☐NOT APPROVED ☐FOR INFORMATION ☐REVISED & RESUBMIT
☒APPROVED WITH COMMENTS *(Action is required and Document revision needs to be provided to acquire on "Approved" status only)*

*Approval shall not relieve Contractor of his Liabilities Under the contract or constitute authorization of any change to contract documents.

Contractor Representative	**Eng. Akram Issa** (Project Manager)	Company	Al Eslah Gen. Cont.
Date		Signature/Stamp	

Consultant Representative	**Eng. Islam Atef Soltan** (Resident Engineer)	Company	Bayaty Architects
Date		Signature/Stamp	

Client Representative		Company	
Date		Signature/Stamp	

Confidentiality Notice: This document is confidential and contains proprietary information and intellectual property of TIP. Neither this document nor any of the information contained herein may be reproduced or disclosed under any circumstances without the express written permission of TIP. Please be aware that disclosure, copying, distribution or use of this document and the information contained therein is strictly prohibited.

RECEIVED
14 JUL 2023
AL BAYATY CONSULTANT AL FORSAN SITE OFFICE
Sign:

SUPERVISION CONSULTANT COMMENTS SHEET

Project Name	AL FORSAN EQUESTRIAN CLUB EXPANSION -PHASE 2
Client	AL FORSAN INTERNATIONAL SPORT RESORT
Employer (PM)	TAWAZUN INDUSTRIAL PARK
Consultant/Engineer	Al BAYATY ARCHITECTS & ENGINEERING CONSULTANCY
Contractor	AL ESLAH GEN. CONT. EST.

Submittal. Ref. No.	EXT-0523- MT- ME-001- Rev-00
Rev. No.	00
Submission Date	14-07-2023
Title	Material Submittal for HDPE Drainage Pipes & Fittings

Item Description: HDPE pipes and fittings Brand COSMOPLAST - UAE (Approved as Noted)

The proposed manufacturer COSMOPLAST– HDPE -Pipe and fittings -UAE Origin to supply project is technically accepted subject to: -

1- Proposed HDPE Pipe shall comply with project specifications.
2- All pipes and fittings dimensions in the shop drawing are normal internal diameter mm
3- All HDPE should be PE 100
4- A sample board for pipe for HDPE pipes and fitting is required for engineer approval.
5- One Mockup to be installed to be provided at the site.
6- All pipes and fittings shall be compatible with each other.
7- Pipes to be supplied site kitemark.
8- HDPE Pipes and fitting sizes details as per approved shop drawing.
9- Electrofusion process to be as manufacturer recommendation and approval method statement.
10- Method statement for pipes laying, join welding and testing to be submitted for engineer approval.
11- Final approval subject T & C of the domestic water system
12- Warranty certificate shall be as per project condition.
13- A certificate of origin is required upon delivery.

Engineer Approval	☐ A – Approved ☐ C – Revise and resubmit ☑ B – Approved with Comments ☐ D – Rejected
Name	Islam Mohamed Atef – Resident Engineer
Date & Signature	

Presidential Court

Engineering and Technical Projects Division

ديوان الرئاسة

إدارة المشاريع الهندسية والفنية

Proj. #	*Detainee Building*	**Material Submittal (MEP)**	Serial #	**DR-10**	Rev #.	**00**

☐ Plumbing ☑ Mech. ☐ Elec ☐ Elv ☐ Civil ☐ Arch. ☐ Landscaping

Project's Name:	*Detainee Building at Madinat Zayed-Western Region, Abu Dhabi, UAE*
Consultant:	*Bainona Engineering Consultant*
Contractor:	*Trojan General Contracting LLC (TGC)*
Sub-Contractor:	*Royal Advance Electromechanical Works (RA)*

Item Details

Item Description	***HDPE Drainage Pipes & Fittings***
Specification / BOQ / Drawing / Reference	***Page No. 31 & 32***
Material Proposed	***Refer to Technical Data Sheet***
Manufacturer / Local Supplier	***M/s. Cosmoplast Industrial Co. L.L.C***
Reason for Alternative	
Remarks	

List of Enclosure

(Tick the Related Box)

- ☑ Vendor's Technical Literature
- ☑ Compliance Statement
- ☑ Previous Test Result
- ☑ Copy of Related Specs
- ☑ Samples
- ☑ Other (Specify)
- ☑ Catalogues
- ☑ Submitted material Specifications

Main Contractor Statement: *We certify that the material submitted herewith has been reviewed in details and in compliance with the contract drawings and specifications except as otherwise stated here above.*

For Consultant Use

Date:

Consultant Recommendation:

☐ **Approved**

☑ **Approved As Noted**

☐ **Revise & Resubmit**

☐ **Not Approved**

Signature:

Date: 17/07/2023

بينونة للإستشارات الهندسية BAINONA Engineering Consultancy Project 1692 Detainee Building project Western Region Abu Dhabi UAE

For Client Use

Date:

Client Decision:

☐ **No Objection, Proceed**

☐ **Objection, Resubmit**

H.O Team	***PM Signature*** for
Acknowledgment Receipt	
Consultant Stamp and Date	***Contractor Stamp and Date***

BAINONA Project 1692 Detainee Building project Engineering Consultancy Western Region Abu Dhabi UAE

14 Jul 2023

RECEIVED

ترجان للمقاولات العامة ذ.م.م TROJAN GENERAL CONTRACTING L.L.C DESIGN AND BUILD OF DETAINESS BUILDING TG2111

Presidential Court

Engineering and Technical Projects Division

ديوان الرئاسة

إدارة المشاريع الهندسية والفنية

SUBMITTAL REVIEW COMMENTS

Project: *Detainee Building at Madinat Zayed-Western Region, Abu Dhabi, UAE*

Submittal Number: *TGC-RHP4-MTS-MEP-DR-0010 Rev.00*

Submittal Subject: *Material Submittal for HDPE Drainage Pipes & Fittings*

Manufacturer / Supplier: *M/s. Cosmoplast Industrial Co. L.L.C*

Comments Date: 17/07/2023

REVIEW STATUS: - Approved as noted -B

Consultant's Comments:

1- No objection for HDPE pipes and fittings from cosmoplast ,UAE,
2.HDPE pipes and fittings manufacture according to BSEN 1519-1,SDR 26 SN 4.
3. All fittings shall be Electro fusion.
4.Max working temperature of HDPE pipe shall be 100 degree celcius.
5.Fire rated acoustic lagging in HDPE pipes connected to kitchen network shall be provided.
5- Arrange mock up for installation at site for review and approval .
6- Follow approved shop drawing and kitchen specialist drawing for size of HDPE.
7.HDPE pipes and fitting shall be marked by BSI kites mark.
8.Installation shall be in accordance of manufacture recommendation.
9.Test certificate shall be submitted along with delivery .

Reviewed By: SHIHABUDHEEN

Signature:

بينونة للإستشارات الهندسية
BAINONA
Engineering Consultancy
Project 1692
Detainee Building project
Western Region Abu Dhabi UAE

Client Comments:

Reviewed By:

Signature

Presidential Court | ديوان الرئاسة

Engineering and Technical Projects Division | إدارة المشاريع الهندسية والفنية

Sample Submittal No. (TGC-RHP4-MTS-MEP-DR-0010-S REV.00)

☐ Plumbing ☑ Mech. ☐ Elec ☐ Civil ☐ Arch. ☐ Landscaping

Project's Name : ***Detainee Building at Madinat Zayed-Western Region, Abu Dhabi, UAE***

Consultant : M/s. Bainona Engineering consultancy

Contractor : M/s. Trojan General Contracting LLC

Sub-Contractor: M/s. Royal Advance Electromechanical Works (RA)

Material Details

		List of Enclosure
Item Description	***Sample Submittal for HDPE Drainage Pipes & Fittings***	(Tick the Related Box)
Specification / BOQ / Drawing / Reference	***Page No. 31 & 32***	☐ Vendor's Technical Literature
Material Proposed	***Refer to Technical Data Sheet***	☐ Compliance Statement ☐ Previous Test Result ☐ Copy of Related Specs
Manufacturer / Local Supplier	***M/s. Cosmoplast Industrial Co. L.L.C***	☑ Sample ☐ Other (Specify)
Reason for Alternative		☐ Catalogues
Remarks		☐ Submitted material Specifications

Main Contractor Statement: We certify that the material submitted herewith has been reviewed in details and in compliance with the contract drawings and specifications except as otherwise stated here above.

Main Contractor's Signature: *Date*

Consultant Received: Date

Consultant's Comments:

☐ **Approved** ☒ **Approved As Noted** ☐ **Revise & Resubmit** ☐ **Not Approved**

Signature: _____ ***Date:*** _____

BAINONA Engineering Consultancy
Project 1692
Detainee Building project
Western Region Abu Dhabi UAE

Client's Representative's Received: *Date*

***Client's* Representative's Comments:**

☐ **No Objection, Proceed** ☐**Objection, Resubmit**

Signature: _____ *Date:* _____

Consultant's Representative's Received: *Date:*

Contractor's Representative's Received: *Date:*

Contractor remains fully responsible for the approved material under the terms and conditions of the contract
Material reject must be resubmitted for approval

SUBMITTAL REVIEW COMMENTS

Project: *Detainee Building at Madinat Zayed-Western Region, Abu Dhabi, UAE*
Submittal Number: *TGC-RHP4-MTS-MEP-DR-0010 Rev.00*
Submittal Subject: *Sample Submittal for HDPE Drainage Pipes & Fittings*
Manufacturer / Supplier: *M/s. Cosmoplast Industrial Co. L.L.C*
Comments Date: 17/07/2023

REVIEW STATUS: - Approved as noted -B

Consultant's Comments:

1.Submit to mock up for installation
2.Storage and installation shall be as per manufacture 's recommendation
3.All Sizes of pipes and fitting shall be Electro fusion .
5.Pipes and fittings shall be mentioned with BIS Kites marks

Reviewed By: SHIHABUDHEEN
Signature:

بينونة للإستشارات الهندسية
BAINONA
Engineering Consultancy
Project 1692
Detainee Building project
Western Region Abu Dhabi UAE

mimar

PROJECT 588- VIDA 1, 2, 3 &4 (BLOCK K) B+G+9F+ROOF (HOTEL + BRANDED RESIDENTIAL & SERVICED APARTMENTS AT MUWAILAH, SHARJAH COMMENTS SHEET	
DESCRIPTION	HDPE PIPES
BRAND	COSMOPLAST
REF. NO.	GACP-7907-VIDA-MECH-MAR-004
REV.	01

Engineers Response:

1. All HDPE pipes should be PE100.
2. Main kitchen, main laundry and F&B areas drainage pipes shall be all HDPE.
3. All main pipes after the Main kitchen, main laundry and F&B shall be HDPE.
4. All fittings shall be used from the same manufacturer.
5. Method statement to be provided prior to start on installation.
6. Mockup installation to be provided at site.
7. All connections (fusion) on site shall be as per manufacturers recommendations.
8. All pipes shall have kitemark certified.
9. Final approval is subject to site installations, T&C and authority approval.
10. All material delivery shall be from the manufacturer direct, no MIR will be accepted from trader.
11. All material shall be from fresh manufactured patches.
12. All material shall be stored as per manufacturer recommendations, no and material allowed to store at outdoor conditions.

Additional comments:

1. **No objection for the proposed HDPE pipes and fittings from Cosmoplast, subject to having Kite mark or equivalent approvals and full compliance to the contract and engineer comments.**
2. **Contractor to determine the thermal expansion with considering the project operating temperature and apply while selecting the suitable socket. the same shall be approved before installation.**
3. **Contractor to provide the kite-mark documents for the fittings within one week, unless this review would be nullified.**
4. **"Conditional Approval".**

STATUS	**Approved as noted**
Mechanical engineer signature	15.6.23 W.
Resident engineer signature	

Distribution:	❑ PM (Original)	❑ Consultant	❑ QS	❑ Contractor	❑ Others

MATERIAL SUBMITTAL

mimar Emirates Engineering Consultant

GULF ASIA Contracting Co. LLC

ARADA

الجادة aljada

PROJECT: B+G+9F+ROOF (HOTEL+BRANDED RESIDENTIAL & SERVICED APARTMENTS AT MUWAILAH, SHARJAH

Submittal Title:	HDPE PIPES AND FITTINGS	Date	30-May-2023
Submittal No.:	GACP-7907-VIDA-MECH-MAR-004	Revision	01

We are sending herewith under separate cover (please check one box):

☐ Shop drawings	☑ Sample	☐ Quality Plan	☐ Inspection & Test Plan	☐ Calculations
☑ Test Results	☐ Schedule	☑ Manufacturer's data	☐ Health & Safety Plan	☑ Certificate
☑ Specification	☐ Guarantee	☐ Method Statement	☐ Operation Manual	☐ Other (PQD)

Ref. No.	Description	Rev	Copies	Remarks
1	Material submittal for HDPE Pipe and Fittings	01	1 Soft + 1 Set Hard Copy	
Spec./Drawing ref:				

Subcontractor/Supplier/Manufacturer: M/s.Cosmaplast Industries Co LLC (Cosmaplast)

Contractor Name: Engr.Masood Ahamed

Signature:

Date: 30/05/2023

Received By:

RECEIVED 31 MAY 2023 MIMAR ENGINEERING CONSULTANTS CONSTRUCTION

We certify that the documents / materials submitted herewith have been reviewed in detail and are in strict conformance with the contract drawings and specifications except as otherwise stated.

Signature / Date:

Consultant Remarks

Refer to attached comments sheet

☐ Approved ☑ Approved as noted ☐ Revised & Resubmit ☐ Not Required ☐ Not Approved

Reviewed By : Wael Shawky

Signature : 4.6.23

Project Manager : **Engr.Ahamed Azzam**

Signature :

Received By

GAC 15 JUN 2023 RECEIVED

Signature / Date:

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of The Contract. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction, coordinating his work with that of other trades and performing his work in a safe and satisfactory manner.

mimar

PROJECT 588- VIDA 1, 2, 3 &4 (BLOCK K) B+G+9F+ROOF (HOTEL + BRANDED RESIDENTIAL & SERVICED APARTMENTS AT MUWAILAH, SHARJAH COMMENTS SHEET	
DESCRIPTION	HDPE PIPES
BRAND	COSMOPLAST
REF. NO.	GACP-7907-VIDA-MECH-MAR-004
REV.	01

Engineers Response:

1. All HDPE pipes should be PE100.
2. Main kitchen, main laundry and F&B areas drainage pipes shall be all HDPE.
3. All main pipes after the Main kitchen, main laundry and F&B shall be HDPE.
4. All fittings shall be used from the same manufacturer.
5. Method statement to be provided prior to start on installation.
6. Mockup installation to be provided at site.
7. All connections (fusion) on site shall be as per manufacturers recommendations.
8. All pipes shall have kitemark certified.
9. Final approval is subject to site installations, T&C and authority approval.
10. All material delivery shall be from the manufacturer direct, no MIR will be accepted from trader.
11. All material shall be from fresh manufactured patches.
12. All material shall be stored as per manufacturer recommendations, no and material allowed to store at outdoor conditions.

Additional comments:

1. **No objection for the proposed HDPE pipes and fittings from Cosmoplast, subject to having Kite mark or equivalent approvals and full compliance to the contract and engineer comments.**
2. **Contractor to determine the thermal expansion with considering the project operating temperature and apply while selecting the suitable socket. the same shall be approved before installation.**
3. **Contractor to provide the kite-mark documents for the fittings within one week, unless this review would be nullified.**
4. **"Conditional Approval".**

STATUS	**Approved as noted**
Mechanical engineer signature	15.6.23 W.
Resident engineer signature	

Distribution:	❑ PM (Original)	❑ Consultant	❑ QS	❑ Contractor	❑ Others

Heat&Power

Material Approval Request (MAR)

Contract Title:	CREEK PALACE, A016, DUBAI, UAE				
Contract/ LOA No.:	6950	Plot No.	4154947		
Employer:	EMAAR	Building Permit	B1915768		
Engineer:	ARCHGROUP CONSULTANTS				
Main Contractor:	AL SAHEL CONTRACTING CO.LLC	Unifier Ref:			
Reference No.:	J264-H&P-MAT-PL-0011	Revision:	00	Date:	24/03/2023

Tick the relevant items below:

☐ Civil/Structural ☐ Architectural ☒ MEP ☐ Landscaping ☐ Others:_____

We are sending herewith the Documents/ Drawings / Samples listed below.

Material Information		
Name of Product:	HDPE DRAINAGE PIPES & FITTINGS	
Location of use:	Basement 3, 2, 1 Ground & First Floor	
Name Manufacturer:	COSMOPLAST	
Source / Country of Origin:	UAE	
Name Local Agent/Supplier:	COSMOPLAST INDUSTRIAL CO. LLC	
Specification / Control Document Reference:	Mechanical Specifications Section 05	
Alternative to Specified product:	☐ Yes NA	☐ No NA
Reason for use of alternate product:	NA	
Cost Impact:	☐ Yes	☒ No
Time Impact:	☐ Yes	☒ No
Description of Attachments (Spec., Brochure, Sample etc.):	Specification, Brochure, previous approval	
Description of Samples:	HDPE Pipe & Fitting	

Compliance Statement: The Contractor hereby confirms that the submitted items have been reviewed in detail and are correct and in accordance with the Contract Documents except otherwise stated.

Compliance with local Authorities Regulations: ☒ Yes ☐ No

Sr Project Manager (H&P)	MEP Manager (ASCC)	PD/PM (ASCC)	QA/QC (ASCC)	Date:
Name: Vipin V V	Benedict Prince	Nabil Abdelmahdy		
Signature:				

AL SAHEL CONTRACTING CO. L.L.C. 28 MAR 2023 SUBMITTAL REV. No.: SIGN.:

Engineer Comments:

Refer atatched sheet for comments

S Mathan Kumar 04 04 23

Engineer's Representative: Sr.RE/Project Director _____ Date 05.04.23

Engineer Review Code:

☐ A- Approved
☐ B- Approved_As_Noted
☐ C- Not_ Approved_ Resubmit
☐ D- Incomplete_ Resubmit
☐ E- Information_ Record

Employer Comments:

Employer _____ Date: 10/04/2023

Action Code:
A - ☐
B - ☑
C - ☐
D - ☐
E - ☐

Distribution: ☐ Contractor (Original) ☐ PMO ☐ Engineer

NOTE: The Engineer's approval shall not in any way relieve the Contractor of his obligation under the Contract. The Contractor shall be solely responsible for the soundness and the correctness of the submitted materials and documents.

List of Selected Projects where Cosmoplast HDPE Drainage Pipes and Fittings have been Installed

PROJECT	CLIENT	CONSULTANT	CONTRACTOR
Telecommunication Regulatory Authority New Building (3B+G+M+3TYP)	Telecommunication Regulatory Authority (TRA) - Federal Authority	M/s. ENG. Adnan Saffarini	M/s. Zener Steward Electromechanical Works LLC
MEERA SHAMS	M/S. ALDAR	M/S. AECOM	M/S. FIBREX
3B+GF+24 Floor 'Nilona Tower' MHEA on Plot No. B1.001 @ Dubai, Health Care City Phase II	DHCC	ARIF & BINTOAK / CKR CONSULTING ENGINEERS	TRANS GULF
G+2 Podium+13 Storey+Roof Hotel Tower on Plot no. IBS 002, Jabal Ali 1st, 591 Dubai	NAKHEEL	ARCHGROUP CONSULTANTS	UNITED ENGINEERING
HABSHAN CLINIC NEW EXTENSION	M/s. ADNOC	MURBANISM PLANNING ARCHITECTURE CONSULTANCY LLC.	M/s. International mechanical & electrical company (IMECO)
DESIGN AND BUILD OF ADDITIONAL REQUIREMENTS AT EXISTING RUWAIS HOSPITAL	M/s. ADNOC		CODE CONTRACTING
DSOA - P052 - SILICON PARK	M/s Dubai Silicon Oasis Authority	M/s Design & Architecture Bureau |M/s IAN Banham & Associates	M/s China State Construction Engrg. Corp.(Middle East) (L.L.C)
Zayed University, Abu Dhabi Campus	M/S Al Habtoor – Murray Roberts Joint Operation (HMR)	Caunsult Maunsell / AECOM	Al Habtoor Specon – Hastie International JV (HSH)
Ruwais Housing Complex Expansion -Phase III . Construction of Bachelor Villas – Package II	ADNOC	Al Torath Engineering Consultant	Al Jaber Building / Emirates Technical & Thermal Systems.
Ruwais Housing Complex Expansion – Phase III Married Staff Accommodation, Facilities and Related	ADNOC	TELE	Al Jaber Building / Emirates Technical & Thermal Systems.
Ruwais Housing Complex Expansion Phase III Construction of Married Staff Accommodation Facilities and Related Infrastructure (Package IV) Project No. 6005,	ADNOC	Al Torath Engineering Consultant	ASCON / Trinity Engineering Services LLC

List of Selected Projects where Cosmoplast HDPE Drainage Pipes and Fittings have been Installed

PROJECT	CLIENT	CONSULTANT	CONTRACTOR
Ruwais Housing Complex Expansion Phase III Construction of Bachelor Accommodation (Package II) Project No. 6010, Agreement No. 116010 C1	ADNOC	ARCH. & PLANNING GROUP	Dubai Masters
ADNOC, Al Ruwais Housing Complex Expansion, Phase-3, Package 4" @ Al Ruwais, Abu Dhabi	ADNOC	Al Torath Engineering Consultant	International Electro-Mechanical Services Co. LLC
Ruwais Housing Complex Expansion Phase III	ADNOC	Thorath Engineering Consultants	Ras Engineering LLC
Ruwais Housing Complex Expansion – Phase II Construction of New Schools Complex Project No.5988 – Agreement no. 115988C1	ADNOC	-	Code Contracting Company LLC
License and Information Technology Building Project. No. CO-15/1/140-08	Abu Dhabi Police	WINNER CONSULTING ENGINEERS	BIPOWER Engineering & Construction
3B+GF+24 Floor 'Nilona Tower' MHEA on Plot No. B1.001 @ Dubai, Health Care City Phase II	DHCC	ARIF & BINTOAK / CKR Consulting Engineers	Trans Gulf
Al Fallah Community	ALDAR	Al Torath Engineering Consultants	ALEC-MEP
Centro Hotel	Crystal Hospitality Investment L.L.C.	GA Architects And Engineers	Drake & Scull International
Khalifa Port and Industrial Zone, Contract 209	Abu Dhabi Ports Company	Halcrow Engineering	Rotary Gulf LLC
Residential Building For Mr. Mohamed Sultan Al Mansouri	-	Hanoover Consulting Engineering	Al Mansouri 3B LLC
Millennium Golf Resort	-	Architectural Consulting Group (ACG)	Balbadi / Verger et Delporte
Bloom Gardens Plot 102-106 E-48/Salam Street, Abu Dhabi	Bloom Emirates Properties	World Planners Consultant Engineer LLC	Emirates Link Matauro LLC / Galaxy Advanced General Contractor Co. LLC
Duabi Sewerage Job No.DS83/3/1 Dubai	Dubai Municipality	Khatib Alami Metcalf Eddy	Lilley Int'l