B. **Shop Drawings**: For drainage system, include plans, elevations, sections, and details.

C. **Field Test Reports**: Indicate and interpret test results for compliance with performance requirements.

1.6 QUALITY ASSURANCE

A. Piping materials shall bear label, stamp, or other markings of specified testing agency.

B. Comply with NSF 14 or BS EN standards for "Plastics Piping Systems Components and Related Materials," for plastic piping components.

C. Ensure no soil pipes will be installed at floor below (high level of any apartment) ceilings.

PART 2 - PRODUCTS

2.1 PIPING MATERIALS

A. Transition Couplings for Underground Pressure Piping: AWWA C219 metal, sleeve-type coupling or other manufactured fitting same size as, with pressure rating at least equal to and ends compatible with, piping to be joined.

2.2 UPVC PIPE AND FITTINGS (BELOW GRADE)

A. DN75 and larger to BSEN-1401-1, SDR-34, push fit type only.

2.3 UPVC PIPING (ABOVE GRADE)

A. **UPVC Pipe**: DN 75 and larger to BSEN 1329, SDR-34, solid-wall drain, waste, rainwater and vent.

B. **UPVC Fittings**: DN 75 and larger to BSEN 1329, SDR-34, waste, and vent patterns solvent weld only.

C. **ABS Pipe fittings (Below ground/Above Grade)**: DN 50 and smaller to BS 5254, SDR-34 solvent weld.

2.4 HDPE PIPING

A. **HDPE Pipe**: Smooth bore, single, solid wall drain, waste, and vent Bell and Spigot with electro-heat fused fittings. To BSEN 1519

1. HPDE Fittings: electro-heat fused, socket type, made to drain, waste, and vent patterns.

B. **HDPE Special Fittings**: Drainage-pattern tube and tubular fittings with ends as required for application.

PROJECT : **DRY DOCKS NEW ADMIN OFFICE BUILDING & MULTISTOREY PARKING**
CLIENT : **M/s. DRY DOCKS WORLD - DUBAI FZCO**
MAIN CONTRACTOR : **M/s. DESIGN D ENGINEERING CONSULTANCY**
CONSULTANT : **M/s. RAQ CONTRACTING L.L.C**
MEP : **M/s. PRIME TECHNOLOGIES L.L.C**
PRODUCT : **HDPE DRAINAGE PIPES & FITTINGS**

SPEC./CLAUSE	REQUIRED MATERIAL	COSMOPLAST STATEMENT	REMARKS
	HDPE PIPE : smooth bore, single solid wall drain, waste and vent bell and spigot with electro-heat fused fittings. to BSEN 1519 **1. HPDE Fittings : electro - heat fused , socket type, made to drain, waster and vent patterns**	The Proposed HDPE Drainage pipes according to BSEN1519-1 Series S 12.5, SDR 26 SN 4 (superseded DIN 19535) suitable for Electro-Fusion Techniques. The Proposed HDPE Drainage fittings according to BSEN1519-1 Series S 12.5 SDR 26 SN 4 (superseded DIN 19535) and ISO 8770 suitable for Electro-Fusion Techniques. **Note:** All fittings can be joined by using electro fusion couplers as demonstrated in our catalogue.	**COMPLY**

P.O.Box: 34862
Dubai - U. A. E.
Junaid Sanitary & Electrical Materials Trading (L.L.C) (Dubai Br.)

Date: 16.05.2024