




Confirming the working position of 21S4 valves with a Magnet and ruler

As measured with a R2 K gen 21S4 valve.
Unless noted or shown, all pictures are oriented
with the compressor discharge on top and the
pilot assembly on the back side.




Cooling cut away

Cooling



Heat cut away


Heating




Valve is approx $8 \frac{3}{4}$ " across
the metal plates holding the white seals will attract a strong
magnet. *

Measure to confirm the position of both plates as shown in the
following pictures.


*expanded vertical view. Profile has been changed for ease of viewing .



Inside the 21S4 cooling position



Inside the 21S4 heating position



Tech in action/unit in cool / valve in
cool



Tech in action / unit still in cool/ valve
stuck in heat

