Hisham A. Kattan
Company Representative
Abqaiq & Khurais Restoration Projects Division
Onshore Maintain Potential Projects Department

SAUDI ARABIAN OIL COMPANY -SAUDI ARAMCO Room 201A, Floor 2, B Wing, South Admin Building, PO 19653, Postal Code 31311 Abqaiq, Saudi Arabia Tel: +966 13 578-6817 Mbl: +966 55-116-3480



October 24, 2021

A&KRPD-L-0342-21

NON-GBS SPECALISED SCAFFOLD CONTRACTOR SUBMITTAL

Response Required: No

Jay-ar T. Dacquel, Al Rushaid Construction Co. Ltd. P.O. Box 31688, Al-Khobar 31952, KSA Tel. No. 013-801-0000 Fax No. 013-801-0177

Ref: ARCC Non-GBS SSC submittal to Loss Prevention Global Safety Assessment & Compliance Div.

According to letter LP/GSACD-058-2021 received from LP/GSACD the Specialized Scaffolding Contractor Evaluation Team (SSCET), facilitated by Loss Prevention Global Safety Assessment and Compliance Division (GSA&CD) has completed its assessment of Al-Rushaid Construction Company Ltd. (ARCC) for consideration as a Non-GBS specialized scaffolding Contractor. In accordance with GI 8.001, Safety Requirements for Scaffolding, and the approval procedure for Non-GBS specialized scaffolding contractors, the SSCET has determined that ARCC meets the requirements to be recognized as such.

As specified in GI 8.001, as a Non-GBS contractor ARCC will only be permitted to design and erect specialized scaffolding, and scaffolding over 12.2 meters, for their own use. Specifically, ARCC is not allowed to build scaffolding for use by others, nor shall other contractors use ARCC-built specialized scaffolds to perform work. Non-compliance with this requirement will result in ARCC no longer being recognized as a Non-GBS specialized scaffolding contractor, and will jeopardize their eligibility to perform future work at Saudi Aramco projects and facilities. This recognition is considered valid for three (3) years from the date of this letter after which a formal review for revalidation is required.

ARCC has been included in the list of approved Non-GBS specialized scaffolding contractors that is located on the LP intranet site https://sharek.aramco.com.sa/orgs/30001886/Pages/Scaffolding.aspx

Should you have any question, please contact Robert L Spence on 872-9124 or Faisal K. Al-Harbi on 673-3003 of the SSCET.

Hisham A. Kattan, Company Representative Abgaig & Khurais Restoration Projects Division

YFS/:fk

Cc: Department Manager, OMPPD Sr. Project Engineer, A&KRPD Project Engineer, A&KRPD Letter Book file